

CANOPY: GALV. STL CHANNEL PERIMETER FRAME MITERED AND WELDED W/ 2x6 INFILL @ 16" O.C. 5/8" SHEATHING HUNG FROM (2) 7/8" O A36 GALV. SMOOTH SHANK ROD W/ MACHINE THREADED ENDS TO MATE WITH CLEVIS PIN @ ENDS. 3/8" PLATE TANGS TOP AND BOT.

CONTINUOUS (2) 2x12 (INSIDE TYPICAL RIM) TO EXTEND 4'-0" BEYOND 'BUMP OUT' - STAGGER SPLICE LSL RIM TO LVL W/ 4'-0" MIN. OVERLAP - TYP. THIS WALL

DOUBLE (BOTH SIDES OF POST) MSTA52 @ POST TO FLOOR TO POST CONNECTION @ THIS SHEAR WALL 2ND FLOOR - TYP.

2x12 @ 16" O.C.

(4) STUD PACK @ CANOPY ATTACHMENT - TYP.

(2) 2x10 HEADER @ UNDER HUNG WALL

CANOPY: GALV. STL CHANNEL PERIMETER FRAME MITERED AND WELDED W/ 2x6 INFILL @ 16" O.C. 5/8" SHEATHING HUNG FROM (2) 7/8" O A36 GALV. SMOOTH SHANK ROD W/ MACHINE THREADED ENDS TO MATE WITH CLEVIS PIN @ ENDS. 3/8" PLATE TANGS TOP AND BOT.


BEARING WALL ABOVE FULL HEIGHT BLOCKING @ BEARING WALL ABOVE - TYP.

2x12 @ 16" O.C.


2x INFILL HEADER AS NEEDED @ BUMP OUT SIDE WINDOWS - TYP.

DOUBLE (BOTH SIDES OF POST) MSTA52 @ POST TO FLOOR TO POST CONNECTION @ THIS SHEAR WALL 2ND FLOOR - TYP.

FRAMING PLAN SYMBOLS KEY	
□	WOOD POST
○	STEEL COLUMN
(X)	NUMBER OF WOOD STUDS IN POST BELOW
A	COLUMN ABOVE THIS LEVEL
C	COLUMN CONTINUOUS THROUGH THIS LEVEL
←	JOIST BEARING
→	CONTINUOUS JOIST WITH INTERMEDIATE BEARING
—	FLUSH FRAMED JOIST BEARING WITH HANGER
—	WOOD STUD BEARING WALL BELOW
—	OVER FRAMING BY OTHERS - TYP
—	NUMBER OF TRIM STUDS UNDER HEADER
—	NUMBER OF KING STUDS ADJACENT TO HEADER



SECOND FLOOR FRAMING PLAN



- NOTES:
- SEE SHEET S1.0 FOR GENERAL STRUCTURAL NOTES
 - ALL WOOD COLUMNS IN 2x6 WALLS SHALL BE 3-2x6 AND IN 2x4 WALLS SHALL BE 3-2x4 UNLESS NOTED OTHERWISE ON PLANS
 - ALL BEAMS ARE DROPPED, UNO
 - ALL HEADERS IN 2x6 BEARING WALLS ARE (2) 2x6 NO.1 GRADE SPF MIN, UNO
 - ALL HEADERS IN 2x4 BEARING WALLS ARE (2) 2x6 NO.1 GRADE SPF MIN, UNO
 - ALL FLOOR SHEATHING TO BE 3/4", SEE GENERAL NOTES FOR ADDITIONAL INFORMATION - TYP

PROJECT NO. **16-0080**
 PROJECT NAME **Merrill Street - 7 unit**
 PORTLAND, ME

REVISIONS	DATE
1	11/11/16
2	12/15/16
3	12/20/16
4	03/09/17
5	

PERMIT SET

DRAWN BY **MKL**
 SHEET TITLE **SECOND FLOOR FRAMING PLAN**

ISSUE DATE **8/23/16**
 SHEET SCALE **AS NOTED**

S
S1.3