



Helen Donaldson <hcd@portlandmaine.gov>

---

## 30 Merrill Conditions of Site Plan Approval

---

Tom Errico <thomas.errico@tylin.com>

Tue, Nov 29, 2016 at 9:31 AM

To: Helen Donaldson <hcd@portlandmaine.gov>, Lauren Swett <lswett@woodardcurran.com>

Hi Nell – I find the fence detail to be acceptable. I find it very difficult to understand the proposed apron/curb work. The plans note a 1.45' section of new curb. Too short. Have them provide a clear detail. While not in our standards, we are asking applicants to provide a maximum 2% accessibility route along the sidewalk. I would like to see if that can be incorporated.

Let me know if you have questions.

Thanks

Thomas A. Errico, PE  
Senior Associate  
Traffic Engineering Director

**TYLIN** INTERNATIONAL

12 Northbrook Drive

Falmouth, ME 04105

207.781.4721 (main)

207.347.4354 (direct)

207.400.0719 (mobile)

207.781.4753 (fax)

[thomas.errico@tylin.com](mailto:thomas.errico@tylin.com)

Visit us online at [www.tylin.com](http://www.tylin.com)

[Twitter](#) | [Facebook](#) | [LinkedIn](#) | [YouTube](#)

"One Vision, One Company"

Please consider the environment before printing.

**From:** Helen Donaldson [<mailto:hcd@portlandmaine.gov>]

**Sent:** Monday, November 28, 2016 12:37 PM

**To:** Lauren Swett <[lswett@woodardcurran.com](mailto:lswett@woodardcurran.com)>; Tom Errico <[thomas.errico@tylin.com](mailto:thomas.errico@tylin.com)>

**Subject:** Re: 30 Merrill Conditions of Site Plan Approval

[Quoted text hidden]

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.