
MEMORANDUM

To: FILE

From: Nell Donaldson

Subject: Application ID: 2016-172

Date: 8/12/2016

Comments Submitted by: Keith Gautreau/Fire on 8/10/2016

The proposed structure will be required to have a sprinkler system in accordance with NFPA 101 2099 ed.

Comments Submitted by: Keith Gautreau/Fire on 8/10/2016

Water supply is adequate with the provided public hydrants on Munjoy Hill.

Comments Submitted by: Keith Gautreau/Fire on 8/10/2016

Emergency access to the proposed site is fine. There appears to be adequate space between the adjacent structures for access.