



Envelope Compliance Certificate

Section 1: Project Information

Energy Code: **2009 IECC**
Project Title: 5-7 Cumberland
Project Type: New Construction

Construction Site:
5-7 Cumberland
Portland, ME 04101
Permit No. 201700254

Owner/Agent:
Mike Boissonneau
Banner Properties LLC
126 Underwood Road
Falmouth, ME 04105
207-332-3038
mboisso1@maine.rr.com

Designer/Contractor:
Evan Carroll
Bild Architecture
PO Box 8235
Portland, ME 04104
207-408-0168
evan@bildarchitecture.com

Building Location (for weather data): Portland, Maine
Climate Zone: 6a
Vertical Glazing / Wall Area Pct.: 13%

Building Use: Activity Type(s) **Floor Area**
1-apartments (Multifamily) : Residential 6285

Section 2: Envelope Assemblies and Requirements Checklist

Envelope PASSES: Design 7% better than code.

Envelope Assemblies:

Component Name/Description	Gross Area or Perimeter	Cavity R-Value	Cont. R-Value	Proposed U-Factor	Budget U-Factor ^(a)
Roof 1: Insulation Entirely Above Deck, [Bldg. Use 1 - apartments]	1719	---	30.0	0.032	0.048
Exterior Wall 1: Wood-Framed, 16" o.c., [Bldg. Use 1 - apartments]	7024	24.3	9.3	0.035	0.051
Window 1: Vinyl/Fiberglass Frame, Perf. Specs.: Product ID vinyl window, SHGC 0.41, [Bldg. Use 1 - apartments] (b)	915	---	---	0.300	0.350
Door 1: Glass (> 50% glazing):Metal Frame, Entrance Door, Perf. Type: Energy code default, Single Pane, Tinted , SHGC 0.70, [Bldg. Use 1 - apartments]	42	---	---	1.200	0.800
Basement Wall 1: Solid Concrete:8" Thickness, Normal Density, Furring: Wood, Wall Ht 8.0, Depth B.G. 6.5, [Bldg. Use 1 - apartments]	1676	0.0	13.0	0.065	0.108

(a) Budget U-factors are used for software baseline calculations ONLY, and are not code requirements.
(b) Fenestration product performance must be certified in accordance with NFRC and requires supporting documentation.

Air Leakage, Component Certification, and Vapor Retarder Requirements:

- 1. All joints and penetrations are caulked, gasketed or covered with a moisture vapor-permeable wrapping material installed in accordance with the manufacturer's installation instructions.
- 2. Windows, doors, and skylights certified as meeting leakage requirements.
- 3. Component R-values & U-factors labeled as certified.
- 4. No roof insulation is installed on a suspended ceiling with removable ceiling panels.
- 5. 'Other' components have supporting documentation for proposed U-Factors.
- 6. Insulation installed according to manufacturer's instructions, in substantial contact with the surface being insulated, and in a manner that achieves the rated R-value without compressing the insulation.
- 7. Stair, elevator shaft vents, and other outdoor air intake and exhaust openings in the building envelope are equipped with motorized dampers.
- 8. Cargo doors and loading dock doors are weather sealed. *N/A*

- 9. Recessed lighting fixtures installed in the building envelope are Type IC rated as meeting ASTM E283, are sealed with gasket or caulk.
- 10. Building entrance doors have a vestibule equipped with self-closing devices.

N/A

Exceptions:

- Building entrances with revolving doors.
- Doors not intended to be used as a building entrance.
- Doors that open directly from a space less than 3000 sq. ft. in area.
- Doors used primarily to facilitate vehicular movement or materials handling and adjacent personnel doors.
- Doors opening directly from a sleeping/dwelling unit.

Section 3: Compliance Statement

Compliance Statement: The proposed envelope design represented in this document is consistent with the building plans, specifications and other calculations submitted with this permit application. The proposed envelope system has been designed to meet the 2009 IECC requirements in COMcheck Version 4.0.6.2 and to comply with the mandatory requirements in the Requirements Checklist.

Evan Carroll, Principal

Evan Carroll

8/7/17

Name - Title

Signature

Date



Interior Lighting Compliance Certificate

Section 1: Project Information

Energy Code: **2009 IECC**
Project Title: 5-7 Cumberland
Project Type: New Construction

Construction Site:
5-7 Cumberland
Portland, ME 04101
Permit No. 201700254

Owner/Agent:
Mike Boissonneau
Banner Properties LLC
126 Underwood Road
Falmouth, ME 04105
207-332-3038
mboisso1@maine.rr.com

Designer/Contractor:
Evan Carroll
Bild Architecture
PO Box 8235
Portland, ME 04104
207-408-0168
evan@bildarchitecture.com

Section 2: Interior Lighting and Power Calculation

A Area Category	B Floor Area (ft2)	C Allowed Watts / ft2	D Allowed Watts (B x C)
apartments (Multifamily)	6285	0.7	4400
Total Allowed Watts =			4400

Section 3: Interior Lighting Fixture Schedule

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
apartments (Multifamily 6285 sq.ft.)				
LED 1: Halo Puck: LED Other Fixture Unit 13W:	1	43	13	559
Track lighting 1: Wac track: Wattage based on 90 feet of track	0	0	2700	2700
LED 2: bathroom sconce: LED A Lamp 25W:	2	26	18	468
LED 3: undercabinete track: LED Undercabinet Unit 4W:	1	35	3.3	115.5
LED 4: LED Linear 33W:	1	13	30	390
Total Proposed Watts =			4233	

Section 4: Requirements Checklist

Interior Lighting PASSES: Design 4% better than code.

Lighting Wattage:

1. Total proposed watts must be less than or equal to total allowed watts.

Allowed Watts	Proposed Watts	Complies
4400	4233	YES

Controls, Switching, and Wiring:

2. Daylight zones under skylights more than 15 feet from the perimeter have lighting controls separate from daylight zones adjacent to vertical fenestration. *N/A*
3. Daylight zones have individual lighting controls independent from that of the general area lighting.

Exceptions:

- Contiguous daylight zones spanning no more than two orientations are allowed to be controlled by a single controlling device.
- Daylight spaces enclosed by walls or ceiling height partitions and containing two or fewer light fixtures are not required to have a separate switch for general area lighting.

4. Independent controls for each space (switch/occupancy sensor).

Exceptions:

- Areas designated as security or emergency areas that must be continuously illuminated.
- Lighting in stairways or corridors that are elements of the means of egress.
5. Master switch at entry to hotel/motel guest room. N/A
6. Individual dwelling units separately metered.
7. Medical task lighting or art/history display lighting claimed to be exempt from compliance has a control device independent of the control of the nonexempt lighting. N/A
8. Each space required to have a manual control also allows for reducing the connected lighting load by at least 50 percent by either controlling all luminaires, dual switching of alternate rows of luminaires, alternate luminaires, or alternate lamps, switching the middle lamp luminaires independently of other lamps, or switching each luminaire or each lamp.

Exceptions:

- Only one luminaire in space.
- An occupant-sensing device controls the area.
- The area is a corridor, storeroom, restroom, public lobby or sleeping unit.
- Areas that use less than 0.6 Watts/sq.ft.
9. Automatic lighting shutoff control in buildings larger than 5,000 sq.ft.

Exceptions:

- Sleeping units, patient care areas; and spaces where automatic shutoff would endanger safety or security.
10. Photocell/astronomical time switch on exterior lights.

Exceptions:

- Lighting intended for 24 hour use.
11. Tandem wired one-lamp and three-lamp ballasted luminaires (No single-lamp ballasts).

Exceptions:

- Electronic high-frequency ballasts; Luminaires on emergency circuits or with no available pair.

Section 5: Compliance Statement

Compliance Statement: The proposed lighting design represented in this document is consistent with the building plans, specifications and other calculations submitted with this permit application. The proposed lighting system has been designed to meet the 2009 IECC requirements in COMcheck Version 4.0.6.2 and to comply with the mandatory requirements in the Requirements Checklist.

Evan Carroll, Principal
Name - Title

Evan Carroll
Signature

8/7/17
Date



Exterior Lighting Compliance Certificate

Section 1: Project Information

Energy Code: **2009 IECC**
 Project Title: 5-7 Cumberland
 Project Type: New Construction
 Exterior Lighting Zone: 2 (Residentially zoned area)

Construction Site:
 5-7 Cumberland
 Portland, ME 04101
 Permit No. 201700254

Owner/Agent:
 Mike Boissonneau
 Banner Properties LLC
 126 Underwood Road
 Falmouth, ME 04105
 207-332-3038
 mboisso1@maine.rr.com

Designer/Contractor:
 Evan Carroll
 Bild Architecture
 PO Box 8235
 Portland, ME 04104
 207-408-0168
 evan@bildarchitecture.com

Section 2: Exterior Lighting Area/Surface Power Calculation

A Exterior Area/Surface	B Quantity	C Allowed Watts / Unit	D Tradable Wattage	E Allowed Watts (B x C)	F Proposed Watts
Front Door Canopy (Entry canopy)	1 ft2	0.25	Yes	0	20
Rear Door Canopy (Entry canopy)	1 ft2	0.25	Yes	0	9
Rear Parking (Parking area)	1 ft2	0.06	Yes	0	22
Total Tradable Watts* =				1	51
Total Allowed Watts =				1	
Total Allowed Supplemental Watts** =				600	

* Wattage tradeoffs are only allowed between tradable areas/surfaces.

** A supplemental allowance equal to 600 watts may be applied toward compliance of both non-tradable and tradable areas/surfaces.

Section 3: Exterior Lighting Fixture Schedule

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
Front Door Canopy (Entry canopy 1 ft2): Tradable Wattage				
LED 1: Other:	1	2	10	20
Rear Door Canopy (Entry canopy 1 ft2): Tradable Wattage				
LED 2: Other:	1	1	9	9
Rear Parking (Parking area 1 ft2): Tradable Wattage				
LED 3: Other:	1	2	11	22
Total Tradable Proposed Watts =				51

Section 4: Requirements Checklist

Lighting Wattage:

1. Within each non-tradable area/surface, total proposed watts must be less than or equal to total allowed watts. Across all tradable areas/surfaces, total proposed watts must be less than or equal to total allowed watts.

Compliance: Passes using supplemental allowance watts.

Controls, Switching, and Wiring:

- 2. All exemption claims are associated with fixtures that have a control device independent of the control of the nonexempt lighting.
- 3. Lighting not designated for dusk-to-dawn operation is controlled by either a a photosensor (with time switch), or an astronomical time switch.
- 4. Lighting designated for dusk-to-dawn operation is controlled by an astronomical time switch or photosensor.
- 5. All time switches are capable of retaining programming and the time setting during loss of power for a period of at least 10 hours.

Exterior Lighting Efficacy:

- 6. All exterior building grounds luminaires that operate at greater than 100W have minimum efficacy of 60 lumen/watt. N/A

Exceptions:

- Lighting that has been claimed as exempt and is identified as such in Section 3 table above.
- Lighting that is specifically designated as required by a health or life safety statute, ordinance, or regulation.
- Emergency lighting that is automatically off during normal building operation.
- Lighting that is controlled by motion sensor.

Section 5: Compliance Statement

Compliance Statement: The proposed exterior lighting design represented in this document is consistent with the building plans, specifications and other calculations submitted with this permit application. The proposed lighting system has been designed to meet the 2009 IECC requirements in COMcheck Version 4.0.6.2 and to comply with the mandatory requirements in the Requirements Checklist.

Evan Carroll, Principal	Evan Carroll	8/7/17
Name - Title	Signature	Date



Mechanical Compliance Certificate

Section 1: Project Information

Energy Code: **2009 IECC**
Project Title: 5-7 Cumberland
Project Type: New Construction

Construction Site:
5-7 Cumberland
Portland, ME 04101
Permit No. 201700254

Owner/Agent:
Mike Boissonneau
Banner Properties LLC
126 Underwood Road
Falmouth, ME 04105
207-332-3038
mboisso1@maine.rr.com

Designer/Contractor:
Evan Carroll
Bild Architecture
PO Box 8235
Portland, ME 04104
207-408-0168
evan@bildarchitecture.com

Section 2: General Information

Building Location (for weather data): Portland, Maine
Climate Zone: 6a

Section 3: Mechanical Systems List

Quantity System Type & Description

- 6 HVAC System 1 (Single Zone) : Split System Heat Pump
Heating Mode: Capacity = 14 kBtu/h,
Proposed Efficiency = 12.50 HSPF, Required Efficiency = 7.70 HSPF
Cooling Mode: Capacity = 12 kBtu/h,
Proposed Efficiency = 26.10 SEER, Required Efficiency: 13.00 SEER
Fan System: None
 - 2 HVAC System 2 (Multiple-Zone) : Split System Heat Pump
Heating Mode: Capacity = 22 kBtu/h,
Proposed Efficiency = 9.50 HSPF, Required Efficiency = 7.70 HSPF
Cooling Mode: Capacity = 20 kBtu/h,
Proposed Efficiency = 15.00 SEER, Required Efficiency: 13.00 SEER
Fan System: FAN SYSTEM 1 | living -- Compliance (Motor nameplate HP method) : Passes
- Fans:
FAN 1 Supply, Single-Zone VAV, 317 CFM, 0.1 motor nameplate hp

Section 4: Requirements Checklist

Requirements Specific To: HVAC System 1 :

- 1. Equipment minimum efficiency: Heat Pump: 7.70 HSPF 13.00 SEER

Requirements Specific To: HVAC System 2 :

- 1. Equipment minimum efficiency: Heat Pump: 7.70 HSPF 13.00 SEER
- 2. Minimum one temperature control device per zone
- 3. Systems serving more than one zone must be VAV systems **N/A**
- 4. Single-duct VAV terminals reduce primary air before reheating **N/A**
- 5. Controls capable of resetting supply air temp (SAT) by 25% of SAT-room temp difference

Exception(s):

- Systems that prevent reheating, recooling or mixing of heated and cooled supply air
- Seventy five percent of the energy for reheating is from site-recovered or site solar energy sources.
- Zones with peak supply air quantities of 300 cfm (142 L/s) or less.

6. VAV fans with static pressure sensors are placed in a position such that the controller setpoint is no greater than one-third the total design fan static pressure. If placement results in the sensor being located downstream of major duct splits, multiple sensors are installed in each major branch.

Exception(s):

- Systems with DDC of individual zone boxes reporting to the central control panel and reset of static pressure setpoint based on the zone requiring the most pressure.

7. Systems with DDC of individual zone boxes reporting to the central control panel has static pressure setpoint reset based on the zone requiring the most pressure.

Generic Requirements: Must be met by all systems to which the requirement is applicable:

1. Plant equipment and system capacity no greater than needed to meet loads

Exception(s):

- Standby equipment automatically off when primary system is operating
 Multiple units controlled to sequence operation as a function of load

2. Minimum one temperature control device per system

3. Minimum one humidity control device per installed humidification/dehumidification system

4. Load calculations per ASHRAE/ACCA Standard 183.

5. Automatic Controls: Setback to 55°F (heat) and 85°F (cool); 7-day clock, 2-hour occupant override, 10-hour backup

Exception(s):

- Continuously operating zones

6. Outside-air source for ventilation; system capable of reducing OSA to required minimum

7. R-5 supply and return air duct insulation in unconditioned spaces

R-8 supply and return air duct insulation outside the building

R-8 insulation between ducts and the building exterior when ducts are part of a building assembly

Exception(s):

- Ducts located within equipment

- Ducts with interior and exterior temperature difference not exceeding 15°F.

8. Mechanical fasteners and sealants used to connect ducts and air distribution equipment

9. Ducts sealed - longitudinal seams on rigid ducts; transverse seams on all ducts; UL 181A or 181B tapes and mastics

10. Hot water pipe insulation: 1.5 in. for pipes <=1.5 in. and 2 in. for pipes >1.5 in.

Chilled water/refrigerant/brine pipe insulation: 1.5 in. for pipes <=1.5 in. and 1.5 in. for pipes >1.5 in.

Steam pipe insulation: 1.5 in. for pipes <=1.5 in. and 3 in. for pipes >1.5 in.

Exception(s):

- Piping within HVAC equipment.

- Fluid temperatures between 55 and 105°F.

- Fluid not heated or cooled with renewable energy.

- Piping within room fan-coil (with AHRI440 rating) and unit ventilators (with AHRI840 rating).

- Runouts <4 ft in length.

11. Operation and maintenance manual provided to building owner

12. Balancing devices provided in accordance with IMC 603.17

13. Demand control ventilation (DCV) present for high design occupancy areas (>40 person/1000 ft² in spaces >500 ft²) and served by systems with any one of 1) an air-side economizer, 2) automatic modulating control of the outdoor air damper, or 3) a design outdoor airflow greater than 3000 cfm.

Exception(s):

- Systems with heat recovery.

- Multiple-zone systems without DDC of individual zones communicating with a central control panel.

- Systems with a design outdoor airflow less than 1200 cfm.

- Spaces where the supply airflow rate minus any makeup or outgoing transfer air requirement is less than 1200 cfm.

14. Motorized, automatic shutoff dampers required on exhaust and outdoor air supply openings

Exception(s):

- Gravity dampers acceptable in buildings <3 stories

15. Automatic controls for freeze protection systems present

16. Exhaust air heat recovery included for systems 5,000 cfm or greater with more than 70% outside air fraction or specifically exempted

Exception(s):

- Hazardous exhaust systems, commercial kitchen and clothes dryer exhaust systems that the International Mechanical Code prohibits the use of energy recovery systems.

- Systems serving spaces that are heated and not cooled to less than 60°F.

- Where more than 60 percent of the outdoor heating energy is provided from site-recovered or site solar energy.

- Heating systems in climates with less than 3600 HDD.

