

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

FIVE SEVEN LLC

Located at

5 CUMBERLAND AVE

PERMIT ID: 2018-00093

ISSUE DATE: 02/01/2018

CBL: 014 C017001

has permission to **Amendment to BP 2017-00254: Remove 4th floor living space. Reduce size of roof deck w/ access from Unit 6 only. Reconfigure 2nd & 3rd floor layouts and windows. Add 2nd floor rear deck.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Brian Stephens

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Use Group: R-2, S-1 **Type:** 5A

Residential Apartments (6 Condo Units), Storage

Occupant Load = 31

Sprinkled: NFPA 13R

ENTIRE

MUBEC/IBC-2009

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Certificate of Occupancy/Final Inspection

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2018-00093	Date Applied For: 01/22/2018	CBL: 014 C017001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Three story building with six residential condominiums (two on each floor) with roof deck for Unit 6 only.		Proposed Project Description: Amendment to BP 2017-00254: Remove 4th floor living space. Reduce size of roof deck w/ access from Unit 6 only. Reconfigure 2nd & 3rd floor layouts and windows. Add 2nd floor rear deck.		
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Matthew Grooms	Approval Date: 02/01/2018	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) All conditions from previous permits for this project are still in effect with the issuance of this permit.				
2) This permit is being approved on the basis of plans and documents submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Brian Stephens	Approval Date: 02/01/2018	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Access to the roof deck shall remain from the stairs within Unit 6 only.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) Construction shall be in compliance with the requirements of the IBC 2009, MUBEC and 2010 ADA Standards for Accessible Design.				
4) .All conditions from previous permits for this project are still in effect with the issuance of this amendment.				
5) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Jason Grant	Approval Date: 02/01/2018	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) All construction shall comply with City Code, Chapter 10. All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 30 and other applicable chapters All construction shall comply with 2009 NFPA 1, Fire Code. This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4). All means of egress to remain accessible at all times. If applicable, all outstanding code violations shall be corrected prior to final inspection.				
2) All conditions from permit 2017-00254 apply to this admendment as well.				