

Hydraulic Design Information Sheet

Name - Marquis Lofts Date - 6-10-14
 Location - Garage
 Building - System No. - 2 of 2
 Contractor - Residential Fire Protection Contract No. - C14015
 Calculated By - JAL Drawing No. - 1 of 2
 Construction: (X) Combustible () Non-Combustible Ceiling Height - 8'-2"
 Occupancy - Auto Parking

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

| M | Area of Sprinkler Operation | - 900 | System Type | Sprinkler/Nozzle |
|---|-----------------------------|-------|---------------|------------------|
| | Density | - .15 | () Wet | Make Viking |
| D | Area Per Sprinkler | - 130 | (X) Dry | Model VK 300 |
| E | Elevation at Highest Outlet | - 8 | () Deluge | Size 1/2" |
| S | Hose Allowance - Inside | - | () Preaction | K-Factor 5.6 |
| I | Rack Sprinkler Allowance | - | () Other | Temp.Rat.155 |
| G | Hose Allowance - Outside | - 100 | | |

N Note Safety Margin: 7.617

Calculation Flow Required - 267.857 Press Required - 41.019
 Summary C-Factor Used: 100 Overhead 140 Underground

| W | Water Flow Test: | Pump Data: | Tank or Reservoir: |
|---|-----------------------|-------------|--------------------|
| A | Date of Test - 6-5-14 | | Cap. - |
| T | Time of Test - | Rated Cap.- | Elev.- |
| E | Static Press - 49 | @ Press - | |
| R | Residual Press - 45 | Elev. - | Well |
| | Flow - 978 | | Proof Flow |
| S | Elevation - 0 | | |

U Location -

P Source of Information -

| C | Commodity | Class | Location |
|---|-----------------|--------------------|------------------------------|
| O | Storage Ht. | Area | Aisle W. |
| M | Storage Method: | % | Palletized % Rack |
| | () Single Row | () Conven. Pallet | () Auto. Storage () Encap. |
| S | () Double Row | () Slave Pallet | () Solid Shelf () Non |
| T | () Mult. Row | | () Open Shelf |

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G Horizontal Barriers Provided:

Water Supply Curve (C)

Residential Fire Protection
Marquis Lofts Dry


Page 2
Date 6-9-14

City Water Supply:

C1 - Static Pressure : 49
C2 - Residual Pressure: 45
C2 - Residual Flow : 978

Demand:

D1 - Elevation : 3.465
D2 - System Flow : 167.857
D2 - System Pressure : 41.019
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 267.857
Safety Margin : 7.617



Fittings Used Summary

Residential Fire Protection
Marquis Lofts Dry

Page 3
Date 6-9-14

Fitting Legend

| Abbrev. | Name | 1/2 | 3/4 | 1 | 1 1/4 | 1 1/2 | 2 | 2 1/2 | 3 | 3 1/2 | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|-----|---|-------|-------|----|-------|----|-------|----|----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 0 | 0 | 0 | 0 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| D | Generic Dry Pipe Valve | 0 | 0 | 0 | 0 | 0 | 0 | 9.5 | 17 | 0 | 28 | 0 | 47 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 0 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| T | 90' Flow thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zia | Wilkins 350 | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Pressure / Flow Summary - STANDARD

Residential Fire Protection
Marquis Lofts Dry

Page 4
Date 6-9-14

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| 20 | 8.0 | 5.6 | 12.64 | na | 19.91 | 0.15 | 70 | 7.0 |
| 21 | 8.0 | 5.6 | 15.35 | na | 21.94 | 0.15 | 70 | 7.0 |
| 22 | 8.0 | 5.6 | 12.13 | na | 19.5 | 0.15 | 130 | 7.0 |
| 23 | 8.0 | 5.6 | 13.87 | na | 20.85 | 0.15 | 130 | 7.0 |
| 24 | 8.0 | 5.6 | 15.62 | na | 22.13 | 0.15 | 130 | 7.0 |
| 25 | 8.0 | 5.6 | 12.53 | na | 19.82 | 0.15 | 130 | 7.0 |
| 26 | 8.0 | 5.6 | 14.33 | na | 21.2 | 0.15 | 130 | 7.0 |
| 27 | 8.0 | 5.6 | 16.14 | na | 22.5 | 0.15 | 130 | 7.0 |
| 30 | 0.0 | | 20.74 | na | | | | |
| 31 | 0.0 | | 20.8 | na | | | | |
| 32 | 0.0 | | 21.37 | na | | | | |
| 33 | 0.0 | | 29.5 | na | | | | |
| TRD | 4.0 | | 28.65 | na | | | | |
| HDR | 1.0 | | 31.07 | na | 100.0 | | | |
| BR | 0.0 | | 39.74 | na | | | | |
| TEST | 0.0 | | 41.02 | na | | | | |

The maximum velocity is 10.3 and it occurs in the pipe between nodes HDR and BR

Final Calculations - Hazen-Williams

Residential Fire Protection
Marquis Lofts Dry

Page 5
Date 6-9-14

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. | Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------------|-------------------------|------------------------|-----------------------|--------|-------------------------|--------------------------|----------------|-------|----------------------|-------|
| 20 to 21 | 19.91 | 1.049 100 | | 0.0 | 15.000 | 12.642 0.0 | | | K Factor = 5.60 | |
| 21 to 30 | 19.91 21.94 41.85 | 0.1808 1.38 100 | | 0.0 | 15.000 | 2.712 15.354 3.465 | | | Vel = 7.39 | |
| | | | 1T | 4.282 | 5.920 | 4.282 | | | K Factor = 5.60 | |
| | | 0.1880 | | 0.0 | 10.202 | 1.918 | | | Vel = 8.98 | |
| | 0.0 41.85 | | | | | 20.737 | | | K Factor = 9.19 | |
| 22 to 23 | 19.50 | 1.049 100 | | 0.0 | 10.000 | 12.125 0.0 | | | K Factor = 5.60 | |
| 23 to 24 | 19.5 | 0.1740 1.38 100 | | 0.0 | 10.000 | 1.740 13.865 0.0 | | | Vel = 7.24 | |
| | 20.85 | | | 0.0 | 10.000 | 1.757 | | | K Factor = 5.60 | |
| 24 to 31 | 22.14 | 1.61 100 | | 0.0 | 10.000 | 15.622 3.465 | | | Vel = 8.66 | |
| | | | 1T | 5.71 | 3.500 | 5.710 | | | K Factor = 5.60 | |
| | 62.49 | 0.1862 | | 0.0 | 9.210 | 1.715 | | | Vel = 9.85 | |
| | 0.0 62.49 | | | | | 20.802 | | | K Factor = 13.70 | |
| 25 to 26 | 19.82 | 1.049 100 | | 0.0 | 10.000 | 12.532 0.0 | | | K Factor = 5.60 | |
| 26 to 27 | 19.82 | 0.1794 1.38 100 | | 0.0 | 10.000 | 1.794 14.326 0.0 | | | Vel = 7.36 | |
| | 21.20 | | | 0.0 | 10.000 | 1.811 | | | K Factor = 5.60 | |
| 27 to 32 | 41.02 | 0.1811 1.61 100 | | 0.0 | 10.000 | 16.137 3.465 | | | Vel = 8.80 | |
| | | | 1T | 5.71 | 3.500 | 5.710 | | | K Factor = 5.60 | |
| | 22.50 | 0.1920 | | 0.0 | 9.210 | 1.768 | | | Vel = 10.01 | |
| | 0.0 63.52 | | | | | 21.370 | | | K Factor = 13.74 | |
| 30 to 31 | 41.85 | 2.635 100 | | 0.0 | 8.100 | 20.737 0.0 | | | | |
| 31 to 32 | 41.85 | 0.0080 2.635 100 | | 0.0 | 8.100 | 0.065 20.802 0.0 | | | Vel = 2.46 | |
| | 62.49 | | | 0.0 | 13.000 | 0.568 | | | Vel = 6.14 | |
| 32 to 33 | 63.52 | 0.0437 2.635 100 | | 0.0 | 13.000 | 21.370 0.0 | | | | |
| | | | 3E | 17.636 | 47.920 | 29.394 | | | | |
| | 167.86 | 0.1052 | 1T | 11.758 | 77.314 | 8.134 | | | Vel = 9.88 | |
| 33 to TRD | 0.0 | 2.635 100 | | 0.0 | 2.500 | 29.504 -1.732 | | | | |
| | | | 1E | 5.879 | 5.879 | 0.882 | | | Vel = 9.88 | |
| TRD to HDR | 167.86 | 0.1053 3.26 100 | | 0.0 | 8.379 | 28.654 1.299 | | | | |
| | | | 1B | 9.592 | 4.000 | 1.116 | | | Vel = 6.45 | |
| HDR to BR | 167.86 | 0.0373 3.26 100 | | 0.0 | 29.898 | 31.069 6.358 | | | | |
| | 100.00 | | 3E | 20.143 | 6.000 | 2.316 | | | Qa = 100 | |
| | | | 1Zia | 0.0 | 20.143 | | | | * Fixed loss = 5.925 | |
| | 267.86 | 0.0886 | | 0.0 | 26.143 | | | | Vel = 10.30 | |

Final Calculations - Standard

Residential Fire Protection
Marquis Lofts Dry

Page 6
Date 6-9-14

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------------|---------------|----------------------|------------------------------------|----------------------------|------------------------|----------------|------------------|-------|-------|
| BR to TEST | 0.0 267.86 | 4.1 140 0.0156 | 1G 2.907 1T 29.067 0.0 | 50.000 31.974 81.974 | 39.743 0.0 1.276 | | Vel = 6.51 | | |
| | 0.0 267.86 | | | | 41.019 | | K Factor = 41.82 | | |