



Portland Fire Department

ALBERT CLOUTIER VN VET

CERTIFIED MAIL

RE: 95 CONGRESS ST
PORTLAND, ME

014 D009001

95 CONGRESS ST Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 5/16/2018 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 9/4/2018 10:00:00AM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan
Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST			
NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-7.4.1	Insufficient number of egress for occupancy.	This violation must be corrected by the date given or, if a permit is required, a complete permit application must be submitted by that date. In reference to your question, 2nd means of egress should be evaluated in the upstairs apartment. Please call fire prevention 874-8400	6/15/2018
NFPA 101-8.3.3.3	Fire doors must be self- or auto-closing.	all fire doors must be self closing	6/15/2018
NFPA 101-8.3.3.2.3	Labels on fire doors must be maintained in a legible condition.	Labels on fire doors are painted over	6/15/2018

NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-7.4.1	Insufficient number of egress for occupancy.	This violation must be corrected by the date given or, if a permit is required, a complete permit application must be submitted by that date. In reference to your question, 2nd means of egress should be evaluated in the upstairs apartment. Please call fire prevention 874-8400	6/15/2018
NFPA 101-8.3.3.3	Fire doors must be self- or auto-closing.	all fire doors must be self closing	6/15/2018
NFPA 101-8.3.3.2.3	Labels on fire doors must be maintained in a legible condition.	Labels on fire doors are painted over	6/15/2018