

**Portland Fire Department**

RE: 89 CONGRESS ST  
PORTLAND, ME

014 D012001

89 CONGRESS ST Page 1 of 2

**NOTICE OF VIOLATION  
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 3/20/2018 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

**A reinspection of your property will take place on 8/13/2018 10:00:00AM .**

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan  
Fire Prevention Bureau  
City of Portland

**NON-COMPLIANCE VIOLATION LIST**

<b>NAME</b>	<b>CODE DESCRIPTION</b>	<b>COMMENTS</b>	<b>Deadline</b>
NFPA 1-11.1.7.6	Extension cords may not be used as a substitute for permanent wiring.	still using extension cord to power an Industrial non walk in freezer in the basement	5/15/2018

---