

Location of Construction: 81 Congress St		Owner: Munroe, Alan/Judy Bonney		Phone:		Permit No: 970412 <b>ISSUED</b>
Owner Address: 86		Lessee/Buyer's Name:		BusinessName:		
Contractor Name: Alan Munroe 787-3377		Address:		Phone:		Permit Issued: MAY - 6 1997 <b>CITY OF PORTLAND</b>
Past Use: 2-fam		Proposed Use: Same		COST OF WORK: \$		
				PERMIT FEE: \$ 25.00		Zone: R-4 CBL: 014-F-018
				FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		
Proposed Project Description: Fire Repairs NO STRUCTURAL DAMAGE OR WORK BEING DONE		Signature:		INSPECTION: Use Group 23 Type: 5B Signature: [Signature]		Zoning Approval: [Signature] Special Zone or Reviews: <input type="checkbox"/> Shoreland 5/5/97 <input type="checkbox"/> Wetland to remain <input type="checkbox"/> Flood Zone 2 D.U. <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/>		Signature: _____ Date: _____		
Permit Taken By: Mary Gresik		Date Applied For: 30 April 1997				

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

Alan Munroe  
635 Long Hill Rd.  
East Sebago, ME 04029

**PERMIT ISSUED  
WITH REQUIREMENTS**

- Zoning Appeal**
- Variance
  - Miscellaneous
  - Conditional Use
  - Interpretation
  - Approved
  - Denied

- Historic Preservation**
- Not in District or Landmark
  - Does Not Require Review
  - Requires Review

- Action:**
- Approved
  - Approved with Conditions
  - Denied

Date: 4/30/97

[Signature]


SIGNATURE OF APPLICANT Alan Munroe ADDRESS: \_\_\_\_\_ DATE: 30 April 1997 PHONE: \_\_\_\_\_

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE \_\_\_\_\_ PHONE: \_\_\_\_\_

CEO DISTRICT [Box with 1] m w

COMMENTS

permit # 9710412  
CBSL # 014-F-018



5/6/97 Inspected + checked

framing / No joists or <sup>wall</sup> studs were replaced from fire damage. Clearing out old plaster on right side apt. / added some extra joists + studs to strengthen existing framing OK Ann

5/21-97 Chedak started sheetrock WIP will call for final to release from Postij.

7/23/97 Released from Postij

Inspection Record

Type	Inspection Record	Date
Foundation:	_____	_____
Framing:	_____	_____
Plumbing:	_____	_____
Final:	_____	_____
Other:	_____	_____

OK to Rent all util's connected Ann