City of Portland Mail

Keri Ouellette <kouellette@portlandr

Inspections Division
Date: 10/31/17

77 Congress Street #2017-01645

2 messages

Keri Ouellette <kouellette@portlandmaine.gov> Tue, Oct 31, 2017 at 12:24 PM
To: Drew Johnson <drew@sylvainsevigny.com>
Cc: lisa.campoli@ellaproperties.com

Hi Drew,

I am currently reviewing your Fast Track application for 77 Congress Street. Could you confirm that the proposed demolition does not include any load bearing demo? The third floor demo plan appears to show removal of a portion of a load bearing wall. Please confirm. Thank you.

Keri

Keri Ouellette
Intake and Review Manager
Permitting and Inspections Department
389 Congress Street
Portland, ME 04101
Phone: (207) 756-8142

Drew Johnson <drew@sylvainsevigny.com> Tue, Oct 31, 2017 at 12:31 PM
To: Keri Ouellette <kouellette@portlandmaine.gov>
Cc: Lisa Campoli <lisa.campoli@ellaproperties.com>

Hi Keri,

Our work related to this portion of the demo will include on removal of non load bearing partitions. The load bearing wall removal will take place under the complete (non fast track) building permit. Would you like me to note this on the demo drawing or does this email suffice?

Thank you for your help!

Drew Johnson
Estimator/Project Manager
o: 207.536.0235 | c: 207.400.0688
www.sylvainsevigny.com

[Quoted text hidden]

[Quoted text hidden]

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that

> what is written in an e-mail could be released to the public and/or the media if requested.

Inspections Division

Date: 10/31/17