Outdoor Unit
Located on the northwest exterior w
and supported by a bracket attache
framing members.

Weight of unit is 88 lbs. Minimum of
steel lag bolts to attach bracket.

Indoor Unit
Located in the garage on the southwest wall.

Weight of unit is 22 lbs. Unit to be mounted to wall framing with 2.5" fasteners sufficient to support the unit.

Notes:
Home is built of traditional wood framing and is sufficient to support the additional load of the equipment being installed.

CITY OF PORTLAND, MAINE — RESURGAM

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 01/30/14

ReVision Energy	HVAC Equipment Layout				
142 Presumpscot Street Portland, Maine, 04097 207-221-6342	Leopold Residence 264 Eastern Promenade, Portland, ME				
	DATE 1/21/14	DRAWN BY Geoff Sparrow	PAGE 1 of 1	DWG# 1	Rev. 0