

CITY OF PORTLAND
Fire Department
 380 Congress Street
 Portland, Maine 04101

Fire Inspection Violations

Business	Location	Number	Inspection Type
	0042 QUEBEC ST	70904-0-0	FP Routine Inspection
Owner/Manager	CBL	Inspector	
DOHERTY EDWARD W JR KW VET	014 H002001	CRAIG S RAWNSLEY Shift: 002 Unit: E1	

Code	Type	Location	Inspection Date	Target Compliance	Actual Compliance
1 101-5-21	Fire Doors Required	42 A and 42 B hallways	11/14/07	12/17/07	
2 1-3-11.1	Debris inside building	rear hallway of 42	11/14/07	12/17/07	
3 4.5.3.1	Minumum of two means of egress	42 a and 42 b	11/14/07	12/17/07	