



Portland Fire Department

MARTIN DOHERTY

RE: 42 QUEBEC ST
PORTLAND, ME 04101

014 H002001

Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 4/11/2018 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan
Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-31.2.2.1	1-hour fire rated doors and assemblies required, including self-closing and self-latching mechanisms.	Fire doors needed front stairs and between the basement and 1st floor apartment	6/30/2017
NFPA101-31.3.3	Wall, floor, and ceiling finish must meet approved class rating	Wood paneling in the stairway	5/28/2018
NFPA 101-Ch. 8	The fire barrier, including walls, ceilings, floors, etc. must be maintained with the minimum required fire rating.	Hole in the wall front stairs	5/28/2018
NFPA 101-31.3.2	Boiler and fuel-fired heaters serving more than one dwelling unit must have 1-hour separator or sprinkler protection.	Need sprinkler head over the hot water heater behind the chimney from the boiler.	5/28/2018