



May 2, 2016

Andrews Christopher S

72 Foreside Rd

Cumberland Foreside, ME 04110

CBL: 014 H010001

Located at 0041 HOWARD ST

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at [www.portlandmaine.gov](http://www.portlandmaine.gov).

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

A handwritten signature in black ink, appearing to read "C. Andrews".

Portland Fire Department

Fire Prevention Bureau

# 353751

CITY OF PORTLAND  
 PORTLAND FIRE DEPARTMENT  
 380 Congress Street  
 Portland, Maine 04101

Inspection Violations

<b>Owner/Manager</b> Andrews Christopher S		<b>Inspector</b> Daniel Small	<b>Inspection Date</b> 4/29/2016
<b>Location</b> 0041 HOWARD ST	<b>CBL</b> 014 H010001	<b>Status</b> Failed	<b>Inspection Type</b> Fire Company-FP Routine Inspec

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
------	---------	-------	----------	------	-----------------

1) 55.25

**Violation:** NFPA 101- 31.3.4.5.1 SMOKE ALARMS REQUIRED; In buildings other than those equipped through out with an existing, complete automatic smoke detection system, smoke alarms shall be installed in accordance with 9.6.2.10, as modified by 31.3.4.5.2, outside every sleeping area in the immediate vicinity of the bedrooms and on all levels of the dwelling unit, including basements.

**Notes:** SMOKE DETECTOR IN BASEMENT MUST BE UNCOVERED

2) 89.05

**Violation:** NFPA 1 EXCESSIVE/DISORDERLY STORAGE; REFERENCE NFPA 1 FOR EXCESSIVE FUEL-LOAD.

**Notes:** REMOVE PAINT STORAGE IN STAIRWAY

3) 91.30

**Violation:** NFPA 70 MISSING BREAKER IN PANEL; REFER TO NFPA 70, NATIONAL ELECTRICAL CODE, FOR INFORMATION ON MISSING BREAKERS IN AN ELECTRICAL PANEL.

**Notes:** MISSING BREAKER COVER IN SECOND FLOOR FRONT PANEL

**Comments:** Inspections from Naviline Fire Inspections. 2 were listed.  
 --Basement door required to be fire rated door  
 --Improper wiring

STATE OF MAINE

DISTRICT COURT

Location: Portland

Docket No.

CITY OF PORTLAND and body politic and  
Corporate, located in the County of  
Cumberland and State of Maine,

Plaintiff,

**FIRE PREVENTION AND PROTECTION  
CODE VIOLATION**

**(M.R. CIV. P. 80H AND 80k)**

v.


Christopher Andrews  
Defendant

SUMMONS NUMBER: 353851

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 07/11/2016. Please contact Tori Ross in Fire Prevention at (207)-874-8400 or via e-mail at [meservev@portlandmaine.gov](mailto:meservev@portlandmaine.gov) to set up an in-person meeting to meet with somebody in the Fire Prevention Bureau to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 07/11/2016.

Dated:

5/12/16



---

Adam R. Lee, Esq. Bar No. 4143  
Associate Corporation Counsel  
City of Portland  
389 Congress St  
Portland, ME 04101  
207-874-8480