From: Scott Garland
To: Alan Small
Subject: FW: 23 Emerson Street, Portland
Date: Wednesday, December 30, 2015 3:48:20 PM

From: Peter Valcourt [mailto:peter.valcourt@yahoo.com]
Sent: Wednesday, November 25, 2015 10:41 AM
To: Scott Garland
Subject: Fwd: 23 Emerson Street, Portland

Please please say you can work with this info. I need to get the sprinkler under way ASAP. Thanks Scott

Peter Valcourt
Property Manager
207-469-8494

Begin forwarded message:

> **From:** AMAP Means Email <means@pwd.org>
> **Date:** November 25, 2015 at 10:13:06 AM EST
> **To:** "'peter.valcourt@yahoo.com'" <peter.valcourt@yahoo.com>
> **Subject: 23 Emerson Street, Portland**
>
> Peter,
>
> In response to your voice message from yesterday here are the results from the testing last week:
>
> Static Pressure: 68
> Residual Pressure: 65
> Approximate measured flow: 150 GPM
>
> As you know we put the pressure gage on the service next door at 23 Emerson Street. In the basement of 13 Emerson Street, we removed the meter and attached a 2-inch diameter hose. We measured the time that it took to fill a 25 gallon drum at approximately ±10 seconds.
>
> This is not an official ISO test and there is significant margin of error, but hopefully it will give you something that your sprinkler designer can use. As we understand that the new services were installed last weekend, we would be willing to work with you perform additional testing that your sprinkler company may need.
>
> Thank you,
> Glissen
>
> **Glissen Havu**
> **Design Engineer**
> Portland Water District
> Phone: 207-774-5961 Ext. 3035
> E-mail: ghavu@pwd.org
> http://www.pwd.org
>
> **Portland Water District NOTICE & DISCLAIMER Confidentiality Notice:**
> THIS MESSAGE IS INTENDED ONLY FOR THE USE OF THE INDIVIDUAL OR ENTITY TO WHICH IT IS ADDRESSED AND MAY CONTAIN INFORMATION THAT IS PRIVILEGED AND CONFIDENTIAL. Please notify the sender if you have received this message in error. Recipients should be aware that replies to this message may not be considered confidential under the Maine Freedom of Access law, 1 M.R.S.A. §402, and may therefore be subject to public disclosure upon request.

Please consider the environment before printing this email