Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 01/28/16

NFPA 13R sprinkler check list

- Is this check list applicable? Yes
- What edition of NFPA 13R is the designed to? 2010
- Building construction type: Combustible - wood framed
- Will the sprinkler system provide complete or partial coverage of the building? Complete
- Will covered exterior balconies, decks and ground floor patios be sprinklered? Yes
- Size of riser assembly: 2"
- Fire department connection- number of 2 ½" inlets: 1
- Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: No
- Is the nearest fire hydrant within 100 ft. of the FDC? No
- The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? Yes

NFPA 13 sprinkler check list

- Is this check list applicable? No
- What edition of NFPA 13 is the designed to? n/a
- Building construction type: n/a
- Will the sprinkler system provide complete or partial coverage of the building? n/a
- System type (See NFPA 13:3.4): n/a
- NFPA 13 Occupancy Classification (Hazard): n/a
- Is the structure high-rise (see NFPA 101:3.3.32.7)? n/a
- Size of riser assembly: n/a
- Fire department connection- number of 2 ½" inlets: n/a
- Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: n/a
- Is the nearest fire hydrant within 100 ft. of the FDC? n/a
- The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? n/a

NFPA 14 standpipe check list

- Is this check list applicable? No
- What edition of NFPA 14 is the designed to? n/a

Building Inspections Division · 389 Congress Street · Portland, Maine 04101 · (207) 874-8703 · FACSIMILE (207) 874-8716 · TTY (207) 874-8936