

Portland, Maine



Yes. Life's good here.

Portland Fire Department  
Fire Prevention Bureau  
380 Congress St  
Portland, ME 04101

July 29, 2016

Dear Mr. Frederick,

This letter is to confirm we have accepted your Plan of Action for the property located on 49 Quebec St. According to the email we received on July 25, 2016, you stated the fire escape, CO alarms, and smoke detectors will be compliant by the end of September. The three fire doors will be installed by the end of November for a completion date of December 1, 2016. Please contact us at 207-874-8400 if there are any changes to this plan or to schedule your re-inspection.

Sincerely,

A handwritten signature in cursive script, appearing to read "V. Ross".

Victoria Ross

OFFICE USE ONLY

7/25/16

Date Submitted

12/1/16


POA Completion Date

PETRUCCELLI

Approved By (Print)

7/26/16

Date



Tori Ross <meservev@portlandmaine.gov>

---

## Repair Plan for 49 Quebec St.

---

Lou <chezlou@gmail.com>  
To: meservev@portlandmaine.gov

Mon, Jul 25, 2016 at 3:46 PM

Hi Tori,

Here is a plan of action to correct the violations at my house at 49 Quebec Street (Summons # 354522).

Violation 1 (repair fire escape), violation 2, (CO alarms in each unit), and violation 3 (smoke detector in each sleeping area) will be fixed during the months of August and September.

Violation 4 (install three 60 minute fire rated doors) will be completed during the months of October and November.

All of the violations will be corrected by December 1st, 2016.

Please let me know if this works, and if you need any other information from me to relieve the requirement to appear in court.

Thank you.

Best,  
Lou Frederick

(207) 370-7799