

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK CITY OF PORTLAND

Please Read Application And Notes, If Any, Attached

BUILDING INSPECTION

PERMIT

Permit Number: 080318

PERMIT ISSUED

APR 10 2008

CITY OF PORTLAND

This is to certify that MORNING EASTERN PRO ENADE LLC /Dean & Allyn

has permission to Install sprinkler system

AT 129 MORNING ST

014 N005001

provided that the person or persons who accept this permit shall comply with all of the provisions of the Statutes of the State and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and when permission is procured before this building or part thereof is occupied or service is closed-in. 4 HOUR NOTICES REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. Greg Cross

Health Dept. _____

Appeal Board _____

Other _____

Department Name

[Signature] 4/10/08
Director, Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716


Permit No: 08-0318	Issue Date:	CBL: 014 N005001
-----------------------	-------------	---------------------

Location of Construction: 129 MORNING ST	Owner Name: MORNING EASTERN PROMENA	Owner Address: PO BOX 4271	Phone:
Business Name:	Contractor Name: Dean & Allyn Inc.	Contractor Address: P.O. Box 709 Gray	Phone 2076575646
Lessee/Buyer's Name	Phone:	Permit Type: Fire Alarm System	Zone: R-6

Past Use: 6 unit residential apartment building	Proposed Use: 6 unit residential apartment building -Install sprinkler system	Permit Fee: \$240.00	Cost of Work: \$22,000.00	CEO District: 1
Proposed Project Description: Install sprinkler system		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied <i>See Conditions</i>	INSPECTION: Use Group: U Type: <i>NFPA</i>	
		Signature: <i>Gregory Cross</i>		Signature: <i>[Signature]</i>
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)				
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied				
Signature: _____ Date: _____				

Permit Taken By: Idobson	Date Applied For: 04/08/2008	Zoning Approval		
-----------------------------	---------------------------------	------------------------	--	--

<ol style="list-style-type: none"> This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. Building permits do not include plumbing, septic or electrical work. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.. 	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> <i>ok with conditions</i> Date: <i>4/8/08</i>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date: _____	Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: _____
---	--	---	--



CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 08-0318	Date Applied For: 04/08/2008	CBL: 014 N005001
------------------------------	--	----------------------------

Location of Construction: 129 MORNING ST	Owner Name: MORNING EASTERN PROMENA	Owner Address: PO BOX 4271	Phone:
Business Name:	Contractor Name: Dean & Allyn Inc.	Contractor Address: P.O. Box 709 Gray	Phone (207) 657-5646
Lessee/Buyer's Name	Phone:	Permit Type: Fire Alarm System	

Proposed Use: 6 unit residential apartment building -Install sprinkler system	Proposed Project Description: Install sprinkler system
---	--

Dept: Zoning **Status:** Approved with Conditions **Reviewer:** Marge Schmuckal **Approval Date:** 04/08/2008

Note: **Ok to Issue:**

- 1) This is NOT an approval for an additional dwelling unit. You SHALL NOT add any additional kitchen equipment including, but not limited to items such as stoves, microwaves, refrigerators, or kitchen sinks, etc. Without special approvals.
- 2) This property shall remain a six (6) family dwelling. Any change of use shall require a separate permit application for review and approval.
- 3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.

Dept: Building **Status:** Approved **Reviewer:** Tammy Munson **Approval Date:** 04/10/2008

Note: **Ok to Issue:**

Dept: Fire **Status:** Approved with Conditions **Reviewer:** Capt Greg Cass **Approval Date:** 04/08/2008

Note: **Ok to Issue:**

- 1) Fire dept. connection to remain accessible at all times
- 2) Application requires State Fire Marshal approval.



General Building Permit Application

If you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Address of Construction: <u>129 MORNING STREET</u>		
Total Square Footage of Proposed Structure		Square Footage of Lot
Tax Assessor's Chart, Block & Lot Chart# <u>14</u> Block# <u>10</u> Lot# <u>5</u>	Owner: <u>CRANDALL TOOTHAKER ASSOCIATES</u> <u>200 HIGH ST. PORTLAND 04101</u>	Telephone: <u>207-774-5358</u>
Lessee/Buyer's Name (If Applicable)	Applicant name, address & telephone: <u>DEAN & ALLYN, INC</u> <u>32 LEWISTON RD BLDG 1-C</u> <u>GRAY, ME 04039</u>	Cost Of Work: \$ <u>22,000.00</u> Fee: \$ <u>240.00</u> C of O Fee: \$ _____
Current legal use (i.e. single family) _____ If vacant, what was the previous use? _____ Proposed Specific use: _____ Is property part of a subdivision? _____ If yes, please name _____ Project description: <u>Fire Alarm Sprinkler System -</u>	<u>207-657-5646</u> <u>Apartment Building -</u> <u>Permit -</u>	
Contractor's name, address & telephone: <u>DEAN & ALLYN, INC</u>		
Who should we contact when the permit is ready: <u>JAMES WHITE</u>		
Mailing address: Phone: <u>207-657-5646</u> <u>32 LEWISTON RD BLDG 1-C</u> <u>GRAY, ME 04039</u>		

Please submit all of the information outlined in the Commercial Application Checklist. Failure to do so will result in the automatic denial of your permit.

In order to be sure the City fully understands the full scope of the project, the Planning and Development Department may request additional information prior to the issuance of a permit. For further information or to download copies of this form and other applications visit the Inspections Division on-line at www.portlandmaine.gov, or stop by the Inspections Division office, room 315 City Hall or call 874-8703.

I hereby certify that I am the Owner of record of the named property, or that the owner of record authorizes the proposed work and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant: <u>James White</u>	Date: <u>4/7/08</u>
--	---------------------

This is not a permit; you may not commence ANY work until the permit is issued.

DEAN & ALLYN, INC.

FIRE PROTECTION · SPECIAL HAZARD

P.O. Box 709 • 32 Lewiston Road • Bldg. 1C
 Gray, ME 04039-0709
 207/657-5646 • fax 657-5647

LETTER OF TRANSMITTAL

DATE	4/7/08	JOB NO.	C770
ATTENTION	BUILDING DEPT. PLAN REVIEW		
RE:	129 MORNING ST.		
	SPRINKLER LAYOUT		
	HYDRAULIC CALCS		
	CD W/ SPRINKLER LAYOUT		
	HYDRAULIC CALCS FOR ARCHIVE		

TO CITY OF PORTLAND "CITY HALL"
 380 CONGRESS ST. RM 315
 PORTLAND, ME 04101
 3RD FLOOR

WE ARE SENDING YOU Attached Under separate cover via _____ the following items:

- Shop drawings Prints Plans Samples Specifications
 Copy of letter Change order HYDRAULIC CALCS

1 CD - W/SPRINKLER LAYOUT & CALCS

COPIES	DATE	NO.	DESCRIPTION
1	4/7	1 OF 1	SPRINKLER LAYOUT
1	4/7	2-6	WX2, WX3, WX4, WX5, WX6 - HYDRAULIC CALCS
1	4/7	1	CD W/ SPRINKLER LAYOUT & HYDRAULIC CALCS IN PDF FORMAT AS WELL AS CAD FILES & HYDRA CALC FILES.
1	4/7	1	APPLICATIONS FOR PERMIT
1	4/7	1	CHECK FOR PERMIT FEE \$ 240.00


THESE ARE TRANSMITTED as checked below:

- For approval Approved as submitted Resubmit _____ copies for approval
 For your use Approved as noted Submit _____ copies for distribution
 As requested Returned for corrections Return _____ corrected prints
 For review and comment _____
 FOR BIDS DUE _____ PRINTS RETURNED AFTER LOAN TO US

REMARKS _____

COPY TO FILE

SIGNED: *James White*



... Fire Protection by Computer Design

*PKT
entire
PKS.
1405-*

DEAN & ALLYN, INC.
32 LEWISTON ROAD BUILDING 1C
P.O. BOX 709
GRAY, ME 04039
207-657-5646

Job Name : 129 MORNING STREET
Building : 129 Morning Street
Location : 3RD FLOOR - Portland, Maine
System : WX2
Contract : C770
Data File : CALC.WX2

Hydraulic Design Information Sheet

Name - 129 Morning Street	Date - 4/7/08
Location - 3RD FLOOR - Portland, Maine	
Building - 129 Morning Street	System No. - WX2
Contractor - Dean & Allyn, Inc	Contract No. - C770
Calculated By - James R White	Drawing No. - 1 OF 1
Construction: (X) Combustible () Non-Combustible	Ceiling Height - 8'-0"
Occupancy - RESIDENTIAL APARTMENTS	

S () NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other NFPA 13 R
 T Specific Ruling

Made By

Date

M	Area of Sprinkler Operation - 4 HEADS	System Type	Sprinkler/Nozzle
	Density - .05	(X) Wet	Make TYCO
D	Area Per Sprinkler - 256/75	() Dry	Model TY2596
E	Elevation at Highest Outlet - 36'-0"	() Deluge	Size 1/2"
S	Hose Allowance - Inside - 0	() Preaction	K-Factor 4.2
I	Rack Sprinkler Allowance - 0	() Other	Temp.Rat.155 DEGRE
G	Hose Allowance - Outside - 0		

Note SAFETY MARGIN = 7.61 LBS PSI

Calculation Flow Required - 58.78 Press Required - 64.37
 Summary C-Factor Used: 120 Overhead 150 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 9/26/06		Cap. -
T	Time of Test -	Rated Cap.-	Elev.-
E	Static Press - 72	@ Press -	
R	Residual Press - 68	Elev. -	Well
	Flow - 903		Proof Flow
S	Elevation - 6		

U Location - HYDRANT # 413

P Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
M	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R	K	Flue Spacing	Clearance:Storage to Ceiling
A		Longitudinal	Transverse

E Horizontal Barriers Provided:

Fittings Used Summary

DEAN & ALLYN, INC.
129 MORNING STREET

Page 2
Date 031608

Fitting Legend		½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90° Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	Generic Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	Generic Swing Check Valve	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.
129 MORNING STREET

Page 3
Date 031608

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
D101	36.0	4.2	17.75	na	17.69	0.05	256	14.5
D102	36.0	4.2	9.6	na	13.01	0.05	75	9.6
D103	36.0	4.2	9.93	na	13.23	0.05	75	9.6
D104	36.0	4.2	12.49	na	14.85	0.05	75	9.6
20	36.0		12.72	na				
1	36.0		9.78	na				
2	36.0		10.29	na				
3	36.0		13.13	na				
4	36.0		16.21	na				
5	36.0		17.38	na				
6	36.0		18.37	na				
7	6.5		32.15	na				
8	6.5		36.12	na				
9	6.5		42.52	na				
10	6.5		43.71	na				
11	6.5		44.31	na				
12	6.5		44.69	na				
13	6.5		44.94	na				
14	6.5		45.17	na				
15	6.5		45.62	na				
16	6.5		46.0	na				
17	6.5		47.71	na				
18	6.5		48.02	na				
TOR	6.5		51.16	na				
BOR	6.5		57.44	na				
19	6.5		57.69	na				
TEST	6.0		64.36	na				

The maximum velocity is 15.25 and it occurs in the pipe between nodes 3 and 4

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
129 MORNING STREET

Page 4
Date 031608

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
D101 to 6	17.69 17.69	1.049 120 0.1038	1T	5.0 0.0 0.0	1.000 5.000 6.000	17.746 0.0 0.623			K Factor = 4.20 Vel = 6.57	
	0.0 17.69						18.369		K Factor = 4.13	
D102 to 1	13.01 13.01	1.049 120 0.0587	1E	2.0 0.0 0.0	1.000 2.000 3.000	9.600 0.0 0.176			K Factor = 4.20 Vel = 4.83	
	0.0 13.01						9.776		K Factor = 4.16	
D103 to 2	13.23 13.23	1.049 120 0.0607	1T	5.0 0.0 0.0	1.000 5.000 6.000	9.925 0.0 0.364			K Factor = 4.20 Vel = 4.91	
	0.0 13.23						10.289		K Factor = 4.12	
D104 to 20	14.85 14.85	1.049 120 0.0750	1E	2.0 0.0 0.0	1.000 2.000 3.000	12.493 0.0 0.225			K Factor = 4.20 Vel = 5.51	
	0.0 14.85						12.718		K Factor = 4.16	
20 to 3	14.85 14.85	1.049 120 0.0751	1T	5.0 0.0 0.0	0.500 5.000 5.500	12.718 0.0 0.413			Vel = 5.51	
	0.0 14.85						13.131		K Factor = 4.10	
1 to 2	13.01 13.01	1.049 120 0.0588		0.0 0.0 0.0	8.720 0.0 8.720	9.776 0.0 0.513			Vel = 4.83	
2 to 3	13.23 26.24	1.049 120 0.2151	1T	5.0 0.0 0.0	8.210 5.000 13.210	10.289 0.0 2.842			Vel = 9.74	
3 to 4	14.85 41.09	1.049 120 0.4930	1E	2.0 0.0 0.0	4.250 2.000 6.250	13.131 0.0 3.081			Vel = 15.25	
4 to 5	0.0 41.09	1.049 120 0.4932	1E	2.0 0.0 0.0	0.370 2.000 2.370	16.212 0.0 1.169			Vel = 15.25	
5 to 6	0.0 41.09	1.38 120 0.1297		0.0 0.0 0.0	7.620 0.0 7.620	17.381 0.0 0.988			Vel = 8.81	
6 to 7	17.69 58.78	1.61 120 0.1187	1T	8.0 0.0 0.0	0.500 8.000 8.500	18.369 12.776 1.009			Vel = 9.26	
7 to 8	0.0 58.78	1.61 120 0.1187	1T	8.0 0.0 0.0	25.410 8.000 33.410	32.154 0.0 3.967			Vel = 9.26	
8 to 9	0.0 58.78	1.61 120 0.1187	4E	16.0 0.0 0.0	37.910 16.000 53.910	36.121 0.0 6.400			Vel = 9.26	

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
129 MORNING STREET

Page 5
Date 031608

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
9 to 10	0.0 58.78	1.61 120 0.1187	1E	4.0 0.0 0.0	6.000 4.000 10.000	42.521 0.0 1.187			Vel = 9.26	
10 to 11	0.0 58.78	2.067 120 0.0352	1E 1S	5.0 11.0 0.0	1.000 16.000 17.000	43.708 0.0 0.598			Vel = 5.62	
11 to 12	0.0 58.78	2.067 120 0.0352	1E	5.0 0.0 0.0	6.000 5.000 11.000	44.306 0.0 0.387			Vel = 5.62	
12 to 13	0.0 58.78	2.067 120 0.0351	1E 1G	5.0 1.0 0.0	1.000 6.000 7.000	44.693 0.0 0.246			Vel = 5.62	
13 to 14	0.0 58.78	2.067 120 0.0352	1E	5.0 0.0 0.0	1.500 5.000 6.500	44.939 0.0 0.229			Vel = 5.62	
14 to 15	0.0 58.78	2.067 120 0.0352	1T	10.0 0.0 0.0	2.830 10.000 12.830	45.168 0.0 0.451			Vel = 5.62	
15 to 16	0.0 58.78	2.067 120 0.0352	1T	10.0 0.0 0.0	0.750 10.000 10.750	45.619 0.0 0.378			Vel = 5.62	
16 to 17	0.0 58.78	2.067 120 0.0352	2E	10.0 0.0 0.0	38.660 10.000 48.660	45.997 0.0 1.711			Vel = 5.62	
17 to 18	0.0 58.78	2.067 120 0.0351	1E	5.0 0.0 0.0	3.910 5.000 8.910	47.708 0.0 0.313			Vel = 5.62	
18 to TOR	0.0 58.78	2.067 120 0.0351	1Fsp	0.0 0.0 0.0	4.042 0.0 4.042	48.021 3.000 0.142			* Fixed loss = 3 Vel = 5.62	
TOR to BOR	0.0 58.78	2.067 120 0.0352	1E 1Zaa	5.0 0.0 0.0	10.500 5.000 15.500	51.163 5.736 0.545			* Fixed loss = 5.736 Vel = 5.62	
BOR to 19	0.0 58.78	2.067 120 0.0351	1E	5.0 0.0 0.0	2.000 5.000 7.000	57.444 0.0 0.246			Vel = 5.62	
19 to TEST	0.0 58.78	1.985 150 0.0283		0.0 0.0 0.0	227.870 0.0 227.870	57.690 0.217 6.458			Vel = 6.09	
	0.0 58.78					64.365			K Factor = 7.33	


Water Supply Curve (C)


DEAN & ALLYN, INC.
129 MORNING STREET

Page 6
Date 031608

City Water Supply:
C1 - Static Pressure : 72
C2 - Residual Pressure: 68
C2 - Residual Flow : 903

Demand:
D1 - Elevation : 12.993
D2 - System Flow : 58.7834
D2 - System Pressure : 64.365
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 58.7834
Safety Margin : 7.610





. . . Fire Protection by Computer Design

DEAN & ALLYN, INC.
32 LEWISTON ROAD BUILDING 1C
P.O. BOX 709
GRAY, ME 04039
207-657-5646

Job Name : 129 MORNING STREET
Building : 129 Morning Street
Location : 3RD FLOOR - Portland, Maine
System : WX3
Contract : C770
Data File : CALC.WX3

Hydraulic Design Information Sheet

Name - 129 Morning Street Date - 4/7/08
 Location - Portland, Maine
 Building - 129 Morning Street System No. - WX3
 Contractor - Dean & Allyn, Inc Contract No. - C770
 Calculated By - James R White Drawing No. - 1 OF 1
 Construction: (X) Combustible () Non-Combustible Ceiling Height - 8'-0"
 Occupancy - RESIDENTIAL APARTMENTS

S () NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve
 S Other NFPA 13 R
 T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 4 HEADS	System Type	Sprinkler/Nozzle
	Density	- .05	(X) Wet	Make TYCO
D	Area Per Sprinkler	- 256/75	() Dry	Model TY2596
E	Elevation at Highest Outlet	- 36'-0"	() Deluge	Size 1/2"
S	Hose Allowance - Inside	- 0	() Preaction	K-Factor 4.2
I	Rack Sprinkler Allowance	- 0	() Other	Temp.Rat.155 DEGRE
G	Hose Allowance - Outside	- 0		

Note SAFETY MARGIN = 9.52 LBS PSI

Calculation Flow Required - 60.23 Press Required - 62.46
 Summary C-Factor Used: 120 Overhead 150 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 9/26/06		Cap. -
T	Time of Test -	Rated Cap. -	Elev. -
E	Static Press - 72	@ Press -	
R	Residual Press - 68	Elev. -	Well
	Flow - 903		Proof Flow
S	Elevation - 6		

U Location - HYDRANT # 413
 P
 L Source of Information - PORTLAND WATER DISTRICT
 Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method: Solid Piled	%	Palletized % Rack
M	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	R () Double Row	() Slave Pallet	() Solid Shelf () Non
T	A () Mult. Row		() Open Shelf
O	C		
R	K Flue Spacing	Clearance:Storage to Ceiling	
A	Longitudinal	Transverse	
G			
E	Horizontal Barriers Provided:		

Fittings Used Summary

DEAN & ALLYN, INC.
129 MORNING STREET

Page 2
Date 031608

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90° Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	Generic Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	Generic Swing Check Valve	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.
129 MORNING STREET

Page 3
Date 031608

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
D201	36.0	4.2	14.5	na	15.99	0.05	140	14.5
D202	36.0	4.2	12.79	na	15.02	0.05	140	9.6
D203	36.0	4.2	12.17	na	14.65	0.05	140	9.6
D204	36.0	4.2	12.02	na	14.56	0.05	140	9.6
40	37.0		12.02	na				
39	37.0		12.58	na				
38	37.0		14.33	na				
33	37.0		11.96	na				
34	37.0		12.27	na				
35	37.0		12.46	na				
36	37.0		13.39	na				
37	37.0		15.48	na				
8	6.5		33.32	na				
9	6.5		40.02	na				
10	6.5		41.26	na				
11	6.5		41.89	na				
12	6.5		42.29	na				
13	6.5		42.55	na				
14	6.5		42.79	na				
15	6.5		43.26	na				
16	6.5		43.65	na				
17	6.5		45.44	na				
18	6.5		45.77	na				
TOR	6.5		48.92	na				
BOR	6.5		55.23	na				
19	6.5		55.49	na				
TEST	6.0		62.46	na				

The maximum velocity is 10.85 and it occurs in the pipe between nodes 35 and 36

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
129 MORNING STREET

Page 4
Date 031608

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
D201 to 38	15.99 15.99 0.0 15.99	1.049 120 0.0860	1E	2.0 0.0 0.0	1.000 2.000 3.000	14.500 -0.433 0.258			K Factor = 4.20 Vel = 5.94	
						14.325			K Factor = 4.22	
D202 to 39	15.02 15.02 0.0 15.02	1.049 120 0.0767	1E	2.0 0.0 0.0	1.000 2.000 3.000	12.785 -0.433 0.230			K Factor = 4.20 Vel = 5.58	
						12.582			K Factor = 4.23	
D203 to 33	14.65 14.65 0.0 14.65	1.049 120 0.0730	1E	2.0 0.0 0.0	1.000 2.000 3.000	12.174 -0.433 0.219			K Factor = 4.20 Vel = 5.44	
						11.960			K Factor = 4.24	
D204 to 40	14.56 14.56 0.0 14.56	1.049 120 0.0723	1T	5.0 0.0 0.0	1.000 5.000 6.000	12.022 -0.433 0.434			K Factor = 4.20 Vel = 5.41	
						12.023			K Factor = 4.20	
40 to 35	14.56 14.56 0.0 14.56	1.049 120 0.0725	1T	5.0 0.0 0.0	1.000 5.000 6.000	12.023 0.0 0.435			Vel = 5.41	
						12.458			K Factor = 4.13	
39 to 36	15.02 15.02 0.0 15.02	1.049 120 0.0766	1T	5.0 0.0 0.0	5.500 5.000 10.500	12.582 0.0 0.804			Vel = 5.58	
						13.386			K Factor = 4.11	
38 to 37	15.99 15.99 0.0 15.99	1.049 120 0.0861	1E	2.0 0.0 0.0	11.410 2.000 13.410	14.325 0.0 1.154			Vel = 5.94	
						15.479			K Factor = 4.06	
33 to 34	14.65 14.65 0.0 14.65	1.049 120 0.0734		0.0 0.0 0.0	4.250 0.0 4.250	11.960 0.0 0.312			Vel = 5.44	
34 to 35	0.0 14.65 0.0 14.65	1.049 120 0.0732		0.0 0.0 0.0	2.540 0.0 2.540	12.272 0.0 0.186			Vel = 5.44	
35 to 36	14.57 29.22 0.0 29.22	1.049 120 0.2621		0.0 0.0 0.0	3.540 0.0 3.540	12.458 0.0 0.928			Vel = 10.85	
36 to 37	15.01 44.23 0.0 44.23	1.38 120 0.1487	1T	6.0 0.0 0.0	8.080 6.000 14.080	13.386 0.0 2.093			Vel = 9.49	

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
129 MORNING STREET

Page 5
Date 031608

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
37	16.00	1.61	1E	4.0	25.330	15.479				
to		120	1T	8.0	12.000	13.210				
8	60.23	0.1242		0.0	37.330	4.635		Vel =	9.49	
8	0.0	1.61	4E	16.0	37.910	33.324				
to		120		0.0	16.000	0.0				
9	60.23	0.1242		0.0	53.910	6.694		Vel =	9.49	
9	0.0	1.61	1E	4.0	6.000	40.018				
to		120		0.0	4.000	0.0				
10	60.23	0.1242		0.0	10.000	1.242		Vel =	9.49	
10	0.0	2.067	1E	5.0	1.000	41.260				
to		120	1S	11.0	16.000	0.0				
11	60.23	0.0368		0.0	17.000	0.625		Vel =	5.76	
11	0.0	2.067	1E	5.0	6.000	41.885				
to		120		0.0	5.000	0.0				
12	60.23	0.0368		0.0	11.000	0.405		Vel =	5.76	
12	0.0	2.067	1E	5.0	1.000	42.290				
to		120	1G	1.0	6.000	0.0				
13	60.23	0.0367		0.0	7.000	0.257		Vel =	5.76	
13	0.0	2.067	1E	5.0	1.500	42.547				
to		120		0.0	5.000	0.0				
14	60.23	0.0368		0.0	6.500	0.239		Vel =	5.76	
14	0.0	2.067	1T	10.0	2.830	42.786				
to		120		0.0	10.000	0.0				
15	60.23	0.0368		0.0	12.830	0.472		Vel =	5.76	
15	0.0	2.067	1T	10.0	0.750	43.258				
to		120		0.0	10.000	0.0				
16	60.23	0.0368		0.0	10.750	0.396		Vel =	5.76	
16	0.0	2.067	2E	10.0	38.660	43.654				
to		120		0.0	10.000	0.0				
17	60.23	0.0368		0.0	48.660	1.789		Vel =	5.76	
17	0.0	2.067	1E	5.0	3.910	45.443				
to		120		0.0	5.000	0.0				
18	60.23	0.0368		0.0	8.910	0.328		Vel =	5.76	
18	0.0	2.067	1Fsp	0.0	4.042	45.771				
to		120		0.0	0.0	3.000		* Fixed loss = 3		
TOR	60.23	0.0366		0.0	4.042	0.148		Vel =	5.76	
TOR	0.0	2.067	1E	5.0	10.500	48.919				
to		120	1Zaa	0.0	5.000	5.740		* Fixed loss = 5.74		
BOR	60.23	0.0368		0.0	15.500	0.571		Vel =	5.76	
BOR	0.0	2.067	1E	5.0	2.000	55.230				
to		120		0.0	5.000	0.0				
19	60.23	0.0367		0.0	7.000	0.257		Vel =	5.76	
19	0.0	1.985		0.0	227.870	55.487				
to		150		0.0	0.0	0.217				
TEST	60.23	0.0296		0.0	227.870	6.754		Vel =	6.24	
	0.0									
	60.23					62.458		K Factor =	7.62	


Water Supply Curve (C)


DEAN & ALLYN, INC.
129 MORNING STREET

Page 6
Date 031608

City Water Supply:
C1 - Static Pressure : 72
C2 - Residual Pressure: 68
C2 - Residual Flow : 903

Demand:
D1 - Elevation : 12.993
D2 - System Flow : 60.228
D2 - System Pressure : 62.458
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 60.228
Safety Margin : 9.515





... Fire Protection by Computer Design

DEAN & ALLYN, INC.
32 LEWISTON ROAD BUILDING 1C
P.O. BOX 709
GRAY, ME 04039
207-657-5646

Job Name : 129 MORNING STREET
Building : 129 Morning Street
Location : 2CND FLOOR - Portland, Maine
System : WX4
Contract : C770
Data File : CALC.WX4

Hydraulic Design Information Sheet

Name - 129 Morning Street Date - 4/7/08
Location - 2CND FLOOR - Portland, Maine
Building - 129 Morning Street System No. - WX4
Contractor - Dean & Allyn, Inc Contract No. - C770
Calculated By - James R White Drawing No. - 1 OF 1
Construction: (X) Combustible () Non-Combustible Ceiling Height - 8'-0"
Occupancy - RESIDENTIAL APARTMENTS

S () NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve

S Other NFPA 13 R
T Specific Ruling

Made By

Date

M Area of Sprinkler Operation - 4 HEADS System Type Sprinkler/Nozzle
Density - .05 (X) Wet Make TYCO
D Area Per Sprinkler - 140 () Dry Model TY2596
E Elevation at Highest Outlet - 26'-5" () Deluge Size 1/2"
S Hose Allowance - Inside - 0 () Preaction K-Factor 4.2
I Rack Sprinkler Allowance - 0 () Other Temp.Rat.155 DEGRE
G Hose Allowance - Outside - 0

N Note SAFETY MARGIN = 7.23 LBS PSI

Calculation Flow Required - 56.38 Press Required - 64.75
Summary C-Factor Used: 150 Overhead 150 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 9/26/06 Cap. -
T Time of Test - Rated Cap.- Elev.-
E Static Press - 72 @ Press -
R Residual Press - 68 Elev. - Well
Flow - 903 Proof Flow
S Elevation - 6

U Location - HYDRANT # 413

L Source of Information - PORTLAND WATER DISTRICT
Y

C Commodity Class Location
O Storage Ht. Area Aisle W.
M Storage Method: Solid Piled % Palletized % Rack
M () Single Row () Conven. Pallet () Auto. Storage () Encap.
S R () Double Row () Slave Pallet () Solid Shelf () Non
T A () Mult. Row () Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
A Longitudinal Transverse

G Horizontal Barriers Provided:
E

Fittings Used Summary

DEAN & ALLYN, INC.
129 MORNING STREET

Page 2
Date 031608

Fitting Legend		½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.
129 MORNING STREET

Page 3
Date 031608

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
D301	26.5	4.2	15.27	na	16.41	0.05	256	14.5
D302	26.5	4.2	9.6	na	13.01	0.05	75	9.6
D303	26.5	4.2	9.69	na	13.07	0.05	75	9.6
D304	26.5	4.2	10.92	na	13.88	0.05	75	9.6
62	27.0		10.87	na				
61	27.0		15.28	na				
51	27.0		9.53	na				
52	27.0		9.8	na				
53	27.0		11.35	na				
54	27.0		15.47	na				
55	27.0		17.8	na				
56	27.0		28.86	na				
57	6.5		40.43	na				
58	6.5		41.48	na				
59	6.5		42.36	na				
60	6.5		46.41	na				
16	6.5		47.09	na				
17	6.5		48.67	na				
18	6.5		48.96	na				
TOR	6.5		52.1	na				
BOR	6.5		58.32	na				
19	6.5		58.55	na				
TEST	6.0		64.75	na				

The maximum velocity is 19 and it occurs in the pipe between nodes 54 and 55

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
129 MORNING STREET

Page 4
Date 031608

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
D301 to 61	16.41	1.101 150 0.0473	1E	3.825 0.0 0.0	1.000 3.825 4.825	15.274 -0.217 0.228			K Factor = 4.20 Vel = 5.53	
	0.0 16.41					15.285			K Factor = 4.20	
D302 to 51	13.01	1.101 150 0.0309	1E	3.825 0.0 0.0	1.000 3.825 4.825	9.600 -0.217 0.149			K Factor = 4.20 Vel = 4.38	
	0.0 13.01					9.532			K Factor = 4.21	
D303 to 52	13.07	1.101 150 0.0311	1T	9.563 0.0 0.0	1.000 9.562 10.562	9.688 -0.217 0.328			K Factor = 4.20 Vel = 4.40	
	0.0 13.07					9.799			K Factor = 4.18	
D304 to 62	13.88	1.101 150 0.0346	1E	3.825 0.0 0.0	1.000 3.825 4.825	10.918 -0.217 0.167			K Factor = 4.20 Vel = 4.68	
	0.0 13.88					10.868			K Factor = 4.21	
62 to 53	13.88	1.101 150 0.0346	1T	9.563 0.0 0.0	4.330 9.562 13.892	10.868 0.0 0.481			Vel = 4.68	
	0.0 13.88					11.349			K Factor = 4.12	
61 to 54	16.41	1.101 150 0.0473		0.0 0.0 0.0	3.830 0.0 3.830	15.285 0.0 0.181			Vel = 5.53	
	0.0 16.41					15.466			K Factor = 4.17	
51 to 52	13.01	1.101 150 0.0307		0.0 0.0 0.0	8.700 0.0 8.700	9.532 0.0 0.267			Vel = 4.38	
52 to 53	13.08	1.101 150 0.1113	1T	9.563 0.0 0.0	4.370 9.562 13.932	9.799 0.0 1.550			Vel = 8.79	
53 to 54	13.87	1.101 150 0.2449	1T	9.563 0.0 0.0	7.250 9.562 16.812	11.349 0.0 4.117			Vel = 13.47	
54 to 55	16.42	1.101 150 0.4627		0.0 0.0 0.0	5.040 0.0 5.040	15.466 0.0 2.332			Vel = 19.00	
55 to 56	0.0	1.101 150 0.4628	1E	3.825 0.0 0.0	20.080 3.825 23.905	17.798 0.0 11.064			Vel = 19.00	
56 to 57	0.0	1.38 120 0.2328	1E 1T	3.0 6.0 0.0	2.540 9.000 11.540	28.862 8.879 2.686			Vel = 12.09	

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
129 MORNING STREET

Page 5
Date 031608

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
57 to 58	0.0 56.38	1.38 120 0.2328	1E	3.0 0.0 0.0	1.540 3.000 4.540	40.427 0.0 1.057			Vel = 12.09	
58 to 59	0.0 56.38	1.38 120 0.2328	1E	3.0 0.0 0.0	0.750 3.000 3.750	41.484 0.0 0.873			Vel = 12.09	
59 to 60	0.0 56.38	1.38 120 0.2328	1E 1T	3.0 6.0 0.0	8.410 9.000 17.410	42.357 0.0 4.053			Vel = 12.09	
60 to 16	0.0 56.38	1.682 120 0.0888		0.0 0.0 0.0	7.660 0.0 7.660	46.410 0.0 0.680			Vel = 8.14	
16 to 17	0.0 56.38	2.067 120 0.0326	2E	10.0 0.0 0.0	38.660 10.000 48.660	47.090 0.0 1.584			Vel = 5.39	
17 to 18	0.0 56.38	2.067 120 0.0325	1E	5.0 0.0 0.0	3.910 5.000 8.910	48.674 0.0 0.290			Vel = 5.39	
18 to TOR	0.0 56.38	2.067 120 0.0327	1Fsp	0.0 0.0 0.0	4.042 0.0 4.042	48.964 3.000 0.132			* Fixed loss = 3 Vel = 5.39	
TOR to BOR	0.0 56.38	2.067 120 0.0325	1E 1Zaa	5.0 0.0 0.0	10.500 5.000 15.500	52.096 5.724 0.504			* Fixed loss = 5.724 Vel = 5.39	
BOR to 19	0.0 56.38	2.067 120 0.0326	1E	5.0 0.0 0.0	2.000 5.000 7.000	58.324 0.0 0.228			Vel = 5.39	
19 to TEST	0.0 56.38	1.985 150 0.0262		0.0 0.0 0.0	227.870 0.0 227.870	58.552 0.217 5.977			Vel = 5.85	
	0.0 56.38					64.746			K Factor = 7.01	


Water Supply Curve (C)


DEAN & ALLYN, INC.
129 MORNING STREET

Page 6
Date 031608

City Water Supply:
C1 - Static Pressure : 72
C2 - Residual Pressure: 68
C2 - Residual Flow : 903

Demand:
D1 - Elevation : 8.879
D2 - System Flow : 56.3778
D2 - System Pressure : 64.746
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 56.3778
Safety Margin : 7.231





... Fire Protection by Computer Design

DEAN & ALLYN, INC.
32 LEWISTON ROAD BUILDING 1C
P.O. BOX 709
GRAY, ME 04039
207-657-5646

Job Name : 129 MORNING STREET
Building : 129 Morning Street
Location : BASEMENT - Portland, Maine
System : WX5
Contract : C770
Data File : CALC.WX5

Hydraulic Design Information Sheet

Name - 129 Morning Street Date - 4/7/08
 Location - BASEMENT - Portland, Maine
 Building - 129 Morning Street System No. - WX5
 Contractor - Dean & Allyn, Inc Contract No. - C770
 Calculated By - James R White Drawing No. - 1 OF 1
 Construction: (X) Combustible () Non-Combustible Ceiling Height - 6'-6"
 Occupancy - LAUNDRY/STORAGE

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve
 S Other NFPA 13R

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 4 HEADS	System Type	Sprinkler/Nozzle
	Density	- .15	(X) Wet	Make TYCO
D	Area Per Sprinkler	- 110	() Dry	Model TY3531/ 3331
E	Elevation at Highest Outlet	- 6'-6'	() Deluge	Size 1/2"
S	Hose Allowance - Inside	- 0	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	- 0	() Other	Temp.Rat.155 DEGRE
G	Hose Allowance - Outside	- 0		

N Note SAFETY MARGIN = 39.82 LBS PSI

Calculation Flow Required - 66.16 Press Required - 32.15
 Summary C-Factor Used: 120 Overhead 150 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 9/26/06		Cap. -
T	Time of Test -	Rated Cap.-	Elev.-
E	Static Press - 72	@ Press -	
R	Residual Press - 68	Elev. -	Well
	Flow - 903		Proof Flow
S	Elevation - 6		

U Location - HYDRANT # 413

P Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G Horizontal Barriers Provided:

Fittings Used Summary

DEAN & ALLYN, INC.
129 MORNING STREET

Page 2
Date 031608

Fitting Legend		½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	Generic Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	Generic Swing Check Valve	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.
129 MORNING STREET

Page 3
Date 031608

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
D401	6.66	5.6	8.95	na	16.75	0.15	110	7.0
D402	6.66	5.6	8.68	na	16.5	0.15	110	7.0
D403	6.66	5.6	9.3	na	17.08	0.15	110	7.0
130	6.66		8.95	na				
128	6.66		9.6	na				
129	7.583		10.69	na				
57	7.583		10.7	na				
58	7.583		10.77	na				
59	7.583		10.83	na				
60	7.583		11.07	na				
127	6.66		9.23	na				
123	6.66	5.6	7.98	na	15.82	0.15	75	7.0
124	7.583		9.79	na				
125	7.583		10.17	na				
9	6.5		10.7	na				
10	6.5		10.81	na				
11	6.5		10.95	na				
12	6.5		11.06	na				
13	6.5		11.12	na				
14	6.5		11.18	na				
15	6.5		11.29	na				
16	6.5		11.64	na				
126	6.5		11.89	na				
17	6.5		13.58	na				
18	6.5		13.97	na				
TOR	6.5		17.15	na				
BOR	6.5		23.59	na				
19	6.5		23.9	na				
TEST	6.0		32.15	na				

The maximum velocity is 6.86 and it occurs in the pipe between nodes 19 and TEST

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
129 MORNING STREET

Page 4
Date 031608

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
D401 to 127	16.75	1.049 120 0.0937	1E 2.0 0.0 0.0	1.000 2.000 3.000	8.950 0.0 0.281		K Factor = 5.60 Vel = 6.22		
	0.0 16.75				9.231		K Factor = 5.51		
D402 to 130	16.50	1.049 120 0.0913	1E 2.0 0.0 0.0	1.000 2.000 3.000	8.681 0.0 0.274		K Factor = 5.60 Vel = 6.13		
	0.0 16.50				8.955		K Factor = 5.51		
D403 to 128	17.08	1.049 120 0.0970	1E 2.0 0.0 0.0	1.000 2.000 3.000	9.305 0.0 0.291		K Factor = 5.60 Vel = 6.34		
	0.0 17.08				9.596		K Factor = 5.51		
130 to 15	16.50	1.049 120 0.0912	2E 4.0 1T 5.0 0.0	15.870 9.000 24.870	8.955 0.069 2.268		Vel = 6.13		
	0.0 16.50				11.292		K Factor = 4.91		
128 to 129	17.08	1.049 120 0.0973	1E 2.0 1T 5.0 0.0	8.370 7.000 15.370	9.596 -0.400 1.495		Vel = 6.34		
129 to 57	0.0	1.61 120 0.0115	0.0 0.0 0.0	1.040 0.0 1.040	10.691 0.0 0.012		Vel = 2.69		
57 to 58	0.0	1.61 120 0.0121	1E 4.0 0.0 0.0	1.540 4.000 5.540	10.703 0.0 0.067		Vel = 2.69		
58 to 59	0.0	1.61 120 0.0120	1E 4.0 0.0 0.0	0.750 4.000 4.750	10.770 0.0 0.057		Vel = 2.69		
59 to 60	0.0	1.61 120 0.0121	1E 4.0 1T 8.0 0.0	8.410 12.000 20.410	10.827 0.0 0.247		Vel = 2.69		
60 to 16	0.0	1.61 120 0.0120	0.0 0.0 0.0	7.660 0.0 7.660	11.074 0.469 0.092		Vel = 2.69		
	0.0 17.08				11.635		K Factor = 5.01		
127 to 126	16.75	1.049 120 0.0938	3E 6.0 1T 5.0 0.0	16.620 11.000 27.620	9.231 0.069 2.590		Vel = 6.22		
	0.0 16.75				11.890		K Factor = 4.86		
123 to 124	15.82	1.049 120 0.0844	3E 6.0 0.0 0.0	20.120 6.000 26.120	7.984 -0.400 2.204		K Factor = 5.60 Vel = 5.87		

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
129 MORNING STREET

Page 5
Date 031608

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
124 to 125	0.0 15.82	1.38 120 0.0222	1T	6.0 0.0 0.0	11.080 6.000 17.080	9.788 0.0 0.379				Vel = 3.39
125 to 9	0.0 15.82	1.61 120 0.0105	1E	4.0 0.0 0.0	2.200 4.000 6.200	10.167 0.469 0.065				Vel = 2.49
9 to 10	0.0 15.82	1.61 120 0.0105	1E	4.0 0.0 0.0	6.000 4.000 10.000	10.701 0.0 0.105				Vel = 2.49
10 to 11	0.0 15.82	1.61 120 0.0105	1E 1S	4.0 9.0 0.0	1.000 13.000 14.000	10.806 0.0 0.147				Vel = 2.49
11 to 12	0.0 15.82	1.61 120 0.0105	1E	4.0 0.0 0.0	6.000 4.000 10.000	10.953 0.0 0.105				Vel = 2.49
12 to 13	0.0 15.82	1.61 120 0.0103	1E 1G	4.0 1.0 0.0	1.000 5.000 6.000	11.058 0.0 0.062				Vel = 2.49
13 to 14	0.0 15.82	1.61 120 0.0105	1E	4.0 0.0 0.0	1.500 4.000 5.500	11.120 0.0 0.058				Vel = 2.49
14 to 15	0.0 15.82	1.61 120 0.0105	1T	8.0 0.0 0.0	2.830 8.000 10.830	11.178 0.0 0.114				Vel = 2.49
15 to 16	16.50 32.32	1.61 120 0.0392	1T	8.0 0.0 0.0	0.750 8.000 8.750	11.292 0.0 0.343				Vel = 5.09
16 to 126	17.09 49.41	2.067 120 0.0255		0.0 0.0 0.0	10.000 0.0 10.000	11.635 0.0 0.255				Vel = 4.72
126 to 17	16.75 66.16	2.067 120 0.0438	2E	10.0 0.0 0.0	28.660 10.000 38.660	11.890 0.0 1.692				Vel = 6.33
17 to 18	0.0 66.16	2.067 120 0.0437	1E	5.0 0.0 0.0	3.910 5.000 8.910	13.582 0.0 0.389				Vel = 6.33
18 to TOR	0.0 66.16	2.067 120 0.0438	1Fsp	0.0 0.0 0.0	4.042 0.0 4.042	13.971 3.000 0.177				* Fixed loss = 3 Vel = 6.33
TOR to BOR	0.0 66.16	2.067 120 0.0437	1E 1Zaa	5.0 0.0 0.0	10.500 5.000 15.500	17.148 5.764 0.678				* Fixed loss = 5.764 Vel = 6.33
BOR to 19	0.0 66.16	2.067 120 0.0439	1E	5.0 0.0 0.0	2.000 5.000 7.000	23.590 0.0 0.307				Vel = 6.33
19 to TEST	0.0 66.16	1.985 150 0.0353		0.0 0.0 0.0	227.870 0.0 227.870	23.897 0.217 8.036				Vel = 6.86

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
129 MORNING STREET

Page 6
Date 031608

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 66.16				32.150			K Factor = 11.67	


Water Supply Curve (C)


DEAN & ALLYN, INC.
129 MORNING STREET

Page 7
Date 031608

City Water Supply:
C1 - Static Pressure : 72
C2 - Residual Pressure: 68
C2 - Residual Flow : 903

Demand:
D1 - Elevation : 0.286
D2 - System Flow : 66.1587
D2 - System Pressure : 32.150
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 66.1587
Safety Margin : 39.819





... Fire Protection by Computer Design

DEAN & ALLYN, INC.
32 LEWISTON ROAD BUILDING 1C
P.O. BOX 709
GRAY, ME 04039
207-657-5646

Job Name : 129 MORNING STREET
Building : 129 Morning Street
Location : 2CND FLOOR - Portland, Maine
System : WX6
Contract : C770
Data File : CALC.WX6

Hydraulic Design Information Sheet

Name - 129 Morning Street Date - 4/7/08
 Location - 2CND FLOOR - Portland, Maine
 Building - 129 Morning Street System No. - WX6
 Contractor - Dean & Allyn, Inc Contract No. - C770
 Calculated By - James R White Drawing No. - 1 OF 1
 Construction: (X) Combustible () Non-Combustible Ceiling Height - 8'-0"
 Occupancy - RESIDENTIAL APARTMENTS

S () NFPA 13 () Lt. Haz. Ord. Haz. Gp. () 1 () 2 () 3 () Ex. Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other NFPA 13 R

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 4 HEADS	System Type	Sprinkler/Nozzle
	Density	- .05	(X) Wet	Make TYCO
D	Area Per Sprinkler	- 140	() Dry	Model TY2596
E	Elevation at Highest Outlet	- 26'-5"	() Deluge	Size 1/2"
S	Hose Allowance - Inside	- 0	() Preaction	K-Factor 4.2
I	Rack Sprinkler Allowance	- 0	() Other	Temp. Rat. 155 DEGRE
G	Hose Allowance - Outside	- 0		

N Note SAFETY MARGIN = 19.22 LBS PSI

Calculation Flow Required - 65.09 Press Required - 52.75
 Summary C-Factor Used: 150 Overhead 150 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 9/26/06		Cap. -
T	Time of Test -	Rated Cap. -	Elev. -
E	Static Press - 72	@ Press -	
R	Residual Press - 68	Elev. -	Well
	Flow - 903		Proof Flow
S	Elevation - 6		

U Location - HYDRANT # 413

L Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance: Storage to Ceiling
 A Longitudinal Transverse

G Horizontal Barriers Provided:

Fittings Used Summary

DEAN & ALLYN, INC.
129 MORNING STREET

Page 2
Date 031608

Fitting Legend		½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
E	90° Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
T	90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.
129 MORNING STREET

Page 3
Date 031608

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
D501	26.5	4.2	14.56	na	16.02	0.05	140	14.5
D502	26.5	4.2	14.5	na	15.99	0.05	140	14.5
D503	26.5	4.2	15.39	na	16.48	0.05	140	14.5
D504	26.5	4.2	15.62	na	16.6	0.05	140	14.5
76	27.0		14.56	na				
75	27.0		15.4	na				
72	27.0		14.5	na				
73	27.0		15.31	na				
74	27.0		19.86	na				
61	27.0		15.64	na				
54	27.0		15.82	na				
55	27.0		16.06	na				
56	20.0		23.22	na				
129	20.0		24.13	na				
57	20.0		24.22	na				
58	20.0		24.62	na				
59	20.0		24.94	na				
60	20.0		26.45	na				
16	20.0		26.71	na				
71	20.0		26.77	na				
126	20.0		26.98	na				
17	6.5		34.47	na				
18	6.5		34.85	na				
TOR	6.5		38.02	na				
BOR	6.5		44.44	na				
19	6.5		44.73	na				
TEST	6.0		52.75	na				

The maximum velocity is 11.89 and it occurs in the pipe between nodes 74 and 71

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
129 MORNING STREET

Page 4
Date 031608

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
D501 to 76	16.02 16.02	1.101 150 0.0454	1E	3.825 0.0 0.0	1.000 3.825 4.825	14.555 -0.217 0.219			K Factor = 4.20 Vel = 5.40	
	0.0 16.02						14.557		K Factor = 4.20	
D502 to 72	15.99 15.99	1.101 150 0.0450	1E	3.825 0.0 0.0	1.000 3.825 4.825	14.500 -0.217 0.217			K Factor = 4.20 Vel = 5.39	
	0.0 15.99						14.500		K Factor = 4.20	
D503 to 75	16.48 16.48	1.101 150 0.0477	1E	3.825 0.0 0.0	1.000 3.825 4.825	15.389 -0.217 0.230			K Factor = 4.20 Vel = 5.55	
	0.0 16.48						15.402		K Factor = 4.20	
D504 to 61	16.60 16.6	1.101 150 0.0483	1E	3.825 0.0 0.0	1.000 3.825 4.825	15.619 -0.217 0.233			K Factor = 4.20 Vel = 5.59	
	0.0 16.60						15.635		K Factor = 4.20	
76 to 73	16.02 16.02	1.101 150 0.0452	1E 1T	3.825 9.563 0.0	3.200 13.387 16.587	14.557 0.0 0.749			Vel = 5.40	
	0.0 16.02						15.306		K Factor = 4.09	
75 to 55	16.48 16.48	1.101 150 0.0476	2E	7.65 0.0 0.0	6.250 7.650 13.900	15.402 0.0 0.661			Vel = 5.55	
	0.0 16.48						16.063		K Factor = 4.11	
72 to 73	15.99 15.99	1.101 150 0.0450	1T	9.563 0.0 0.0	8.330 9.562 17.892	14.500 0.0 0.806			Vel = 5.39	
73 to 74	16.03 32.02	1.101 150 0.1625	2E	7.65 0.0 0.0	20.410 7.650 28.060	15.306 0.0 4.559			Vel = 10.79	
74 to 71	0.0 32.02	1.049 120 0.3108	1E 1T	2.0 5.0 0.0	5.450 7.000 12.450	19.865 3.032 3.869			Vel = 11.89	
	0.0 32.02						26.766		K Factor = 6.19	
61 to 54	16.60 16.6	1.101 150 0.0483		0.0 0.0 0.0	3.830 0.0 3.830	15.635 0.0 0.185			Vel = 5.59	
54 to 55	0.0 16.6	1.101 150 0.0482		0.0 0.0 0.0	5.040 0.0 5.040	15.820 0.0 0.243			Vel = 5.59	

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
129 MORNING STREET

Page 5
Date 031608

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
55	16.48	1.101	1E	3.825	20.080	16.063				
to		150		0.0	3.825	3.032				
56	33.08	0.1725		0.0	23.905	4.124		Vel = 11.15		
56	0.0	1.38	1E	3.0	1.500	23.219				
to		120	1T	6.0	9.000	0.0				
129	33.08	0.0869		0.0	10.500	0.912		Vel = 7.10		
129	0.0	1.38		0.0	1.040	24.131				
to		120		0.0	0.0	0.0				
57	33.08	0.0865		0.0	1.040	0.090		Vel = 7.10		
57	0.0	1.38	1E	3.0	1.540	24.221				
to		120		0.0	3.000	0.0				
58	33.08	0.0868		0.0	4.540	0.394		Vel = 7.10		
58	0.0	1.38	1E	3.0	0.750	24.615				
to		120		0.0	3.000	0.0				
59	33.08	0.0869		0.0	3.750	0.326		Vel = 7.10		
59	0.0	1.38	1E	3.0	8.410	24.941				
to		120	1T	6.0	9.000	0.0				
60	33.08	0.0868		0.0	17.410	1.511		Vel = 7.10		
60	0.0	1.682		0.0	7.660	26.452				
to		120		0.0	0.0	0.0				
16	33.08	0.0330		0.0	7.660	0.253		Vel = 4.78		
16	0.0	2.067		0.0	4.950	26.705				
to		120		0.0	0.0	0.0				
71	33.08	0.0123		0.0	4.950	0.061		Vel = 3.16		
71	32.01	2.067		0.0	5.040	26.766				
to		120		0.0	0.0	0.0				
126	65.09	0.0425		0.0	5.040	0.214		Vel = 6.22		
126	0.0	2.067	2E	10.0	28.660	26.980				
to		120		0.0	10.000	5.847				
17	65.09	0.0424		0.0	38.660	1.641		Vel = 6.22		
17	0.0	2.067	1E	5.0	3.910	34.468				
to		120		0.0	5.000	0.0				
18	65.09	0.0424		0.0	8.910	0.378		Vel = 6.22		
18	0.0	2.067	1Fsp	0.0	4.042	34.846				
to		120		0.0	0.0	3.000		* Fixed loss = 3		
TOR	65.09	0.0426		0.0	4.042	0.172		Vel = 6.22		
TOR	0.0	2.067	1E	5.0	10.500	38.018				
to		120	1Zaa	0.0	5.000	5.760		* Fixed loss = 5.76		
BOR	65.09	0.0425		0.0	15.500	0.658		Vel = 6.22		
BOR	0.0	2.067	1E	5.0	2.000	44.436				
to		120		0.0	5.000	0.0				
19	65.09	0.0424		0.0	7.000	0.297		Vel = 6.22		
19	0.0	1.985		0.0	227.870	44.733				
to		150		0.0	0.0	0.217				
TEST	65.09	0.0342		0.0	227.870	7.798		Vel = 6.75		
	0.0									
	65.09					52.748		K Factor = 8.96		

Water Supply Curve (C)

DEAN & ALLYN, INC.
129 MORNING STREET

Page 6
Date 031608

City Water Supply:
C1 - Static Pressure : 72
C2 - Residual Pressure: 68
C2 - Residual Flow : 903

Demand:
D1 - Elevation : 8.879
D2 - System Flow : 65.0917
D2 - System Pressure : 52.748
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 65.0917
Safety Margin : 19.222

