



... Fire Protection by Computer Design

DEAN & ALLYN, INC.
32 LEWISTON ROAD BUILDING 1C
P.O. BOX 709
GRAY, ME 04039
207-657-5646

Job Name : 133 MORNING ST
Building : 129 Morning Street
Location : 3RD FLOOR - Portland, Maine
System : WX6
Contract : C780
Data File : 133-Morn.WX6

Fittings Used Summary

DEAN & ALLYN, INC.
133 MORNING ST

Page 1
Date 050908

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.
133 MORNING ST

Page 2
Date 050908

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
D501	36.75	4.2	7.36	na	11.39	0.05	100	7.0
D502	36.75	4.2	7.46	na	11.48	0.05	170	7.0
D503	36.75	4.2	7.24	na	11.3	0.05	80	7.0
D504	36.75	4.2	7.0	na	11.11	0.05	80	7.0
107	37.208		7.18	na				
105	37.208		7.3	na				
106	37.208		7.55	na				
94	37.208		6.93	na				
95	37.208		7.42	na				
96	37.208		9.03	na				
97	37.208		10.84	na				
98	37.208		12.82	na				
99	37.208		15.35	na				
100	37.208		15.51	na				
101	37.208		17.95	na				
102	26.5		25.31	na				
103	26.5		27.29	na				
104	26.5		28.28	na				
73	26.5		29.56	na				
74	26.5		31.7	na				
BTR	6.833		40.44	na				
BR	1.0		46.2	na				
UC	-5.0		55.09	na				
TEST	-10.0		61.76	na				

The maximum velocity is 9.71 and it occurs in the pipe between nodes 96 and 97

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
133 MORNING ST

Page 3
Date 050908

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
D501 to 105	11.39 11.39	1.049 120 0.0457	1E	2.0 0.0 0.0	1.000 2.000 3.000	7.358 -0.198 0.137			K Factor = 4.20 Vel = 4.23	
	0.0 11.39					7.297			K Factor = 4.22	
D502 to 106	11.48 11.48	1.049 120 0.0465	1T	5.0 0.0 0.0	1.000 5.000 6.000	7.465 -0.198 0.279			K Factor = 4.20 Vel = 4.26	
	0.0 11.48					7.546			K Factor = 4.18	
D503 to 107	11.30 11.3	1.049 120 0.0450	1E	2.0 0.0 0.0	1.000 2.000 3.000	7.241 -0.198 0.135			K Factor = 4.20 Vel = 4.19	
	0.0 11.30					7.178			K Factor = 4.22	
D504 to 94	11.11 11.11	1.049 120 0.0437	1E	2.0 0.0 0.0	1.000 2.000 3.000	7.000 -0.198 0.131			K Factor = 4.20 Vel = 4.12	
	0.0 11.11					6.933			K Factor = 4.22	
107 to 95	11.30 11.3	1.049 120 0.0453	1T	5.0 0.0 0.0	0.450 5.000 5.450	7.178 0.0 0.247			Vel = 4.19	
	0.0 11.30					7.425			K Factor = 4.15	
105 to 106	11.39 11.39	1.049 120 0.0460		0.0 0.0 0.0	5.410 0.0 5.410	7.297 0.0 0.249			Vel = 4.23	
106 to 96	11.48 22.87	1.049 120 0.1667	1T	5.0 0.0 0.0	3.910 5.000 8.910	7.546 0.0 1.485			Vel = 8.49	
	0.0 22.87					9.031			K Factor = 7.61	
94 to 95	11.11 11.11	1.049 120 0.0439	1E	2.0 0.0 0.0	9.200 2.000 11.200	6.933 0.0 0.492			Vel = 4.12	
95 to 96	11.30 22.41	1.049 120 0.1606	1T	5.0 0.0 0.0	5.000 5.000 10.000	7.425 0.0 1.606			Vel = 8.32	
96 to 97	22.87 45.28	1.38 120 0.1552	2E	6.0 0.0 0.0	5.660 6.000 11.660	9.031 0.0 1.810			Vel = 9.71	
97 to 98	0.0 45.28	1.38 120 0.1552	1E	3.0 0.0 0.0	9.750 3.000 12.750	10.841 0.0 1.979			Vel = 9.71	
98 to 99	0.0 45.28	1.38 120 0.1552	1E 1T	3.0 6.0 0.0	7.330 9.000 16.330	12.820 0.0 2.534			Vel = 9.71	

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
133 MORNING ST

Page 4
Date 050908

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
99 to 100	0.0 45.28	1.38 120 0.1550		0.0 0.0 0.0	1.000 0.0 1.000	15.354 0.0 0.155			Vel = 9.71	
100 to 101	0.0 45.28	1.38 120 0.1552	1T	6.0 0.0 0.0	9.750 6.000 15.750	15.509 0.0 2.445			Vel = 9.71	
101 to 102	0.0 45.28	1.38 120 0.1551	2E 1T	6.0 6.0 0.0	5.500 12.000 17.500	17.954 4.638 2.715			Vel = 9.71	
102 to 103	0.0 45.28	1.38 120 0.1552	1E	3.0 0.0 0.0	9.750 3.000 12.750	25.307 0.0 1.979			Vel = 9.71	
103 to 104	0.0 45.28	1.61 120 0.0733	1E 1T	4.0 8.0 0.0	1.540 12.000 13.540	27.286 0.0 0.992			Vel = 7.14	
104 to 73	0.0 45.28	1.61 120 0.0733		0.0 0.0 0.0	17.500 0.0 17.500	28.278 0.0 1.282			Vel = 7.14	
73 to 74	0.0 45.28	1.61 120 0.0733	1E 2T	4.0 16.0 0.0	9.146 20.000 29.146	29.560 0.0 2.135			Vel = 7.14	
74 to BTR	0.0 45.28	2.067 120 0.0217	1T	10.0 0.0 0.0	0.500 10.000 10.500	31.695 8.518 0.228			Vel = 4.33	
BTR to BR	0.0 45.28	2.067 120 0.0217	1Fsp 1E	0.0 5.0 0.0	5.583 5.000 10.583	40.441 5.526 0.230		* Fixed loss = 3	Vel = 4.33	
BR to UC	0.0 45.28	2.067 120 0.0217	6E 1Zaa	30.0 0.0 0.0	3.688 30.000 33.688	46.197 8.159 0.730		* Fixed loss = 5.56	Vel = 4.33	
UC to TEST	0.0 45.28	1.917 150 0.0207	2E	10.47 0.0 0.0	206.950 10.470 217.420	55.086 2.166 4.505			Vel = 5.03	
	0.0 45.28					61.757			K Factor = 5.76	

Water Supply Curve (C)

DEAN & ALLYN, INC.
133 MORNING ST

Page 5
Date 050908

City Water Supply:
C1 - Static Pressure : 72
C2 - Residual Pressure: 68
C2 - Residual Flow : 903

Demand:
D1 - Elevation : 20.247
D2 - System Flow : 45.2811
D2 - System Pressure : 61.757
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 45.2811
Safety Margin : 10.227

