



... Fire Protection by Computer Design

DEAN & ALLYN, INC.
32 LEWISTON ROAD BUILDING 1C
P.O. BOX 709
GRAY, ME 04039
207-657-5646

Job Name : 129 MORNING STREET
Building : 129 Morning Street
Location : 2CND FLOOR - Portland, Maine
System : WX4
Contract : C770
Data File : CALC.WX4

Hydraulic Design Information Sheet

Name - 129 Morning Street Date - 4/7/08
 Location - 2CND FLOOR - Portland, Maine
 Building - 129 Morning Street System No. - WX4
 Contractor - Dean & Allyn, Inc Contract No. - C770
 Calculated By - James R White Drawing No. - 1 OF 1
 Construction: (X) Combustible () Non-Combustible Ceiling Height - 8'-0"
 Occupancy - RESIDENTIAL APARTMENTS

S () NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other NFPA 13 R

T Specific Ruling Made By Date

E
 M Area of Sprinkler Operation - 4 HEADS System Type Sprinkler/Nozzle
 Density - .05 (X) Wet Make TYCO
 D Area Per Sprinkler - 140 () Dry Model TY2596
 E Elevation at Highest Outlet - 26'-5" () Deluge Size 1/2"
 S Hose Allowance - Inside - 0 () Preaction K-Factor 4.2
 I Rack Sprinkler Allowance - 0 () Other Temp.Rat.155 DEGRE
 G Hose Allowance - Outside - 0

N Note SAFETY MARGIN = 7.23 LBS PSI

Calculation Flow Required - 56.38 Press Required - 64.75
 Summary C-Factor Used: 150 Overhead 150 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 9/26/06 Cap. -
 T Time of Test - Rated Cap.- Elev.-
 E Static Press - 72 @ Press -
 R Residual Press - 68 Elev. - Well
 Flow - 903 Proof Flow
 S Elevation - 6

U Location - HYDRANT # 413

P
 L Source of Information - PORTLAND WATER DISTRICT
 Y

C Commodity Class Location
 O Storage Ht. Area Aisle W.
 M Storage Method: Solid Piled % Palletized % Rack
 M
 () Single Row () Conven. Pallet () Auto. Storage () Encap.
 S R () Double Row () Slave Pallet () Solid Shelf () Non
 T A () Mult. Row () Open Shelf
 O C

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G
 E Horizontal Barriers Provided:

Fittings Used Summary

DEAN & ALLYN, INC.
129 MORNING STREET

Page 2
Date 031608

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.
129 MORNING STREET

Page 3
Date 031608

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
D301	26.5	4.2	15.27	na	16.41	0.05	256	14.5
D302	26.5	4.2	9.6	na	13.01	0.05	75	9.6
D303	26.5	4.2	9.69	na	13.07	0.05	75	9.6
D304	26.5	4.2	10.92	na	13.88	0.05	75	9.6
62	27.0		10.87	na				
61	27.0		15.28	na				
51	27.0		9.53	na				
52	27.0		9.8	na				
53	27.0		11.35	na				
54	27.0		15.47	na				
55	27.0		17.8	na				
56	27.0		28.86	na				
57	6.5		40.43	na				
58	6.5		41.48	na				
59	6.5		42.36	na				
60	6.5		46.41	na				
16	6.5		47.09	na				
17	6.5		48.67	na				
18	6.5		48.96	na				
TOR	6.5		52.1	na				
BOR	6.5		58.32	na				
19	6.5		58.55	na				
TEST	6.0		64.75	na				

The maximum velocity is 19 and it occurs in the pipe between nodes 54 and 55

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
129 MORNING STREET

Page 4
Date 031608

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftn'g's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
D301 to 61	16.41	1.101 150	1E	3.825 0.0	1.000 3.825	15.274 -0.217			K Factor = 4.20	
	16.41	0.0473		0.0	4.825	0.228			Vel = 5.53	
	0.0									
	16.41					15.285			K Factor = 4.20	
D302 to 51	13.01	1.101 150	1E	3.825 0.0	1.000 3.825	9.600 -0.217			K Factor = 4.20	
	13.01	0.0309		0.0	4.825	0.149			Vel = 4.38	
	0.0									
	13.01					9.532			K Factor = 4.21	
D303 to 52	13.07	1.101 150	1T	9.563 0.0	1.000 9.562	9.688 -0.217			K Factor = 4.20	
	13.07	0.0311		0.0	10.562	0.328			Vel = 4.40	
	0.0									
	13.07					9.799			K Factor = 4.18	
D304 to 62	13.88	1.101 150	1E	3.825 0.0	1.000 3.825	10.918 -0.217			K Factor = 4.20	
	13.88	0.0346		0.0	4.825	0.167			Vel = 4.68	
	0.0									
	13.88					10.868			K Factor = 4.21	
62 to 53	13.88	1.101 150	1T	9.563 0.0	4.330 9.562	10.868 0.0				
	13.88	0.0346		0.0	13.892	0.481			Vel = 4.68	
	0.0									
	13.88					11.349			K Factor = 4.12	
61 to 54	16.41	1.101 150		0.0 0.0	3.830 0.0	15.285 0.0				
	16.41	0.0473		0.0	3.830	0.181			Vel = 5.53	
	0.0									
	16.41					15.466			K Factor = 4.17	
51 to 52	13.01	1.101 150		0.0 0.0	8.700 0.0	9.532 0.0				
	13.01	0.0307		0.0	8.700	0.267			Vel = 4.38	
52 to 53	13.08	1.101 150	1T	9.563 0.0	4.370 9.562	9.799 0.0				
	26.09	0.1113		0.0	13.932	1.550			Vel = 8.79	
53 to 54	13.87	1.101 150	1T	9.563 0.0	7.250 9.562	11.349 0.0				
	39.96	0.2449		0.0	16.812	4.117			Vel = 13.47	
54 to 55	16.42	1.101 150		0.0 0.0	5.040 0.0	15.466 0.0				
	56.38	0.4627		0.0	5.040	2.332			Vel = 19.00	
55 to 56	0.0	1.101 150	1E	3.825 0.0	20.080 3.825	17.798 0.0				
	56.38	0.4628		0.0	23.905	11.064			Vel = 19.00	
56 to 57	0.0	1.38 120	1E 1T	3.0 6.0	2.540 9.000	28.862 8.879				
	56.38	0.2328		0.0	11.540	2.686			Vel = 12.09	

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
129 MORNING STREET

Page 5
Date 031608

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
57 to 58	0.0 56.38	1.38 120 0.2328	1E	3.0 0.0 0.0	1.540 3.000 4.540	40.427 0.0 1.057		Vel = 12.09		
58 to 59	0.0 56.38	1.38 120 0.2328	1E	3.0 0.0 0.0	0.750 3.000 3.750	41.484 0.0 0.873		Vel = 12.09		
59 to 60	0.0 56.38	1.38 120 0.2328	1E 1T	3.0 6.0 0.0	8.410 9.000 17.410	42.357 0.0 4.053		Vel = 12.09		
60 to 16	0.0 56.38	1.682 120 0.0888		0.0 0.0 0.0	7.660 0.0 7.660	46.410 0.0 0.680		Vel = 8.14		
16 to 17	0.0 56.38	2.067 120 0.0326	2E	10.0 0.0 0.0	38.660 10.000 48.660	47.090 0.0 1.584		Vel = 5.39		
17 to 18	0.0 56.38	2.067 120 0.0325	1E	5.0 0.0 0.0	3.910 5.000 8.910	48.674 0.0 0.290		Vel = 5.39		
18 to TOR	0.0 56.38	2.067 120 0.0327	1Fsp	0.0 0.0 0.0	4.042 0.0 4.042	48.964 3.000 0.132		* Fixed loss = 3 Vel = 5.39		
TOR to BOR	0.0 56.38	2.067 120 0.0325	1E 1Zaa	5.0 0.0 0.0	10.500 5.000 15.500	52.096 5.724 0.504		* Fixed loss = 5.724 Vel = 5.39		
BOR to 19	0.0 56.38	2.067 120 0.0326	1E	5.0 0.0 0.0	2.000 5.000 7.000	58.324 0.0 0.228		Vel = 5.39		
19 to TEST	0.0 56.38	1.985 150 0.0262		0.0 0.0 0.0	227.870 0.0 227.870	58.552 0.217 5.977		Vel = 5.85		
	0.0 56.38					64.746		K Factor = 7.01		

Water Supply Curve (C)

DEAN & ALLYN, INC.
129 MORNING STREET

Page 6
Date 031608

City Water Supply:
C1 - Static Pressure : 72
C2 - Residual Pressure: 68
C2 - Residual Flow : 903

Demand:
D1 - Elevation : 8.879
D2 - System Flow : 56.3778
D2 - System Pressure : 64.746
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 56.3778
Safety Margin : 7.231

