Markup Legend	
Delete Line	
Add Line	
Add Tee	
Add Elbow	
Add Coupling	
Add Head	A.1 A.2 A.3
Delete Head	
Move Head	
Note: All revisions must be reviewed by Uponor	

Table F002-1

Multipurpose Fire Safety Systems

The Uponor Residential Fire Safety System is a residential fire protections system installed in combination with the cold side of the domestic potable water system. Only licensed contractors trained by Uponor can install this system.

What to do if Changes are Required

If any features or obstructions require the addition or deletion of sprinkler heads, or significant relocation of sprinkler heads, contact the Uponor Design Department to determine if observed changes require a redesign (888.594.7726).

SPRINKLER SYMBOL DEFINITION

XXX-XX(s1)(s2)

- SLOPED CEILING MAX. SLOPE OF 8:12 (33.7°) PITCH (MAY NOT APPLY)
- SLOPED CEILING MAX. SLOPE OF 4:12 (18.4°) PITCH (MAY NOT APPLY)
- MAXIMUM SPACING (TYP)
- SPRINKLER MODEL (TYP)
- HEAD SYMBOL (TYP)

COLOR/LINETYPE LEGEND

BLUE LINES= FEED TO FIXTURES (BATH, SHOWER, ETC.).
GREEN LINES= INTERLEVEL CONNECTIONS.
BLACK LINES= SPRINKLER HEAD TO SPRINKLER HEAD.

- 6 = 1/2" PIPE SIZE
- 5 = 3/4" PIPE SIZE
- 1 = 1" PIPE SIZE
- 1¼ = 1-1/4" PIPE SIZE
- 2 = 2" PIPE SIZE

1" AQUAPEX INTERLEVEL CONNECTIONS FROM FIRST FLOOR TO SECOND FLOOR

1 / F101

SECOND FLOOR

1/4" = 1'-0"

5 0 5 15

1/4" = 1'-0"

uponor

TECHNICAL SERVICES - DESIGN DEPARTMENT
5925 148th Street West, Apple Valley, MN 55124
T 888.594.7726 **F** 952.997.1731
E-M USTECHSERVICE@UPONOR.COM
WEB WWW.UPONOR-USA.COM

DISCLAIMER

THIS SERIES OF PLUMBING, HYDRONIC HEATING/COOLING, SNOW AND ICE MELTING, AND/OR FIRE SPRINKLER TECHNICAL DRAWINGS HAVE BEEN DESIGNED BY UPONOR, INC. TECHNICAL SERVICES - DESIGN DEPARTMENT. THEY HAVE BEEN PREPARED TO MEET PROFESSIONAL STANDARDS, PRESENT AND CONSTRUCTION, WHERE STATING ALL WORK ASSOCIATED WITH THIS DESIGN, IT IS MANDATORY TO MAKE A CAREFUL CHECK OF PIPE SIZE, CALCULATIONS, MATERIALS, PLUMBING AND/OR FIRE CODES USED. REPORT ANY ERRORS AND/OR DESIGN CHANGES TO UPONOR, INC. TECHNICAL SERVICES - DESIGN DEPARTMENT TO DETERMINE IF THE DESIGN REQUIRES REVISION. IF ERRORS AND/OR DESIGN CHANGES ARE NOT REPORTED BACK TO UPONOR, INC., IT IS THE SOLE RESPONSIBILITY OF THE INSTALLER TO ENSURE A SYSTEM DESIGN WILL FUNCTION IN ACCORDANCE WITH ALL APPLICABLE CODES AND EXPECTATIONS. THERE IS NO WARRANTY WRITTEN, EXPRESSED OR IMPLIED FOR DAMAGES THAT MAY RESULT FROM THE APPLICATION AND INCORRECT INTERPRETATION OF THESE DRAWINGS.

SALES REP:

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 5/21/2013
Planner: Benjamin Wallace Jr

10 HOWARD STREET

PORTLAND, ME 04101

DRAWN BY:	BRENT KOTULA, SET IV	CONTACT PH. NUMBER:	207-939-4515
CHECKED BY:	DAN HUBBARD	ALLIANCE ID:	TBD
CERTIFICATION LEVEL:	SET IV	PLOT DATE:	4/22/13
CERTIFICATION NUMBER:	115052	SHEET SCALE:	1/4"=1'-0"
COMPANY:	FORTIN SERVICES	PROJECT NUMBER:	13359F
CONTACT:	CHARLES FORTIN	SQUARE FEET:	3477 SQ. FT.

REVISIONS

NO.	DATE	DESCRIPTION
1	4/26/13	SIDEWALL SPRINKLERS IN FRONT ROOMS

SHEET DESCRIPTION
SECOND FLOOR

SHEET NUMBER
F101

T:\TechService\2013\Design Services\13359 10 Howard St\13359F R1\Uponor Drawing & Calcs\13359F REV 1 10 Howard St.dwg 04/26/13 - 8:28 am