Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 03/29/16

Protection 1 Branch 11660
10 Manual Drive, Portland, ME 04103 PH# 1-800-310-5011

System Outputs

System Inputs	Actuate common alarm signal indicator	Actuate audible alarm system	Actuate common supervisory signal indicator	Actuate audible supervisory signal	Actuate common trouble signal indicator	Actuate Ground Level A Evacuation Signals	Actuate Ground Level B Evacuation signals	Actuate 1st Floor Evacuation Signals	Actuate 2nd Floor Evacuation Signal	Actuate 3rd Floor Evacuation Signals	Actuate 4th Floor Evacuation Signals	Actuate 5th Floor Evacuation Signals	Transmit fire alarm signal to supervising station	Transmit supervisory signal to supervising	Transmit trouble signal to supervising station
	Control Unit Annunciation					Notification							Safety Contro		
System Pull Stations	X	X				X	X	X	X	X	X	X		X	
System Smoke Detectors	X	X				X	X	X	X	X	X	X		X	
System Heat Detectors	X	X				X	X	X	X	X	X	X		X	
Sprinkler Water Flow	X	X				X	X	X	X	X	X	X		X	
FACP AC Loss				X	X										X
FACP Low Battery				X	X										X
FACP Ground Fault				X	X										X
Phone Line #1 Fail				X	X										X
Phone Line #2 Fail				X	X										X

Promenarde East
340 Eastern Promenade
Portland, Maine 04101