

EXHAUST FAN INFORMATION - Job#1910978

FAN UNIT NO.	TAG	FAN UNIT MODEL #	CFM	ESP.	RPM	HP.	#	VOLT	FLA	DISCHARGE VELOCITY	WEIGHT (LBS.)	SONES
1		CASRE15B0	1733	0.860	1418	1.500	3	208	4.7	1273 FPM	226	17.2

MUA FAN INFORMATION - Job#1910978

FAN UNIT NO.	TAG	FAN UNIT MODEL #	BLOWER	HOUSING	CFM	ESP.	RPM	HP.	#	VOLT	FLA	WEIGHT (LBS.)	SONES
2		A1-G10	G10	A1	1560	0.350	654	0.750	3	208	2.7	277	10.7

FAN OPTIONS

FAN UNIT NO.	TAG	OPTION (Qty. - Descr.)
1		1 - Fan Base Ceramic Seal - For Grease Ducts
		1 - Utility Set Grease Cup
		1 - RE15 - Rain Cap Assembly - Includes Hardware And Gasket.
2		1 - Gravity Backdraft Damper For Size 1 Housing
		1 - Full Crating For Untempered Fans

FAN ACCESSORIES

FAN UNIT NO.	TAG	EXHAUST				SUPPLY			
		GREASE CUP	GRAVITY DAMPER	WALL MOUNT	SIDE DISCHARGE	GRAVITY DAMPER	MOTORIZED DAMPER	WALL MOUNT	
1		YES							
2						YES			

CURB ASSEMBLIES

NO.	DN FAN	WEIGHT	ITEM	SIZE
1	# 1	37 LBS	Curb	23,000"W x 23,000"L x 24,000"H Vented
2	# 2	29 LBS	Curb	21,000"W x 21,000"L x 20,000"H

CUSTOMER APPROVAL TO MANUFACTURE:

Approved as Noted

Approved with NO Exception Taken

Revise and Resubmit

SIGNATURE _____

Your Title _____ Date _____



CAPTIVEAIR

JOB 90 Congress St r3	
LOCATION PORTLAND, ME	
DATE 11/26/2013	JOB # 1910978
DWG # 2	DRAWN BY BFC-21
REV.	SCALE 3/8" = 1'-0"