Inspections Division
Date: 02/27/18

JOE KIEVITT
74-76 MUNJOY ST
PORTLAND, ME 04101
207-650-1084
kievitt@mac.com

- Wood stove installed 16” from non combustable heat shield at back (22” to combustable surfaces). Heat shield also on floor. These dimensions are within the allow distances for stove and stove pipe.

- Stove pipe made by ICC Chimney (http://icc-chimney.com/en/excel) - double walled 6” pipe in the interior and 6” insulated pipe through the ceiling cavity and through the roof. Installed in accordance with ICC specs and instructions.