

. . . Fire Protection by Computer Design

FREEDOM FIRE PROTECTION
77 BROWN ROAD
POLAND, MAINE 04274
(207) 998-9474

Job Name : GRISANTI CONDOMINIUMS HC2
Drawing : 60 MUNJOY STREET
Location : PORTLAND, MAINE 04101
Remote Area : #1 AREA #2
Contract :
Data File : GRISANTI CONDOMINIUMS HC2.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - GRISANTI CONDOMINIUMS Date - 10/20/17
Location - PORTLAND, MAINE 04101
Building - 60 MUNJOY STREET System No. - #1 AREA #2
Contractor - FREEDOM FIRE PROTECTION Contract No. -
Calculated By - MIKE NOBLIT Drawing No. - FP-3
Construction: (X) Combustible () Non-Combustible Ceiling Height 8'-6"
OCCUPANCY - CONDOMINIUMS

S Type of Calculation: (X)NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 16 Gpm System Type
Listed Pres. at Start Point - 13.2 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16' x 16' () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - 0 Gpm Make TYCO Model LFII
I Elevation at Highest Outlet - 24.166Feet Size 1/2" K-Factor 4.4
G Note: Temperature Rating 155
N

Calculation Gpm Required 66.374 Psi Required 43.171 At Test
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 5/25/2017 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 57 Elev.
R Residual (Psi) - 54 Other Well
Flow (Gpm) - 1198 Proof Flow Gpm
S Elevation -

P Location:
P
L Source of Information: PORTLAND WATER DISTRICT
Y


Water Supply Curve C

FREEDOM FIRE PROTECTION
GRISANTI CONDOMINIUMS HC2

Page 2
Date 10/20/17

City Water Supply:
C1 - Static Pressure : 57
C2 - Residual Pressure: 54
C2 - Residual Flow : 1198

Demand:
D1 - Elevation : 10.466
D2 - System Flow : 66.374
D2 - System Pressure : 43.171
Hose (Demand) : _____
D3 - System Demand : 66.374
Safety Margin : 13.815



Fittings Used Summary

FREEDOM FIRE PROTECTION
GRISANTI CONDOMINIUMS HC2

Page 3
Date 10/20/17

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

FREEDOM FIRE PROTECTION
GRISANTI CONDOMINIUMS HC2

Page 4
Date 10/20/17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
201	24.166	4.4	16.22	na	17.72	0.05	0.001	13.2
26	24.166		16.46	na				
10	5.166		26.24	na				
202	24.166	4.4	14.0	na	16.46	0.05	0.001	13.2
7	24.166		14.47	na				
6	5.166		23.79	na				
203	24.166	4.4	13.57	na	16.21	0.05	0.001	13.2
25	24.166		13.76	na				
24	5.166		23.05	na				
204	24.166	4.4	13.2	na	15.99	0.05	0.001	13.2
23	24.166		13.65	na				
22	5.166		22.91	na				
21	5.166		23.08	na				
20	5.166		23.22	na				
5	5.166		23.97	na				
4	5.166		26.45	na				
3	5.166		29.34	na				
2	5.166		32.09	na				
1	0.0		41.29	na				
0	0.0		42.1	na				
TEST	0.0		43.17	na				

The maximum velocity is 14.24 and it occurs in the pipe between nodes 4 and 3

Final Calculations - Hazen-Williams - 2007

FREEDOM FIRE PROTECTION
GRISANTI CONDOMINIUMS HC2

Page 5
Date 10/20/17

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
201 to 26	24.166 24.166	4.40	17.72 17.72	1 1.101	E 0.0	3.825 3.825 0.0	150 0.0543	16.222 0.0 0.235		Vel = 5.97	
26 to 10	24.166 5.166		0.0 17.72	1 1.101	T 0.0	9.563 9.562 0.0	150 0.0544	16.457 8.229 1.554		Vel = 5.97	
10 to 4	5.166 5.166		0.0 17.72	1.25 1.38	T 0.0	9.066 9.066 0.0	150 0.0182	26.240 0.0 0.210		Vel = 3.80	
4			0.0 17.72					26.450		K Factor = 3.45	
202 to 7	24.166 24.166	4.40	16.46 16.46	1 1.101	T 0.0	9.563 9.562 0.0	150 0.0474	13.996 0.0 0.477		Vel = 5.55	
7 to 6	24.166 5.166		0.0 16.46	1 1.101	E 0.0	3.825 3.825 0.0	150 0.0474	14.473 8.229 1.083		Vel = 5.55	
6 to 5	5.166 5.166		0.0 16.46	1.25 1.38	T 0.0	6.0 6.000 0.0	120 0.0239	23.785 0.0 0.183		Vel = 3.53	
5			0.0 16.46					23.968		K Factor = 3.36	
203 to 25	24.166 24.166	4.40	16.21 16.21	1 1.101	E 0.0	3.825 3.825 0.0	150 0.0462	13.565 0.0 0.200		Vel = 5.46	
25 to 24	24.166 5.166		0.0 16.21	1 1.101	E 0.0	3.825 3.825 0.0	150 0.0461	13.765 8.229 1.052		Vel = 5.46	
24 to 20	5.166 5.166		0.0 16.21	1.25 1.38	T 0.0	6.0 6.000 0.0	120 0.0232	23.046 0.0 0.178		Vel = 3.48	
20			0.0 16.21					23.224		K Factor = 3.36	
204 to 23	24.166 24.166	4.40	15.99 15.99	1 1.101	T 0.0	9.563 9.562 0.0	150 0.0449	13.200 0.0 0.452		Vel = 5.39	
23 to 22	24.166 5.166		0.0 15.99	1 1.101	E 0.0	3.825 3.825 0.0	150 0.0450	13.652 8.229 1.026		Vel = 5.39	
22 to 21	5.166 5.166		0.0 15.99	1.25 1.38	T 0.0	6.0 6.000 0.0	120 0.0227	22.907 0.0 0.174		Vel = 3.43	
21 to 20	5.166 5.166		0.0 15.99	1.25 1.38		0.0 0.0 0.0	120 0.0226	23.081 0.0 0.143		Vel = 3.43	
20 to 5	5.166 5.166		16.20 32.19	1.25 1.38		0.0 0.0 0.0	120 0.0825	23.224 0.0 0.744		Vel = 6.90	

Final Calculations - Hazen-Williams

FREEDOM FIRE PROTECTION
GRISANTI CONDOMINIUMS HC2

Page 6
Date 10/20/17

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
5 to 4	5.166 5.166		16.46 48.65	1.25 1.38		14.000 0.0	120	23.968 0.0			
4 to 3	5.166 5.166		17.72 66.37	1.25 1.38	T 0.0	6.0 6.000	120	26.450 0.0		Vel = 10.44	
3 to 2	5.166 5.166		0.0 66.37	1.5 1.61	E 0.0	4.0 4.000	120	29.336 0.0		Vel = 14.24	
2 to 1	5.166 0		0.0 66.37	1.5 1.61	Zaa E 0.0	5.166 4.000	120	32.085 7.837		Vel = 10.46	** Fixed Loss = 5.6
1 to 0	0 0		0.0 66.37	2 1.739		12.000 0.0	150	41.285 0.0		Vel = 10.46	
0 to TEST	0 0		0.0 66.37	2 1.959		25.000 0.0	140	42.096 0.0		Vel = 8.97	
TEST			0.0 66.37			25.000	0.0430	1.075		Vel = 7.06	
TEST								43.171		K Factor = 10.10	