

Freedom Fire Protection, Inc.

Over 30 Years of Fire Protection Experience
77 Brown Rd. Poland, Maine 04274
Phone 207/998-9474 Fax 207/998-9473

August 9, 2018

Portland City Hall
Third Floor Room 315
Portland, Maine 04101

Attn. Captain Petruccelli

Ref: Grisanti Apartments
60 Munjoy Street
Portland, Maine

Subj: Sprinkler System Certification Letter

This letter is certification that sprinkler system for the Basement, 1st level, and 2nd level were designed, calculated and installed at the above referenced location by Freedom Fire Protection, and meet the requirements of the National Fire Protection Association 13R Standard (NFPA 13R). At this current date the building is only partially sprinkled. The 3rd floor renovation has not been completed once the renovation is completed Freedom Fire Protection will complete the fire sprinkler installation. Therefore the sprinkler system certification test papers and the signed State of Maine permit will not be available until the project is completed

Sprinkler permit # FSP13470 was issued by the State of Maine Fire Marshal's office.

The partial portion of the sprinkler system was left in service by Freedom Fire Protection on August 8, 2018.

The alarm flow switch was tested and received at the fire alarm panel and monitoring company within 22 seconds. The (2) two control valve tampers were tested and received at the fire alarm panel and monitoring company.

Regards,