FOOTINGS & STAIRS

CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 08/19/16

use sloped joist hanger w/min capacity of 625#

Sec 1009.4.2 Max riser hight 7"
minimum tread depth 11"
1009.4.3 Dimentional Uniformity
Max 3/8" for risers and treads