

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

Christopher Gelfand/Munjoy Hill Homes

Located at

33 ATLANTIC ST

PERMIT ID: 2013-01174

ISSUE DATE: 07/03/2013

CBL: 016 C016001

has permission to **Interior renovation - adding new interior stairway. Removing chimney - removing kitchen on second floor and moving to 3rd floor for changing unit configuration - within same footprint. Some window changes.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
two Family Dwelling

Building Inspections

Fire Department

Classification:

One or Two Family Dwellings

ENTIRE

2009 NFPA

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing

Final Inspection

Electrical Close-in

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2013-01174	Date Applied For: 06/07/2013	CBL: 016 C016001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Saame: Two Family	Proposed Project Description: Interior renovation - adding new interior stairway. Removing chimney - removing kitchen on second floor and moving to 3rd floor for changing unit configuration -within same footprint. Some window changes.			
Dept: Zoning Status: Approved w/Conditions Reviewer: Marge Schmuckal Approval Date: 06/14/2013				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) This permit is being approved on the basis of revised plans submitted. Any deviations shall require a separate approval before starting that work.				
2) This is NOT an approval for an additional dwelling unit. You SHALL NOT add any additional kitchen equipment including, but not limited to items such as stoves, microwaves, refrigerators, or kitchen sinks, etc. Without special approvals.				
3) This property shall remain a two family dwelling. Any change of use shall require a separate permit application for review and approval. It is understood that there is an internal reconfiguration of the two dwelling units within the structure.				
Dept: Building Status: Approved w/Conditions Reviewer: Tammy Munson Approval Date: 06/26/2013				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) Permit approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire Status: Approved w/Conditions Reviewer: Chris Pirone Approval Date: 07/02/2013				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Single-station Carbon Monoxide (CO) alarms are required. They shall be powered by the building's electrical service with battery backup and shall be interconnected. CO alarms shall be installed in the following locations: (1) Outside each separate dwelling unit sleeping area in the immediate vicinity of the bedrooms (2) On every occupiable level of the dwelling unit, including basements, excluding attics and crawl spaces				
2) Single-station photoelectric smoke alarms are required. They shall be powered by the building's electrical service with battery backup and shall be interconnected. Smoke alarms shall be installed in the following locations: (1) All sleeping rooms (2) Outside each separate sleeping area, in the immediate vicinity of the sleeping rooms (3) On each level of the dwelling unit, including basements.				
3) A copy of the State Sprinkler permit with RMS date and signature shall be provided prior to scheduling of the final inspection.				
4) A sprinkler system shall be installed in accordance with NFPA 13D. A no fee One- or Two-family CITY Fire Sprinkler Permit is required.				