

... Fire Protection by Computer Design

EASTERN FIRE PROTECTION
170 KITTYHAWK AVE.
P.O. BOX 1390
AUBURN, MAINE 04210
207-784-1507

Job Name : 33 ATLANTIC AVE.
Drawing : WOOD CONSTRUCTION
Location : PORTLAND, MAINE
Remote Area : WET
Contract : 5088
Data File : 33 ATLANTIC AVENUE REMOTE.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 33 ATLANTIC AVE. Date - 10-28-13
Location - PORTLAND, MAINE
Building - WOOD CONSTRUCTION System No. - WET
Contractor - EASTERN FIRE PROTECTION Contract No. - 5088
Calculated By - ROBERT PETERS Drawing No. - 1 OF 1
Construction: (X) Combustible () Non-Combustible Ceiling Height VARIES
OCCUPANCY - RESIDENTIAL

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 23 Gpm System Type
Listed Pres. at Start Point - 27.3 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 18 x 18 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make TYCO Model LF II
I Elevation at Highest Outlet - 125.83Feet Size 1/2" K-Factor 4.4
G Note: Temperature Rating 155
N

Calculation Gpm Required 45.455 Psi Required 50.504 At Test
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - Rated Cap. 40 Cap. 525
T Time of Test - @ Psi 52.39 Elev.
E Static (Psi) - Elev. 94'
R Residual (Psi) - Other Well
Flow (Gpm) - Proof Flow Gpm
S Elevation -

P Location: BASEMENT

P
L Source of Information: PUMP MANUFACTURER DATA SHEET
Y


Water Supply Curve C

EASTERN FIRE PROTECTION
33 ATLANTIC AVE.

Page 2
Date 10-28-13

Pump Data:
P1 - Pump Churn Pressure : 54.99
P2 - Pump Rated Pressure : 52.39
P2 - Pump Rated Flow : 40
P3 - Pump Pressure @ Max Flow : 32.04
P3 - Pump Max Flow : 80

Demand:
D1 - Elevation : 12.703
D2 - System Flow : 45.455
D2 - System Pressure : 50.504
Hose (Demand) : _____
D3 - System Demand : 45.455
Safety Margin : 0.128



Fittings Used Summary

EASTERN FIRE PROTECTION
33 ATLANTIC AVE.

Page 3
Date 10-28-13

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

Node at Source	Static Pressure	Residual Pressure	Flow	Available Pressure	Total Demand	Required Pressure
PUMP	See Information on Pump Curve			50.632	45.45	50.504

NODE ANALYSIS

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes
LIN	0.0	5.6	10.68	18.3	
1	123.33	4.4	27.3	22.99	
A	118.083		30.71		
2	125.833	4.4	26.07	22.46	
H	118.083		30.4		
I	118.083		30.6		
J	118.083		30.94		
C	118.083		31.82		
D	109.042		36.19		
E	98.75		42.4		
L	98.75		43.18		
G	98.75		43.88		
TOR	94.0		46.32		
PUMP	94.0		50.5		

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
33 ATLANTIC AVE.

Page 5
Date 10-28-13

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
LIN to DRP1	0 0	5.60	18.30 18.3	1 1.049	2E T	4.0 5.0 0.0	1.833 9.000 10.833	120 0.1104	10.679 0.0 1.196			Vel = 6.79
DRP1			0.0 18.30						11.875			K Factor = 5.31
1 to A	123.330 118.083	4.40	22.99 22.99	1 1.101	E	3.825 0.0 0.0	9.083 3.825 12.908	150 0.0881	27.300 2.272 1.137			Vel = 7.75
A to J	118.083 118.083		0.0 22.99	1.5 1.598	T	11.656 0.0 0.0	4.333 11.656 15.989	150 0.0143	30.709 0.0 0.229			Vel = 3.68
J			0.0 22.99						30.938			K Factor = 4.13
2 to H	125.833 118.083	4.40	22.46 22.46	1 1.101	E	3.825 0.0 0.0	7.750 3.825 11.575	150 0.0843	26.068 3.357 0.976			Vel = 7.57
H to I	118.083 118.083		0.0 22.46	1.5 1.598	T	11.656 0.0 0.0	2.917 11.656 14.573	150 0.0137	30.401 0.0 0.200			Vel = 3.59
I to J	118.083 118.083		0.0 22.46	1.5 1.598	T	11.656 0.0 0.0	12.875 11.656 24.531	150 0.0137	30.601 0.0 0.337			Vel = 3.59
J to C	118.083 118.083		22.99 45.45	1.5 1.598	2E	11.656 0.0 0.0	5.708 11.656 17.364	150 0.0507	30.938 0.0 0.880			Vel = 7.27
C to D	118.083 109.042		0.0 45.45	1.5 1.598		0.0 0.0 0.0	9.042 0.0 9.042	150 0.0505	31.818 3.916 0.457			Vel = 7.27
D to E	109.042 98.750		0.0 45.45	1.5 1.598	2E T	11.656 11.656 0.0	11.292 23.312 34.604	150 0.0507	36.191 4.457 1.753			Vel = 7.27
E to L	98.750 98.750		0.0 45.45	1.5 1.61		0.0 0.0 0.0	10.583 0.0 10.583	120 0.0738	42.401 0.0 0.781			Vel = 7.16
L to G	98.750 98.750		0.0 45.45	1.5 1.61	T	8.0 0.0 0.0	1.458 8.000 9.458	120 0.0737	43.182 0.0 0.697			Vel = 7.16
G to TOR	98.750 94		0.0 45.45	1.5 1.682	E	4.95 0.0 0.0	1.542 4.950 6.492	120 0.0598	43.879 2.057 0.388			Vel = 6.56
TOR to PUMP	94 94		0.0 45.45	1.5 1.61	S Fsp	9.0 0.0 0.0	7.000 9.000 16.000	120 0.0738	46.324 3.000 1.180			* * Fixed Loss = 3 Vel = 7.16
PUMP			0.0 45.45						50.504			K Factor = 6.40

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
33 ATLANTIC AVE.

Page 6
Date 10-28-13

Node1	Elev1	K	Qa	Nom	Fitting		Pipe	CFact	Pt			
to					or		Ftng's		Pe	*****	Notes	*****
Node2	Elev2	Fact	Qt	Act	Eqv.	Ln.	Total	Pf/Ft	Pf			
