

CITY OF PORTLAND
Fire Department
 380 Congress Street
 Portland, Maine 04101

Fire Inspection Violations

Business	Location	Number	Inspection Type
	0007 ATLANTIC ST	48308-0-0	FP Routine Inspection
Owner/Manager	CBL	Inspector	
KATZE MEHITABEL LENA	016 C022001	KEVIN P MCGUIRE Shift: 004 Unit: L1	

Code	Type	Location	Inspection Date	Target Compliance	Actual Compliance
1	101-5-21	Fire Doors Required	All apartments	3/18/08	4/20/08
2	K-NFPA31	boiler protection required	basement	3/18/08	4/20/08
3	4.5.3.1	Minumum of two means of egress	all apartments need two means	3/18/08	4/20/08