



Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/16/14

Bartlett Design

LIGHTING & ELECTRICAL ENGINEERING

942 WASHINGTON STREET BATH, MAINE 04

TEL (207) 443-5447 FAX (207) 443-5560

CLARIFICATIONS

DATE: May 13, 2014

PROJECT: 118 on Munjoy Hill
13-0048

ARCHITECT: Archetype
Portland, Maine

REF: Revised Electrical Room Layout

Revise the layout of Electrical Room 110 per attached sketch SKE1.01.



Reviewed for Code Compliance
Inspectors Division
Approved with Conditions

Date: 05/16/14

PANEL HP2
120/208V, 3PH, 4W

LIGHTING CONTROL
PANEL LC1
HP1 #20

TELECOM DEMARCATION
EQUIPMENT
HP1 #18

FIRE ALARM
PANEL (HP1 #14)

FIRE ALARM
BOOSTERS
HP1 #16

PANEL HP1 (2 SECTION)
120/208V, 3PH, 4W

DISTRIBUTION PANEL DP HP1 #47
120/208V, 3PH, 4W

MODULAR METER CENTER

required
clear
space

required
clear
space

NORTH



ELECTRICAL 110

1/4" = 1'-0"



Lawrence E. Bartlett
5/13/14

**ARCHITECTS
ARCHETYPE, P.A.**

48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056

118 ON MUNJOY HILL

118 CONGRESS STREET
PORTLAND, MAINE

Date: 05-13-14
Scale: 1/4" = 1'-0"

SK-E1.01a