



SECTION 16111

CONDUIT

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Rigid metal conduit and fittings.
- B. Non-metallic conduit and fittings.
- C. Electrical metallic tubing and fittings.
- D. Flexible metal conduit and fittings.
- E. Liquid-tight flexible metal conduit and fittings.

1.2 RELATED WORK

- A. Section 16123 - Wiring and Cable

1.3 REFERENCES

- A. ANSI C80.1 - Rigid Steel Conduit, Zinc-Coated.
- B. ANSI C80.3 – Electrical Metallic Tubing, Zinc-Coated.
- C. ANSI/NEMA FB 1 - Fittings and Supports for Conduit and Cable Assemblies.
- D. NEMA TC 2 - Electrical Plastic Tubing (EPT) and Conduit (EPC-40 and EPC-80).
- E. NEMA TC 3 - PVC Fittings for Use with Rigid PVC Conduit and Tubing.

PART 2 - PRODUCTS

2.1 RIGID METAL CONDUIT AND FITTINGS

- A. Rigid Steel Conduit: ANSI C80.1.
- B. Fittings and Conduit Bodies: ANSI/NEMA FB 1; threaded type, material to match conduit.

2.2 ELECTRICAL METALLIC TUBING (EMT) AND FITTINGS

- A. EMT: ANSI C80.3 galvanized tubing.



Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/16/14

118 ON MUNJOY HILL – PORTLAND, MAINE

- B. Fittings and Conduit Bodies: ANSI/NEMA FB1; steel compression or set-screw type.

2.3 FLEXIBLE METAL CONDUIT AND FITTINGS

- A. Conduit: Steel.
- B. Fittings and Conduit Bodies: ANI/NEMA FB 1.

2.4 LIQUID-TIGHT FLEXIBLE METAL CONDUIT AND FITTINGS

- A. Conduit: Flexible metal conduit with PVC jacket.
- B. Fittings and Conduit Bodies: ANSI/NEMA FB1.

2.5 PLASTIC CONDUIT AND FITTINGS

- A. Conduit: NEMA TC 2; Schedule 40 PVC.
- B. Fittings and Conduit Bodies: NEMA TC 3.

2.6 CONDUIT SUPPORTS

- A. Conduit Clamps, Straps, and Supports: Steel or malleable iron.

PART 3 - EXECUTION

3.1 CONDUIT SIZING, ARRANGEMENT, AND SUPPORT

- A. Size conduit for conductor type installed $\frac{3}{4}$ -inch minimum size.
- B. Arrange conduit to maintain headroom and present a neat appearance.
- C. Route conduit parallel and perpendicular to walls.
- D. Maintain minimum 6-inch clearance between conduit and heat sources such as flues, steam pipes and heating appliances.
- E. Arrange conduit supports to prevent distortion of alignment by wire pulling operations. Fasten conduit using galvanized straps, lay-in adjustable hangers, clevis hangers, or bolted split stamped galvanized hangers.
- F. Group conduit in parallel runs where practical and use conduit rack constructed of steel channel with conduit straps or clamps. Provide space for 25 percent additional conduit.



G. Do not fasten conduit with wire or perforated pipe straps. Remove all wire used for temporary conduit support during construction, before conductors are pulled.

H. Support conduit at spacing not to exceed the spacing allowed per ANSI 70.

3.2 CONDUIT INSTALLATION

A. Cut conduit square using a saw or a pipe cutter; de-burr cut ends.

B. Bring conduit to the shoulder of fittings and couplings and fasten securely.

C. Use conduit hubs for fastening conduit to cast boxes, and for fastening conduit to sheet metal boxes in damp or wet locations.

D. Install no more than the equivalent of three 90-degree bends between boxes.

E. Use hydraulic one-shot conduit bender or factory elbows for bends in conduit larger than 1-inch size.

F. Avoid moisture traps where possible; where unavoidable, provide junction box with drain fitting at conduit low point.

G. Use suitable conduit caps to protect installed conduit against entrance of dirt and moisture.

H. Provide No. 12 AWG insulated conductor or suitable nylon pull rope in empty conduit, except sleeves and nipples.

I. Install expansion joints where conduit crosses building expansion joints.

J. Where conduit penetrates fire-rated walls and floors, seal opening around conduit with UL listed foamed silicone elastomer compound.

K. Wipe plastic conduit clean and dry before joining. Apply full even coat of cement to entire area that will be inserted into fitting. Let joint cure for 20 minutes minimum. Provide spacers for multiple runs of buried raceways.

L. Where conduit(s) pass(es) from refrigerated or cooled atmosphere to warmer areas where condensation of water vapor may occur within raceways, conduit bodies sealed with "duct Seal" type compound shall be provided after conductors are installed.

M. Flexible metal conduit shall not exceed three (3) feet in length.

N. Where exposed ceiling structure exists in unfinished spaces, conduit shall be run on the ceiling deck parallel to ceiling joists, along the sides of primary framing members, or immediately adjacent to walls. Exposed conduit running from joist-to-joist attached to the bottom of joists will not be accepted.



- O. Where conduit is installed to be attached to metal roof deck, maintain 1-1/2" clearance between the conduit and the roof deck.

3.3 UNDERGROUND CONDUIT INSTALLATION

- A. Install top of conduit minimum 30 inches below finished grade.
- B. Slope underground conduit away from building.
- C. Use rigid galvanized steel conduit long-sweeps for underground elbows in conduit sizes 2 inch and larger.

3.4 CONDUIT INSTALLATION OF SCHEDULE

- A. Underground Installations: Schedule 40 plastic conduit.
- B. Exposed Outdoor Locations: Rigid steel conduit.
- C. Exposed Interior Locations (unfinished spaces): Electrical metallic tubing.
- D. Connections to Motors (exterior locations): Liquid-tight flexible metal conduit.
- E. Connections to Motors (interior locations): Flexible metal conduit.

END OF SECTION