

**NO  
EXCUSES!**



## FIRE ALARM DOCUMENTS

The FAD is the perfect fit to meet the demanding code requirements today. SAE's number one goal is to manufacture code compliant solutions and this product allows you to do just that. NFPA 72 2010 section 6.2.2.1 states, "A record of installed software and firmware version numbers shall be maintained at the location of the fire alarm control unit."

This durable 16 gauge steel enclosure with a solid piano hinge and key lock will keep all of your code required documents in one safe place. With a 4GB USB flash drive it stores your fire alarm software safe and secure eliminating the occurrences of the software not being on site when technicians arrive to service the system. Along with your fire alarm software you can store your test & inspection documents, service records, manuals & AS built drawings for the system. Using a standard USB B connector it allows you to plug in with any standard SB printer cable to upload or download information.

The FDB is designed to hold critical manuals and documents with a durable steel retainer. It has designated hooks to organize key rings and hold important business cards for easy access and reference. Inside the cover it has a organized note table that allows for documentation for passwords and other critical system information.

### Standard Features:

- Installed with a 4 gig digital flash drive with USB B connector
- 2 Key ring hooks to hold system keys
- Business card holder for key contacts
- Overall Dimensions are 12" x 13" tall and 2 ¼ deep
- 16 gauge steel box and cover for security
- Durable powercoat baked on finish other colors available
- Standard ¾" cat 30 key lock other lock assemblies available
- Solid stainless steel piano hinge
- Permanently screened white ink 1" high "Fire Alarm Documents"
- Legend sheet for passwords and system information



**ISO 9001  
REGISTERED  
COMPANY**




**ACEBOX**

Space Age Electronics, Inc.  
www.1sae.com  
**800.486.1723** Toll Free  
508.485.0966 Local  
508.485.4740 Fax

## Specifications:

The fire alarm documents box (FAD) shall be constructed of 18 gauge cold rolled steel. It shall have a red powder coat epoxy finish. The cover shall be permanently screened with 1" high lettering "FIRE ALARM DOCUMENTS" with white indelible ink. The access door shall be locked with a 3/4" barrel lock and the hinge shall be a solid width 12" stainless steel piano hinge. The enclosure will supply 4 mounting holes. Inside the enclosure will accommodate standard 8 1/2 x 11 manuals and loose document records that will be protected within the enclosure. A legend sheet will be permanently attached to the door for system required documentation, key contacts and system information. The FAD will have securely mounted inside a minimum of 4 Gigabyte digital flash memory drive with a standard USB B connector for uploading and downloading information. The drive shall not be accessible without tools to any person whom gains access to the records. The enclosure shall also provide 2 key ring holders with a location to mount standard business type cards for key contact personnel.



USB Storage Interface  
Requires Standard USB-B  
Connector

Key Ring  
Hooks

Business  
Card Holder

For replacement forms order PIN: EA0316 (Qty. 10)

Property Information	Minimum Required Documentation (SIG-FUN)
Name of property: _____	(Reference NFPA-72 2013 Section 7.2.1)
Address: _____	1 Written narrative providing intent and system description
Description of property: _____	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
Occupancy type: _____	2 Riser diagram
	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
	3 Floor plan layout showing location of all devices and control equipment
	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
	4 Sequence of operation in either an input/output matrix or narrative form
	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
	5 Equipment technical data sheets
	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
	6 Manufacturers published instructions, including operation and maintenance instruction
	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
	7 Battery calculations (where batteries are provided)
	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
	8 Voltage drop calculations for notification appliance circuits
	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
	9 Completed record of inspection and testing in accordance with 7.6.6 and 7.8.2
	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
	10 Completed record of completion in accordance with 7.5.6 and 7.8.2
	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
	11 Copy of site specific software, where applicable
	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
	12 Record (as built) drawings
	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
	13 Periodic inspection, testing, and maintenance documentation in accordance with Section 7.6
	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
	14 Records, record retention, and record maintenance in accordance with 7.7
	<input type="checkbox"/> NA <input type="checkbox"/> Enclosed <input type="checkbox"/> At Location
Signed: _____	Signed: _____ Date: ____/____/____

Space Age Electronics, Inc. 58 Chocksett Road Sterling, MA 01564 800-486-1723 www.1sae.com LT10644 Rev. 1

Legend sheet for storing system information including contacts, sign-off, maintenance & test information, and alternate locations of additional records.

## Ordering Information:

Part # Description

SSU00685 Fire Alarm Storage Cabinet RED

SSU00686 Custom screening with your Logo

Check out our Infinity line eFAD single gang 2 Gig digital storage solutions (IAMEFAD)



Space Age Electronics, Inc.  
www.1sae.com  
800.486.1723 Toll Free  
508.485.0966 Local  
508.485.4740 Fax

No Excuses, Just Solutions!

This document is subject to change without notice, see doc # ED0479 for legal disclaimer

ED0549

LT10559

Rev.C

2/2