



- general notes
1. "VL" indicates 'versa-lam' beam manuf. by Boise Cascade or approved equal.
 2. wall sheathing shall be 1/2" APA rated sheathing w/ 10d nails @ 4" oc at panel edges and 6" oc intermediate.
 3. provide 2x6 jack stud plus 2-2x6 king studs at each jamb, typ. (unless noted otherwise)