

. . . Fire Protection by Computer Design

Residential Fire Protection
64 Daggett Hill Rd.
Greene, ME 04236
(207)946-343

Job Name : 93 SAINT LAWRENCE STREET BLDG
Building : WOOD STRUCTURE
Location : 1ST FLR UNIT
System : 1 (WET)
Contract : C16014
Data File : 93 ST LAWRENCE ST- 1ST FLR- HYD CALC.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 93 ST. LAWRENCE STREET Date - 4/18/2016
Location - 1ST FLR UNIT
Building - WOOD STRUCTURE System No. - 1 (WET)
Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C16014
Calculated By - T. PRAY Drawing No. - 1 OF 2
Construction: (X) Combustible () Non-Combustible Ceiling Height 8'-6"
OCCUPANCY - APARTMENT

S Type of Calculation: (X)NFPA 13 Residential ()NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 7 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16' x 16' () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make VIKING Model VK468
I Elevation at Highest Outlet - 109.08Feet Size 7/16" K-Factor 4.9
G Note: Temperature Rating 155
N

Calculation Gpm Required 74.82 Psi Required 45.94 At Test
Summary C-Factor Used: Overhead 150 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 4/30/2014 Rated Cap. Cap.
T Time of Test - N/A @ Psi Elev.
E Static (Psi) - 50 Elev.
R Residual (Psi) - 44 Other Well
Flow (Gpm) - 919 Proof Flow Gpm
S Elevation - 100

P Location: TEST HYDRANT AT THE CORNER OF MONUMENT ST AND ST LAWRENCE ST,
P SEE PLOT PLAN FOR MORE INFORMATION
L Source of Information: PORTLAND WATER DISTRICT
Y


Water Supply Curve (C)

Residential Fire Protection
93 SAINT LAWRENCE STREET BLDG

Page 2
Date 4/18/16

City Water Supply:
C1 - Static Pressure : 50
C2 - Residual Pressure: 44
C2 - Residual Flow : 919

Demand:
D1 - Elevation : 3.933
D2 - System Flow : 74.8219
D2 - System Pressure : 45.942
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 74.8219
Safety Margin : 4.000



Fittings Used Summary

Residential Fire Protection
93 SAINT LAWRENCE STREET BLDG

Page 3
Date 4/18/16

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Pressure / Flow Summary - STANDARD

Residential Fire Protection
93 SAINT LAWRENCE STREET BLDG

Page 4
Date 4/18/16

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DO01	0.0	4.9	12.05	na	17.01	0.0525	324	12.0
DO02	0.0	4.9	12.05	na	17.01	0.0525	324	12.0
40	109.08	K = K @ EQ01	12.75	na	17.01			
41	109.08	K = K @ EQ02	14.41	na	17.65			
42	109.08	K = K @ EQ01	17.14	na	19.72			
43	109.08	K = K @ EQ02	19.32	na	20.44			
53	109.08		26.52	na				
54	109.08		26.75	na				
55	109.08		27.33	na				
AD	109.08		27.9	na				
TOR	108.5		31.82	na				
BOR	102.08		37.48	na				
BFP	102.08		37.8	na				
6UG	101.0		45.47	na				
TEST	100.0		45.94	na				

The maximum velocity is 21.48 and it occurs in the pipe between nodes 43 and 53

Final Calculations - Hazen-Williams

Residential Fire Protection
93 SAINT LAWRENCE STREET BLDG

Page 5
Date 4/18/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DO01 to EQ01	17.01 17.01	0.874 150 0.1551	1E	4.026 0.0 0.0	0.500 4.026 4.526	12.051 0.0 0.702			K Factor = 4.90 Vel = 9.10	
	0.0 17.01					12.753			K Factor = 4.76	
DO02 to EQ02	17.01 17.01	0.874 150 0.1552	1T	8.053 0.0 0.0	0.500 8.052 8.552	12.051 0.0 1.327			K Factor = 4.90 Vel = 9.10	
	0.0 17.01					13.378			K Factor = 4.65	
40 to 41	17.01 17.01	0.874 150 0.1553		0.0 0.0 0.0	10.670 0.0 10.670	12.753 0.0 1.657			K Factor @ node EQ01 Vel = 9.10	
41 to 55	17.65 34.66	0.874 150 0.5794	2E	8.053 0.0 0.0	14.250 8.052 22.302	14.410 0.0 12.922			K Factor @ node EQ02 Vel = 18.54	
	0.0 34.66					27.332			K Factor = 6.63	
42 to 43	19.72 19.72	0.874 150 0.2040		0.0 0.0 0.0	10.670 0.0 10.670	17.139 0.0 2.177			K Factor @ node EQ01 Vel = 10.55	
43 to 53	20.44 40.16	0.874 150 0.7608	1T	8.053 0.0 0.0	1.420 8.052 9.472	19.316 0.0 7.206			K Factor @ node EQ02 Vel = 21.48	
53 to 54	0.0 40.16	1.598 150 0.0402		0.0 0.0 0.0	5.790 0.0 5.790	26.522 0.0 0.233			Vel = 6.42	
54 to 55	0.0 40.16	1.598 150 0.0403	1T	11.656 0.0 0.0	2.670 11.656 14.326	26.755 0.0 0.577			Vel = 6.42	
55 to AD	34.66 74.82	1.598 150 0.1271		0.0 0.0 0.0	4.500 0.0 4.500	27.332 0.0 0.572			Vel = 11.97	
AD to TOR	0.0 74.82	1.61 120 0.1856	2E 1T	8.0 8.0 0.0	3.750 16.000 19.750	27.904 0.251 3.665			Vel = 11.79	
TOR to BOR	0.0 74.82	1.61 120 0.1855	1Z 1T	4.0 8.0 0.0	3.500 12.000 15.500	31.820 2.780 2.875			Vel = 11.79	
BOR to BFP	0.0 74.82	2.469 120 0.0231	2I	12.0 0.0 0.0	2.000 12.000 14.000	37.475 0.0 0.324			Vel = 5.01	
BFP to 6UG	0.0 74.82	2.469 120 0.0231	1I	6.0 0.0 0.0	3.000 6.000 9.000	37.799 7.468 0.208			* Fixed loss = 7 Vel = 5.01	
6UG to TEST	0.0 74.82	6.16 140 0.0002	2L 1G 1T	25.822 4.304 43.037	95.000 73.163 168.163	45.475 0.433 0.034			Vel = 0.81	

Final Calculations - Standard

Residential Fire Protection
93 SAINT LAWRENCE STREET BLDG

Page 6
Date 4/18/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0								
	74.82				45.942			K Factor = 11.04	