

**. . . Fire Protection by Computer Design**

Residential Fire Protection  
64 Daggett Hill Rd.  
Greene, ME 04236  
(207)946-343

Job Name : 93 SAINT LAWRENCE STREET BLDG  
Building : WOOD STRUCTURE  
Location : MEZZANINE  
System : 1 (WET)  
Contract : C16014  
Data File : 93 ST LAWRENCE ST- MEZZ- HYD CALC.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 93 ST. LAWRENCE STREET Date - 4/18/2016  
Location - MEZZANINE  
Building - WOOD STRUCTURE System No. - 1 (WET)  
Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C16014  
Calculated By - Drawing No. - 2 OF 2  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height VARIES  
OCCUPANCY - BEDROOM

S Type of Calculation: (X)NFPA 13 Residential ( )NFPA 13R ( )NFPA 13D  
Y Number of Sprinklers Flowing: ( )1 ( )2 (X)4 ( )  
S ( )Other  
T ( )Specific Ruling Made by Date  
E  
M Listed Flow at Start Point - 13 Gpm System Type  
Listed Pres. at Start Point - 10.6 Psi (X) Wet ( ) Dry  
D MAXIMUM LISTED SPACING 16' x 16' ( ) Deluge ( ) PreAction  
E Domestic Flow Added - Gpm Sprinkler or Nozzle  
S Additional Flow Added - Gpm Make VIKING Model VK468  
I Elevation at Highest Outlet - 130.34Feet Size 7/16" K-Factor 4.0  
G Note: Temperature Rating 155  
N

Calculation Gpm Required 33.06 Psi Required 48.58 At Test  
Summary C-Factor Used: Overhead 150 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - 4/30/2014 Rated Cap. Cap.  
T Time of Test - N/A @ Psi Elev.  
E Static (Psi) - 50 Elev.  
R Residual (Psi) - 44 Other Well  
Flow (Gpm) - 919 Proof Flow Gpm  
S Elevation - 100

P Location: TEST HYDRANT AT THE CORNER OF MONUMENT ST AND ST LAWRENCE ST,  
P SEE PLOT PLAN FOR MORE INFORMATION  
L Source of Information: PORTLAND WATER DISTRICT  
Y


# Water Supply Curve (C)

Residential Fire Protection  
93 SAINT LAWRENCE STREET BLDG

Page 2  
Date 4/18/16

City Water Supply:  
C1 - Static Pressure : 50  
C2 - Residual Pressure: 44  
C2 - Residual Flow : 919

Demand:  
D1 - Elevation : 17.597  
D2 - System Flow : 33.0579  
D2 - System Pressure : 49.017  
Hose ( Adj City ) : \_\_\_\_\_  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 33.0579  
Safety Margin : 0.970



# Fittings Used Summary

Residential Fire Protection  
93 SAINT LAWRENCE STREET BLDG

Page 3  
Date 4/18/16

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

# Pressure / Flow Summary - STANDARD

Residential Fire Protection  
93 SAINT LAWRENCE STREET BLDG

Page 4  
Date 4/18/16

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
30	140.63	4.9	10.6	na	15.95	0.0508	256	10.6
31	139.55	4.9	12.19	na	17.1	0.0508	256	10.6
50	139.55		18.72	na				
51	130.34		23.56	na				
23	130.34		24.0	na				
52	130.34		25.86	na				
54	109.08		35.99	na				
55	109.08		36.39	na				
AD	109.08		36.52	na				
TOR	108.5		37.58	na				
BOR	102.08		40.99	na				
BFP	102.08		41.06	na				
6UG	101.0		48.58	na				
TEST	100.0		49.02	na				

The maximum velocity is 11.14 and it occurs in the pipe between nodes 31 and 50

# Final Calculations - Hazen-Williams

Residential Fire Protection  
93 SAINT LAWRENCE STREET BLDG

Page 5  
Date 4/18/16

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
30 to 31	15.95 15.95	0.874 150 0.1378	1E	4.026 0.0 0.0	4.080 4.026 8.106	10.600 0.468 1.117			K Factor = 4.90 Vel = 8.53	
31 to 50	17.11 33.06	1.101 150 0.1724	4E	15.3 0.0 0.0	22.620 15.301 37.921	12.185 0.0 6.538			K Factor = 4.90 Vel = 11.14	
50 to 51	0.0 33.06	1.394 150 0.0546	1T	9.523 0.0 0.0	6.000 9.523 15.523	18.723 3.989 0.848			Vel = 6.95	
51 to 23	0.0 33.06	1.394 150 0.0546		0.0 0.0 0.0	8.000 0.0 8.000	23.560 0.0 0.437			Vel = 6.95	
23 to 52	0.0 33.06	1.394 150 0.0546	2T	19.046 0.0 0.0	15.000 19.047 34.047	23.997 0.0 1.860			Vel = 6.95	
52 to 54	0.0 33.06	1.598 150 0.0281	1T	11.656 0.0 0.0	21.210 11.656 32.866	25.857 9.208 0.923			Vel = 5.29	
54 to 55	0.0 33.06	1.598 150 0.0281	1T	11.656 0.0 0.0	2.670 11.656 14.326	35.988 0.0 0.402			Vel = 5.29	
55 to AD	0.0 33.06	1.598 150 0.0282		0.0 0.0 0.0	4.500 0.0 4.500	36.390 0.0 0.127			Vel = 5.29	
AD to TOR	0.0 33.06	1.61 120 0.0409	2E 1T	8.0 8.0 0.0	3.750 16.000 19.750	36.517 0.251 0.808			Vel = 5.21	
TOR to BOR	0.0 33.06	1.61 120 0.0410	1Z 1T	4.0 8.0 0.0	3.500 12.000 15.500	37.576 2.780 0.635			Vel = 5.21	
BOR to BFP	0.0 33.06	2.469 120 0.0051	2I	12.0 0.0 0.0	2.000 12.000 14.000	40.991 0.0 0.072			Vel = 2.22	
BFP to 6UG	0.0 33.06	2.469 120 0.0050	1I	6.0 0.0 0.0	3.000 6.000 9.000	41.063 7.468 0.045			* Fixed loss = 7 Vel = 2.22	
6UG to TEST	0.0 33.06	6.16 140 0.0	2L 1G 1T	25.822 4.304 43.037	95.000 73.163 168.163	48.576 0.433 0.008			Vel = 0.36	
	0.0 33.06					49.017			K Factor = 4.72	