
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager GEORGE JUDY D		Inspector Suzanne Hunt	Inspection Date 7/11/2008
Location 52 ATLANTIC ST	CBL 016 E008001	Status Re-Inspect 30 Days	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108.d	Exterior		2	Deck	
Violation: Stairways, stairwells, stairs and porches.					
Notes: The guardrail on 4th floor deck must be made structurally sound and safe to use.					
2) 6-108.d	Interior		2		
Violation: Stairways, stairwells, stairs and porches.					
Notes: hand rails are required to be graspable. Bring to code the handrail in unit 2 between 2nd and 3rd floor back stairs					
3) 6-116.	Interior			Hallway	
Violation: Minimum standards for safety.					
Notes: Every dwelling unit and every rooming unit shall have safe, unobstructed means of egress.					

Comments: