Inspections Division
Date: 01/13/15

30 Monument Street
NFPA Code Review

NFPA 101 2009

Chapter 24 Residential
New Structure to be equipped with automatic sprinkler system
Second means of egress provided at bedrooms with egress windows
Smoke alarms shall be installed in all sleeping rooms, outside of each sleeping area, and on each level of the dwelling including the basement