



NOTE: STAIR SHAFT TO BE 1 HR. FIRE RATED SEPARATION FROM FIRST FLOOR TO ROOF. ALL RATINGS INDICATED ARE FOR OCCUPANCY AND EGRESS PATH RATING REQUIREMENTS.


1 THIRD FLOOR LIFE SAFETY PLAN
NOT TO SCALE




2 SECOND FLOOR LIFE SAFETY PLAN
NOT TO SCALE




3 FIRST FLOOR LIFE SAFETY PLAN
NOT TO SCALE




4 BASEMENT LIFE SAFETY FLOOR PLAN
NOT TO SCALE



5 STAIR SECTIONS
NOT TO SCALE



1 DETAIL LESS THAN 2 1/2" PVC PIPE PENETRATION
SCALE: 3" = 1'-0"



2 DETAIL FOR 2 1/2" AND LARGER PVC PIPE PENETRATION
SCALE: 3" = 1'-0"

FIRE STOPPING SPECIFICATIONS:

WRAP STRIP: 1/4" THICK x 1 1/2" MINIMUM WIDTH INTUMESCENT MATERIAL WITH PLASTIC FILM FACING BOTH SIDES. TEMPORARILY SECURE WITH MASKING TAPE. SPECIFIED TECHNOLOGIES INC. (STW) "SpecSeal" RED WRAP STRIP OR "SpecSeal" BLU WRAP STRIP OR EQUAL.

FIRESTOP DEVICE: IN LIEU OF THE WRAP STRIP AND STEEL COLLAR, A FIRESTOP DEVICE MAY BE USED AS FOLLOWS:
a. FOR 3" PVC PIPE (3 1/2" O.D.) USE "SpecSeal" LCC COLLAR #LCC300
b. FOR 4" PVC PIPE (4 1/2" O.D.) USE "SpecSeal" LCC COLLAR #LCC400
c. DO NOT USE FIRESTOP DEVICE AT JOINTS (JOINT FLANGES) IN PIPE. PROVIDE WRAP STRIP AND STEEL COLLAR.

STEEL COLLAR: WRAP STRIP MANUFACTURER'S STEEL COLLAR, FABRICATED FROM 3/16" THICK GALVANIZED SHEET STEEL, WIDTH TO MATCH WRAP STRIP (1 1/2" MINIMUM) WITH 1/2" x 2" ANCHOR TABS AND RETAINER TABS. ANCHOR TABS TO BE SYMMETRICALLY OPPOSED AROUND COLLAR. PROVIDE 3 #8 x 3/8" AND 3" PIPE, PROVIDE 4 TABS FOR 4" PIPE.

INTUMESCENT SEALANT: ONE PART, INTUMESCENT, LATEX ELASTOMER TESTED TO ASTM E 814. MINIMUM EXPANSION OF 3x AT 1000°F. 3M "FIRE BARRIER SEALANT CP 25" OR EQUAL.

FIRESTOP SEALANT: SINGLE COMPONENT NONCOMBUSTIBLE FIRE RATED SEALANT TESTED TO ASTM E 814. TESTED TO 3000°F. "BOSS 136" FIRESTOP/DRAIN SEALANT" MANUFACTURED BY ACCUMETRIC, LLC, OR EQUAL.

SEALANT SCHEDULE:

INTUMESCENT SEALANT: PROVIDE AT ALL PENETRATIONS THROUGH RATED CONSTRUCTION FOR PENETRATING ITEMS INCLUDING BUT NOT LIMITED TO: PVC PIPE, ROOF LEADER PIPES, GAS PIPES & LINES, SPRINKLER PIPES, ELECTRICAL & COMMUNICATIONS CABLES & WIRES, AND ALARM SYSTEM WIRES. DO NOT USE INTUMESCENT SEALANT AT DOMESTIC HOT WATER OR HYDRONIC HEATING SYSTEM PIPES.

FIRESTOP SEALANT: PROVIDE AT ALL PENETRATIONS THROUGH RATED CONSTRUCTION FOR PENETRATING ITEMS INCLUDING DOMESTIC HOT AND COLD WATER PIPES AND HYDRONIC HEATING SYSTEM PIPES.

Applicable Codes:
IBC, 2009 Edition; NFPA 101, 2009 Edition, 2009 Maine Uniform Energy & Building Code

Construction Type:
Type V(B) Construction. Floor, walls, and roof framing are of wood materials. (IBC 602.5)
Type V(000) Construction. (NFPA)

Allowable Area:
As per IBC, Table 503, a R-2 use of Type V(B) construction has an allowable area of 7,000 SF and a maximum allowable height of 3 stories. (additional 3rd story permitted as per Table 504.2 due to approved automatic sprinkler system)

Fire Rating of Building Elements (IBC Table 60, NFPA A.8.2.1.2):

Structural Frame:	0 hours
Floor Construction:	0 hours
Bearing Walls [Interior]:	0 hours
Bearing Walls [Exterior]:	0 hours
Roof:	0 hours

Fire Resistance Rating of Exterior Wall Based on Fire Separation Distance (IBC Table 602)

Walls [Exterior Perpendicular to Lot Line]:	1 hour
Openings:	None Permitted (IBC 704.8). Existing openings to remain with no increase in size)

Existing North Wall at 1st and 2nd Floors – 5/8" GWB interior, no change to exterior
New North Wall at 3rd Floor – 5/8" GWB interior and exterior (IBC 705.5)

Means of Egress Components

Residential Use, Occupancy calculation based on IBC Table 1004.1.1, NFPA Table 7.3.1.2.	
Floor 1 - 200 sqft gross floor area / occupant. Gross sqft = 960	Occupancy = 5
Floor 2 - 200 sqft gross floor area / occupant. Gross sqft = 960	Occupancy = 5
Floor 3 - 200 sqft gross floor area / occupant. Gross sqft = 894	Occupancy = 5
Basement - Mechanical only	Occupancy = 0

One enclosed fire stair extends from the 3rd floor to exit discharge at the 1st floor. Total travel distance within the units to entering the exit stairway enclosure does not exceed 50 ft. Building up to (5) stories in height allowed a single exit in accordance with IBC Table 1021.2. (NFPA 31.2.4.4)

Maximum Travel Distance with (1) means of egress per unit is 50' (IBC 1021.2) Maximum 35' travel from apartment door to an exit. Maximum travel distance within unit 125'. From unit door to exit 200' (NFPA 31.2.4.4, Table A31.1) All travel distances within the building comply with the above requirements. See Life Safety Plan for travel distances within the building.

Fire Rating – 0.5 hr in exit corridors, 1 hr in stairway enclosure (IBC 1022.1, IBC Table 1018.1) (NFPA 31.2.4.4)

Fire Doors – 1 hr rating with self closing hinges (IBC Table 715.4) (NFPA 31.2.4.4)

Fire Separation Between Units – 1 hr (IBC Table 508.4, 508.3.3) 1/2 hr NFPA. (NFPA 31.2.4.4)

Arrangement of Means of Egress:

This is an existing building and is therefore exempt from the 1/2 diagonal measurement separation criteria of NFPA 7.5.1.3.2, [see NFPA 7.5.1.3.3].

Means of Escape:

This building is equipped with an approved automatic sprinkler system and is required to provide a secondary means of escape within each bedroom as per IBC Table 1021.2 (IBC 1029.1), (Not required as per NFPA 31.2.1.2) Secondary means of escape to be provided and conform to IBC 1029.

Portable Fire Extinguishers:

This building is equipped with an approved automatic sprinkler system and is therefore exempt from requiring portable fire extinguishers. (NFPA 31.3.5) Nonetheless, (1) portable fire extinguisher is being provided per unit.

Emergency Lighting:

This building is not required to provide emergency lighting along the egress path being less than 4 stories in height and fewer than 12 units. (NFPA 31.2.9) (IBC 1006.3)

Exit Signs:

This building is only required to have one exit, and thus is not required to have Exit signs. (NFPA 31.2.10) (IBC 1011.1)

Dimensional Criteria of Stairs:

Width of Egress Path = min 36" (IBC 1009.1) exceeds at 38" (NFPA 7.2.2.2.1.2 (B))
Headroom along Egress Path = min 80" (IBC 1009.2) (NFPA 7.2.2.3.2.3)
Stair Rise/Run = max 7" rise, 11" run. (IBC 1009.4) (NFPA 7.2.2.2.1.2 (B))
Landings min 36" x 36" (IBC 1009.5) (NFPA 7.2.2.3.2.3)
Handrails – (IBC 1009.12) (NFPA 7.2.2.4.1.1)
Basement Stair - (IBC 34.04.1) The existing basement stairs are unsafe and highly non conforming with a 9" rise and a 8" tread. The new basement stairs have a 7 1/4" rise and a 10" tread, bringing them closer to conformance.

Accessibility

Accessibility is not required as an alteration to an existing building. (IBC 1007.1) (NFPA 7.5.4.1)

Acoustics

(IBC 1207.2 & 3) Walls, partitions, doors between dwelling units or dwelling units and common areas STC < 50. Ceilings – resilient channel at underside of joists + 5/8" Type X GWB. Walls - one (quiet) side = 5/8" Type X GWB; other (noisy) side = resilient channel with (2) 5/8" Type X GWB.

Interior Finishes

As per section NFPA 10.2. Typ. Interior finishes GWB ceilings and walls, hardwood floor throughout.


2009 Uniform Energy Code Summary

Insulation Levels:	
Basement Walls –	R-15 continuous closed cell sprayfoam insulation. Foam protected by an approved thermal barrier such as 1/2" GWB or equal (IBC 2603.4)
Crawlspace Walls -	R-10 continuous closed cell sprayfoam insulation
Wood Framed Walls Above Grade –	R-24 closed cell sprayfoam insulation
Ceiling –	R-38 closed cell sprayfoam insulation
Skylight –	0.60 U Factor Max
Windows -	0.35 U Factor Max
Doors -	0.55 U Factor Max

Lachman
Architects & Planners

Architecture
Planning
Preservation

165 State Street
Portland, Maine 04101
207-773-3811



ALTERATIONS TO
52 MONUMENT STREET
PORTLAND, MAINE

TITLE:
LIFE SAFETY PLANS
AND CODE REVIEW
SUMMARY

DATE:
ORIGINAL: 11/5/13
REVISION 1:
REVISION 2:
REVISION 3:
ISSUED FOR:
BUILDING PERMIT SET

DRAWING NO:

G2