

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND

BUILDING PERMIT

This is to certify that
DEAN & ALLYN, INC.
PO BOX 709 - 116 LEWISTON RD
GRAY, ME 04039

For installation at
4 ST LAWRENCE ST
TWO-FAMILY

Job ID: 2012-08-4603-FAFS

CBL: 016- J-012-001

has permission to install NFPA 13D sprinkler system

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be

Bjornberg (58)

Fire Prevention Officer

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
PENALTY FOR REMOVING THIS CARD

BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

Final Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.



PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life • www.portlandmaine.gov

Director of Planning and Urban Development
Jeff Levine

Job ID: 2012-08-4603-FAFS
install NFPA 13D sprinkler system

For installation at:
4 ST LAWRENCE ST
TWO-FAMILY

CBL: 016- J-012-001

Conditions of Approval:

Fire

1. The sprinkler system shall be installed in accordance with NFPA 13D. A compliance letter is required.
2. All control valves shall be supervised in accordance with NFPA 13D. Pad locks shall only be installed on valves designed to be secured in the open position by pad lock.
3. Application requires State Fire Marshal approval.



Fire Suppression System Permit

R-y Entered 8/2/12

(B)

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

2012-08-4603-FAFS

By mail

Installation address: 4 St. Lawrence St CBL: 016 JO12

Exact location: (within structure) complete buildings

Type of occupancy(s) (NFPA & ICC): _____

Building owners: John & Mary Macomber 80 Fessenden 04103

Managing Supervisor: DANA Stewart License No: NICET IV 064544

Supervisor phone: _____ E-mail: _____

Installing contractor: _____ License No: _____

Contractor phone: 233 9105 E-mail: hking@Maine.rr.com

The suppression work to be done will be: New: Renovation: Addition to existing system:

This is an amendment to an existing permit: Yes: NO Permit no: _____

NFPA Standard will this system is designed to: 13D Edition: 2010

*Non-NFPA systems are not approved for use within the City of Portland.

Attach all design information and complete approved submittals as may be required by the State Fire Marshal's Office.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

\$ 15000
 COST OF WORK: 15000
\$ 170.00
 PERMIT FEE: 170.00
 (\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)
 RECEIVED
 AUG 01 2012
Resident

Download a new copy of this document from www.portlandmaine.gov for every submitted permit application to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

Applicant signature: Harry King Date: 7-31-12

*Harry King
Dean and Allyn INC
PO Box 709
GRAY Maine*



... Fire Protection by Computer Design

DEAN & ALLYN, INC.
PO BOX 709
116 LEWISTON ROAD
GRAY, MAINE 04039
207-657-5646

Job Name : 4 ST LAWRENCE ST
Building :
Location : 4 ST LAWRENCE STREET PORTLAND MAINE
System :
Contract : 121094
Data File : ST LAWRENCE ST.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 4 ST LAWRENCE STREET Date - 7-21-12
Location - 4 ST LAWRENCE STREET PORTLAND MAINE
Building - System No. -
Contractor - DEAN AND ALLYN INC Contract No. - 121094
Calculated By - H KING Drawing No. - 1 OF 1
Construction: (X) Combustible () Non-Combustible Ceiling Height VARIES
OCCUPANCY - RESIDENTIAL

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 10.6 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - 5 Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make VIKING Model FREEDOM
I Elevation at Highest Outlet - 33' Feet Size 1/2" K-Factor 4.0
G Note:CUSHION: 13.24 PSI Temperature Rating 155
N

Calculation Gpm Required 31.3 Psi Required 69.7 At Test
Summary C-Factor Used: Overhead 120 Underground 120

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 8-9-11 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 83 Elev.
R Residual (Psi) - 20 Other Well
Flow (Gpm) - 1233 Proof Flow Gpm
S Elevation - 0

P Location: FEDERAL STREET
P
L Source of Information: PWD
Y

Fittings Used Summary

DEAN & ALLYN, INC.
4 ST LAWRENCE ST

Page 2
Date 7-21-12

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Abbrev.	Name																					
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.
4 ST LAWRENCE ST

Page 3
Date 7-21-12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	33.0	4	10.6	na	13.02	0.05	256	10.6
2	33.0	4	11.02	na	13.28	0.05	256	10.6
10	21.0		16.92	na				
11	21.0		17.33	na				
12	21.0		17.37	na				
13	21.0		17.8	na				
14	10.0		29.69	na				
15	10.0		32.28	na				
16	10.0		34.72	na				
17	10.0		37.31	na				
18	0.0		44.56	na				
TR	0.0		50.17	na				
FF	-6.0		55.79	na	5.0			
CTY	0.0		69.69	na				

The maximum velocity is 12.17 and it occurs in the pipe between nodes FF and CTY

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1	13.02	1.049	1T	5.0	12.000	10.600			K Factor = 4.00	
to		120.0	1E	2.0	7.000	5.197				
10	13.02	0.0588		0.0	19.000	1.118			Vel = 4.83	
	0.0									
	13.02					16.915			K Factor = 3.17	
2	13.28	1.049	1T	5.0	12.000	11.015			K Factor = 4.00	
to		120.0	1E	2.0	7.000	5.197				
12	13.28	0.0610		0.0	19.000	1.159			Vel = 4.93	
	0.0									
	13.28					17.371			K Factor = 3.19	
10	13.02	1.049	1T	5.0	2.000	16.915				
to		120.0		0.0	5.000	0.0				
11	13.02	0.0589		0.0	7.000	0.412			Vel = 4.83	
11	0.0	1.049		0.0	8.000	17.327				
to		120.0		0.0	0.0	0.0				
13	13.02	0.0589		0.0	8.000	0.471			Vel = 4.83	
	0.0									
	13.02					17.798			K Factor = 3.09	
12	13.28	1.049	1T	5.0	2.000	17.371				
to		120.0		0.0	5.000	0.0				
13	13.28	0.0610		0.0	7.000	0.427			Vel = 4.93	
13	13.02	1.049	3E	6.0	17.000	17.798				
to		120.0	2T	10.0	16.000	4.764				
14	26.3	0.2159		0.0	33.000	7.126			Vel = 9.76	
14	0.0	1.049	1E	2.0	10.000	29.688				
to		120.0		0.0	2.000	0.0				
15	26.3	0.2160		0.0	12.000	2.592			Vel = 9.76	
15	0.0	1.049	2T	10.0	1.300	32.280				
to		120.0		0.0	10.000	0.0				
16	26.3	0.2159		0.0	11.300	2.440			Vel = 9.76	
16	0.0	1.049	1T	5.0	5.000	34.720				
to		120.0	1E	2.0	7.000	0.0				
17	26.3	0.2160		0.0	12.000	2.592			Vel = 9.76	
17	0.0	1.049	1E	2.0	11.500	37.312				
to		120.0		0.0	2.000	4.331				
18	26.3	0.2159		0.0	13.500	2.915			Vel = 9.76	
18	0.0	1.049	2E	4.0	12.000	44.558				
to		120.0	2T	10.0	14.000	0.0				
TR	26.3	0.2160		0.0	26.000	5.615			Vel = 9.76	
TR	0.0	1.049	1S	5.0	7.000	50.173				
to		120.0	1Z	0.0	5.000	2.599				
FF	26.3	0.2519		0.0	12.000	3.023			Vel = 9.76	

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
4 ST LAWRENCE ST

Page 5
Date 7-21-12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
FF to CTY	5.00 31.3	1.025 120.0 0.3424	2E 3.574 1G 0.0 0.0	30.000 3.574 33.574	55.795 2.401 11.496		Qa = 5 * Fixed loss = 5 Vel = 12.17
	0.0 31.30				69.692		K Factor = 3.75

Water Supply Curve (C)

DEAN & ALLYN, INC.
4 ST LAWRENCE ST

Page 6
Date 7-21-12

City Water Supply:
C1 - Static Pressure : 83
C2 - Residual Pressure: 20
C2 - Residual Flow : 1233

Demand:
D1 - Elevation : 14.292
D2 - System Flow : 26.299
D2 - System Pressure : 69.692
Hose (Demand) : 5
D3 - System Demand : 31.299
Safety Margin : 13.237

