

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 25 Fore Street		Owner: *** Casco Bay Ventures		Phone: ***797-7752		Permit No: 001199	
Owner Address: 223 Woodville Rd. Falmouth, ME 04105		Lessee/Buyer's Name:		Phone:		BusinessName:	
Contractor Name:		Address:		Phone:		Permit Issued:	
Past Use: Commercial Residential 3 D.U.-legal		Proposed Use: Commercial Residential 3 DU		COST OF WORK: \$ 6,000.00		PERMIT FEE: \$60.00	
Proposed Project Description: 3 sun decks with 5' sliding doors on a 3 unit building		Signature: <i>[Signature]</i>		FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group 102 Type: 53 BOCA 99 Signature: <i>[Signature]</i>	
				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/> Signature: _____ Date: _____			
Permit Taken By: Gayle		Date Applied For: October 11, 2000 GG					

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

October 11, 2000

SIGNATURE OF APPLICANT _____ ADDRESS: _____ DATE: _____ PHONE: _____

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE _____ PHONE: _____

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

**PERMIT ISSUED
WITH REQUIREMENTS**

Zone: **R-2** CBL: 016-J-013
Zoning Approval: **3 units of per 1955 Dir.**
Special Zone or Reviews:
☐ Shoreland ☒ Wetland ☒ Flood Zone ☐ Subdivision ☐ Site Plan major ☐ minor ☐ mm ☐
Zoning Appeal
☐ Variance ☐ Miscellaneous ☐ Conditional Use ☐ Interpretation ☐ Approved ☐ Denied

Historic Preservation
☒ Not in District or Landmark ☐ Does Not Require Review ☐ Requires Review

Action:
☐ Approved ☒ Approved with Conditions ☐ Denied

Date: *[Signature]*

**PERMIT ISSUED
WITH REQUIREMENTS
CBO DISTRICT**

1

COMMENTS

10-27-2K: MET w/owner & MEASURED SET BACK @ 10'. EXPLAINED IMPORTANCE OF DECK NOT INFRINGING INTO SET-BACK. CHECKED DEPTH OF TUBES @ 4'. INSTRUCTED OWNER THAT A PERMIT "IS" REQUIRED FOR ANY STRUCTURAL CHANGES TO BLDG. ELECTRICAL & PLUMBING PERMITS WILL ALSO BE REQUIRED FOR 1ST FL. REMODELING & BEAM IN BASEMENT. AKW

11-6-2K: Measured set back to Abutter & found to be 10' 1 1/2" to West house wall. AKW

11-8-2K: Returned to re measure set back - Owner has surveyor plan showing property line @ wall of abutting house. AKW

3/16/00 - Spoke to owner of Casco Bay Ventures (Lutaly Gear) and explained that a change of use permit must be obtained to convert Apartments to Condo's - Mr Gear said he was told that that is applied for after the building permits requirements have been met - I informed him he should apply for change of use immediately - he said he will be in today to apply for change of use permit.

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____

**THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE
PERMIT IS ISSUED**

**Building or Use Permit Pre-Application
Attached Single Family Dwellings/Two-Family Dwelling
Multi-Family or Commercial Structures and Additions Thereto**

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTEIf you or the property owner owes real estate or personal property taxes or user charges on ANY PROPERTY within the City, payment arrangements must be made before permits of any kind are accepted.**

Location/Address of Construction (include Portion of Building): <u>25 Fore St</u>			
Total Square Footage of Proposed Structure <u>3 Decks 70 Sq Each</u>		Square Footage of Lot	
Tax Assessor's Chart, Block & Lot Number Chart# <u>016</u> Block# <u>223</u> Lot# <u>013</u>		Owner: <u>Casco Bay Ventures</u>	Telephone#: <u>207-7977752</u>
Owner's Address: <u>223 Woodville Rd Falmouth Me 04105</u>		Lessee/Buyer's Name (If Applicable) <u>Same</u>	Cost Of Work: <u>\$6000</u> Fee: <u>\$60.00</u>
Proposed Project Description: (Please be as specific as possible) <u>to Build three Sun Decks with 5' sliding doors on a three unit Building</u>			
Contractor's Name, Address & Telephone <u>Same</u>			Rec'd By: <u>Wally</u>
Current Use: <u>Commercial</u>		Proposed Use: <u>Commercial</u>	

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

- All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.
- All plumbing must be conducted in compliance with the State of Maine Plumbing Code.
- All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.
- HVAC (Heating, Ventilation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.

You must Include the following with your application:

- 1) A Copy of Your Deed or Purchase and Sale Agreement
- 2) A Copy of your Construction Contract, if available
- 3) A Plot Plan/Site Plan

Minor or Major site plan review will be required for the above proposed projects. The attached checklist outlines the minimum standards for a site plan.

4) Building Plans

Unless exempted by State Law, construction documents must be designed by a registered design professional.

A complete set of construction drawings showing all of the following elements of construction:

- Cross Sections w/Framing details (including porches, decks w/railings, and accessory structures)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

Certification


I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant: <u>Wally Geyer</u>	Date: <u>10-10-00</u>
--	-----------------------

Building Permit Fee: \$30.00 for the 1st \$1000. cost plus \$6.00 per \$1,000.00 construction cost thereafter.

Additional Site review and related fees are attached on a separate addendum

* IF Available also
Submit Plans on
ADOBE or CAD Form



BUILDING PERMIT REPORT

DATE: 12 OCT. 2000 ADDRESS: 25 Fore St. CBL: 016-J-013
REASON FOR PERMIT: 3 decks with 5' sliding doors on 3 unit dwelt.
BUILDING OWNER: Caso Bay Ventures
PERMIT APPLICANT: CONTRACTOR owner
USE GROUP: R-2 CONSTRUCTION TYPE: 5B CONSTRUCTION COST: \$6,000.00 PERMIT FEES: \$60.00

The City's Adopted Building Code (The BOCA National Building Code/1999 with City Amendments)
The City's Adopted Mechanical Code (The BOCA National Mechanical Code/1993)

CONDITION(S) OF APPROVAL

This permit is being issued with the understanding that the following conditions shall be met: *1, *2, *11, *29, *32, *34, *36, *37, #3

- X 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
- X 2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection) "ALL LOT LINES SHALL BE CLEARLY MARKED BEFORE CALLING."
3. Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2
4. Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6" O.C. between bolts. Section 2305.17
5. Waterproofing and dampproofing shall be done in accordance with Section 1813.0 of the building code.
6. Precaution must be taken to protect concrete from freezing. Section 1908.0
7. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
8. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4, Section 407.0 of the BOCA/1999)
9. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211
- X 10. Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building Code.
- X 11. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42". In occupancies in Use Group A, B, H-4, I-1, I-2, M, R, public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. Handrails shall be a minimum of 34" but not more than 38". Exception: Handrails that form part of a guard shall have a height not less than 36 inches (914 mm) and not more than 42 inches (1067 mm). Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0). Handrails shall be on both sides of stairway. (Section 1014.7)
12. Headroom in habitable space is a minimum of 7'6". (Section 1204.0)
13. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 1/2" maximum rise. All other Use Group minimum 11" tread, 7" maximum rise. (Section 1014.0)
14. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6'8") 1014.4
15. Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508)mm, and a minimum net clear opening of 5.7 sq. ft. (Section 1010.4)
16. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. (Section 1010.1)
17. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closure's. (Over 3 stories in height requirements for fire rating is two (2) hours. (Section 710.0)
18. The boiler shall be protected by enclosing with (1) hour fire rated construction including fire doors and ceiling, or by providing automatic extinguishment. (Table 302.1.1)

10/11

19. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1999), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):

- In the immediate vicinity of bedrooms
- In all bedrooms
- In each story within a dwelling unit, including basements

20. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. (Section 921.0)

21. The Fire Alarm System shall be installed and maintained to NFPA #72 Standard.

22. The Sprinkler System shall be installed and maintained to NFPA #13 Standard.

23. All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023.0 & 1024.0 of the City's Building Code. (The BOCA National Building Code/1999)

24. Section 25 - 135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".

25. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification the Division of Inspection Services.

26. Ventilation and access shall meet the requirements of Chapter 12 Sections 1210.0 and 1211.0 of the City's Building Code. (Crawl spaces & attics).

27. All electrical, plumbing and HVAC permits must be obtained by Master Licensed holders of their trade. No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.

28. All requirements must be met before a final Certificate of Occupancy is issued.

X 29. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code (The BOCA National Building Code/1996).

30. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical code (The BOCA National Mechanical Code/1993). (Chapter M-16)

31. Please read and implement the attached Land Use Zoning report requirements. *SHALL REMAIN 3 D.U. THIS IS NOT AN ALLOWANCE TO INCREASE THE NUMBER OF UNITS*

X 32. Boring, cutting and notching shall be done in accordance with Sections 2305.3, 2305.3.1, 2305.4.4 and 2305.5.1 of the City's Building Code.

X 33. Bridging shall comply with Section 2305.16.

X 34. Glass and glazing shall meet the requirements of Chapter 24 of the building code. (Safety Glazing Section 2406.0)

X 35. All signage, shall be done in accordance with Section 3102.0 signs of the City's Building Code, (The BOCA National Building Code/1999).

X 36. All flashing shall comply with Section 1406.3.10.

X 37. Fasteners shall be used between Footing & Sono Tube and Pier and Column and Column and deck Framing.

P. Samuel Hoffses, Building Inspector

Lt. McDougall, PFD

Marge Schrauckal, Zoning Administrator

PSH 10/1/00

****This permit is herewith issued, on the basis of plans submitted and conditions placed on these plans, any deviations shall require a separate approval.**

****THIS PERMIT HAS BEEN ISSUED WITH THE UNDERSTANDING THAT ALL THE CONDITIONS OF THE APPROVAL SHALL BE COMPLETED. THEREFORE, BEFORE THE WORK IS COMPLETED A REVISED PLAN OR STATEMENT FROM THE PERMIT HOLDER SHALL BE SUBMITTED TO THIS OFFICE SHOWING OR EXPLAINING THAT THE CONDITIONS HAVE BEEN MET. IF THIS REQUIREMENT IS NOT RECEIVED YOUR CERTIFICATE OF OCCUPANCY SHALL BE WITHHELD.**

******ALL PLANS THAT REQUIRE A PROFESSIONAL DESIGNER'S SEAL, (AS PER SECTION 114.0 OF THE BUILDING CODE) SHALL ALSO BE PRESENTED TO THIS DIVISION ON AUTO CAD LT. 2000, DXF FORMAT OR EQUIVALENT.**


*******CERTIFICATE OF OCCUPANCY FEE \$50.00**

CBL 016-J-13

STREET ADDRESS

25 Fore Street

[illegible]



R-6

Sides: 10' req - 10' shown
REAR: 20' req - 20' shown
front: 10' Normally req.
but an Average on each side
6' is shown

This house is on the sidewalk

house is on the sidewalk

This house is on the sidewalk

38'

Hi,
CAN WE
TALK ABOUT
THIS?
anyway

Lot
4216
13


109'

R-6

House

Side! 10' req - 10.5' shown
'EAT': 20' req - 20' shown
'Front': 10' Normally req.
but on Average on each side
6' is shown -

This
house is on
the sidewalk



house is on the
sidewalk

This house
is on the
sidewalk


25 Fore St

12-8-2K


Measure to Tackon

Survey Plan by J
BACK BY [unclear] VC
[unclear] [unclear]

Shows [unclear] [unclear] [unclear]




22
17.5



16 J-13

N/F
JOHN S DAVIS
12.731/383
287/301



(F)

15
5048

16
5000

17
4796

18
4015

19
3656

20
4770

24
5890

22
2680

23
3444

STREET

8964
5

4749
6

4055
7

3505
8

2847
9

1560
10

1515
11

2956
12

20
2277

21
2935

22
2431

23
2800

24
3322

25
1590

26
4180

13
4216

40+

STREET

SHEET 17-A

FORE

SHEET 18-A

STRE

REAL ESTATE
CLOSINGS

1099-S INPUT FORM

SALE
ESCROW

☐

EXCHANGE
ESCROW

☐

TERRY N. SNOW, P.A.
294 MAIN ST. PO BOX 275 (FILER)
CUMBERLAND, ME 04021

BUYER(S)

Casco Bay Ventures

FILER'S FID: 01-0370028

4. ACTUAL CLOSING DATE 10/06/00

SUBJECT PROPERTY INFORMATION:

Principal Residence ()
Other Real Estate (x)
(Check one)

25-27 Fore Street & 7-11 Waterville Street

STREET ADDRESS OR BRIEF FORM OF LEGAL DESCRIPTION

Portland, Maine

CITY

STATE

ZIP

6. INDICATE HERE WITH AN X IF THE GROSS PROCEEDS CANNOT BE
DETERMINED WITH CERTAINTY (ONLY IN CONTINGENT TRANSACTIONS)

☐

7. CONTRACT SALE PRICE ~~(ENTER IN DOLLARS AND CENTS)~~ \$ 490,000.00

(IF THIS IS AN EXCHANGE, PROVIDE IN THE SPACE ABOVE THE TOTAL DOLLAR
VALUE OF CASH, NOTES AND DEBT RELIEF RECEIVED BY THIS EXCHANGER.)

8. INDICATE HERE WITH AN X THAT OTHER PROPERTY OR SERVICES WERE
RECEIVED OR ARE TO BE RECEIVED

☐

9. NO. OF 1099-S FORMS TO BE PRODUCED FOR THE SALE OF THIS PROPERTY: 1

10. IF MORE THAN ONE SELLER: DOLLAR AMOUNT TO BE REPORTED
BASED ON SELLERS DECLARATION: \$

10A. Real Estate Tax Charged to Buyer at Closing: \$ 832.76

11. SELLER INFORMATION:

YOU ARE REQUIRED BY LAW TO PROVIDE YOUR CLOSING AGENT WITH YOUR CORRECT TAXPAYER IDENTIFICATION NUMBER. IF
YOU DO NOT PROVIDE YOUR CLOSING AGENT WITH YOUR CORRECT TAXPAYER IDENTIFICATION NUMBER, YOU MAY BE SUBJECT
TO CIVIL OR CRIMINAL PENALTIES IMPOSED BY LAW UNDER THE TAX REFORM ACT OF 1986, UNDER INTERNAL REVENUE CODE
SECTIONS 6045(E), 6678, 6722, 6723, AND 7203.

Estate of John J. Davis

c/o Lawrence P. Davis, Co-Personal Representative

LAST NAME

FIRST NAME

MI

127 Lester Drive

FORWARDING STREET ADDRESS

TELEPHONE NO.

Portland, ME 04103

CITY

STATE

ZIP CODE OR COUNTRY

01-6157784

SOCIAL SECURITY NUMBER

OR

TAX IDENTIFICATION NUMBER

CERTIFICATION: UNDER PENALTIES OF PERJURY, I CERTIFY THAT THE NUMBER SHOWN ON THIS STATEMENT IS MY
CORRECT TAXPAYER IDENTIFICATION NUMBER.

Lawrence P. Davis, Co-Personal Representative 10/06/00
Marie Davis Sweatt, Co-Personal Representative

SELLERS SIGNATURE

DATE SIGNED



CITY OF PORTLAND, MAINE

Department of Building Inspection

11 2011

Received from Barbara J. - a fee

of 15 /100 Dollars \$ 15.00

for permit to install
erect
alter

at 45 Tuck St move
demolish Est. Cost \$ 6,000

City # 1004
City # 5013

Inspector of buildings
Per [Signature]

THIS IS NOT A PERMIT

No work is to be started until PERMIT CARD is actually posted upon the premises. Acceptance of fee is no guarantee that permit will be granted. PRESERVE THIS RECEIPT. In case permit cannot be granted the amount of the fee will be refunded upon return of the receipt less \$5.00 or 10% whichever is greater.

WHITE - Applicant's Copy
YELLOW - Office Copy
PINK - Auditors Copy