

Life Safety Fire Protection  
Fire Sprinklers Save Lives  
97 Lower Jaffrey Road - Dublin NH

H Y D R A U L I C C A L C U L A T I O N S

C O V E R S H E E T

31 Fore Street

W A T E R S U P P L Y

STATIC PRESSURE (psi) 81  
RESIDUAL PRESSURE (psi) 70  
RESIDUAL FLOW (gpm) 1125

B O O S T E R P U M P S

NUMBER OF BOOSTER PUMPS 0

S P R I N K L E R S

MINIMUM FLOW PER SPRINKLER (gpm) 13  
MINIMUM PRESSURE PER SPRINKLER (psi) 7.04


THIS SYSTEM OPERATES AT A FLOW OF 0.00 gpm AT A PRESSURE OF 0.00 psi  
AT THE BASE OF THE RISER (REF. PT. 0)

PIPES USED FOR THIS SYSTEM

=====

111 DUCTILE IRON (350)  
002 SCHEDULE 10  
001 SCHEDULE 40  
009 BLAZEMASTER CPVC

Jeffrey G. Denis  
NICET Level 3  
Certification Number 89807



~~~~~  
SYSTEM ANALYSIS TO SHOW MAXIMUM FLOW  
WITH ZERO PRESSURE REMAINING  
~~~~~

THE FOLLOWING SPRINKLERS ARE OPERATING IN:

TEST AREA 1     TEST AREA 2     TEST AREA 3     REMOTE AREA

Elevation of sprinklers = Elevation above water test.

REF. PT.	K	ELEV. ft	FLOW gpm	PRESSURE psi
50	4.90	39.00	18.53	14.29
51	4.90	39.00	17.99	13.47
52	4.90	39.00	17.04	12.09
53	4.90	39.00	16.62	11.50

THE SPRINKLER SYSTEM FLOW IS 70.17 gpm

THE OUTSIDE HOSE FLOW AT REFERENCE POINT NO. 1 IS 0.00 gpm

THE INSIDE HOSE                     RACK SPKLR'S.  
 YARD HYDT. FLOW                    IS                    0.00 gpm

THE FOLLOWING PRESSURES & FLOWS OCCUR  
---> AT REF. PT. 1 <---

STATIC PRESSURE	81.00 psi	
RESIDUAL PRESSURE	70.00 psi	AT 1125.00 gpm
TOTAL SYSTEM FLOW	70.17 gpm	
AVAILABLE PRESSURE	80.94 psi	AT 70.17 gpm
OPERATING PRESSURE	80.94 psi	AT 70.17 gpm
PRESSURE REMAINING	0.00 psi	

THE ABOVE RESULTS INCLUDE 14.00 psi FRICTION LOSS AT REF. PT. # 2 FOR A

BACKFLOW PREVENTER                     METER  
 DETECTOR CHECK VALVE                     OTHER DEVICE

~~~~~  
HYDRAULIC CALCULATIONS AT SPECIFIED FLOW  
~~~~~

THE FOLLOWING SPRINKLERS ARE OPERATING IN:

TEST AREA 1       TEST AREA 2       TEST AREA 3       REMOTE AREA

Elevation of sprinklers = Elevation above water test.

REF. PT.	K	ELEV. ft	FLOW gpm	PRESSURE psi
50	4.90	39.00	14.53	8.79
51	4.90	39.00	14.09	8.26
52	4.90	39.00	13.32	7.39
53	4.90	39.00	13.00	7.04

THE SPRINKLER SYSTEM FLOW IS 54.93 gpm

THE OUTSIDE HOSE FLOW AT REFERENCE POINT NO. 1 IS 0.00 gpm

THE INSIDE HOSE       RACK SPKLR'S.      IS 0.00 gpm  
 YARD HYDT. FLOW

THE FOLLOWING PRESSURES & FLOWS OCCUR  
----> AT REF. PT. 1 <----

STATIC PRESSURE                      81.00 psi  
RESIDUAL PRESSURE                     70.00 psi                      AT 1125.00 gpm  
TOTAL SYSTEM FLOW                     54.93 gpm  
AVAILABLE PRESSURE                    80.96 psi                      AT 54.93 gpm  
OPERATING PRESSURE                    62.42 psi                      AT 54.93 gpm  
PRESSURE REMAINING                    18.54 psi

THE ABOVE RESULTS INCLUDE 14.00 psi FRICTION LOSS AT REF. PT. # 2 FOR A

BACKFLOW PREVENTER                       METER  
 DETECTOR CHECK VALVE                     OTHER DEVICE

Life Safety Fire Protection  
Fire Sprinklers Save Lives

31 Fore Street

PAGE 3

FITTING Equivalent Length per NFPA 13 1994, 6-4.3

'-' Indicates Equivalent Length. 'T' Indicates Threaded Fitting

1=45 Elbow, 2=90 Elbow, 3='T'/Cross, 4=Butterfly Valve, 5=Gate Valve, 6=Swing Check Valve


FROM	TO	FLOW (gpm)	PIPE (ft)	FITS	EQV. (ft)	H-W C	PIPE TYPE	DIA. (in)	FRIC. (psi)	ELEV. (psi)	FROM (psi)	TO (psi)	DIFF (psi)
1	2	54.93	85.00	2235	62.34	140	111	4.300	0.001	0.867	62.42	61.45	0.10
2	3	54.93	10.00	22	8.62	120	2	2.157	0.025	2.600	61.45	44.39	14.47
3	4	0.00	12.00	2236	32.60	120	2	2.157	0.000	0.000	44.39	44.39	0.00
4	5	0.00	35.00	2222	17.24	120	2	2.157	0.000	0.000	44.39	44.39	0.00
5	6	0.00	13.00	0	0.00	120	2	2.157	0.000	0.000	44.39	44.39	0.00
5	70	0.00	7.00	3	5.30	120	1	1.380	0.000	0.000	44.39	44.39	0.00
6	71	0.00	7.00	3	5.30	120	1	1.380	0.000	0.000	44.39	44.39	0.00
70	72	0.00	9.00	0	0.00	120	1	1.380	0.000	0.000	44.39	44.39	0.00
71	73	0.00	9.00	0	0.00	120	1	1.380	0.000	0.000	44.39	44.39	0.00
72	74	0.00	9.00	0	0.00	120	1	1.049	0.000	0.000	44.39	44.39	0.00
73	75	0.00	9.00	0	0.00	120	1	1.049	0.000	0.000	44.39	44.39	0.00
74	76	0.00	9.00	0	0.00	120	1	1.049	0.000	0.000	44.39	44.39	0.00
75	77	0.00	9.00	0	0.00	120	1	1.049	0.000	0.000	44.39	44.39	0.00
3	7	54.93	6.00	3	6.57	120	2	1.442	0.179	0.000	44.39	42.14	2.25
7	8	54.93	19.00	222	24.04	150	9	1.400	0.137	3.900	42.14	32.35	5.89
8	9	54.93	22.00	3	6.01	150	9	1.400	0.137	9.533	32.35	18.98	3.83
9	10	54.93	38.00	2223	30.04	150	9	1.400	0.137	0.000	18.98	9.68	9.31
10	50	28.61	2.00	3	5.01	150	9	1.109	0.127	0.000	9.68	8.79	0.89
50	51	14.09	15.00	0	0.00	150	9	1.109	0.034	0.000	8.79	8.26	0.52
10	52	26.32	14.00	2	7.01	150	9	1.109	0.109	0.000	9.68	7.39	2.29
52	53	13.00	12.00	0	0.00	150	9	1.109	0.029	0.000	7.39	7.04	0.35

A MAX. VELOCITY OF 11.44 ft./sec. OCCURS BETWEEN REF. PT. 9 AND 10

Sprinkler-CALC Release 7.2 Win  
By Walsh Engineering Inc.  
North Kingstown R.I. U.S.A.

# WATER SUPPLY/DEMAND GRAPH

31 Fore Street



Sprinkler-CALC 7.2 Win

Life Safety Fire Protection  
Fire Sprinklers Save Lives  
97 Lower Jaffrey Road - Dublin NH

H Y D R A U L I C C A L C U L A T I O N S  
C O V E R S H E E T

31 Fore Street

W A T E R S U P P L Y

STATIC PRESSURE (psi) 81  
RESIDUAL PRESSURE (psi) 70  
RESIDUAL FLOW (gpm) 1125

B O O S T E R P U M P S

NUMBER OF BOOSTER PUMPS 0

S P R I N K L E R S

MAXIMUM SPACING OF SPRINKLERS (ft) 13  
MAXIMUM SPACING OF SPRINKLER LINES (ft) 9  
SPECIFIED DISCHARGE DENSITY (gpm/sq. ft.) .15

THIS SPRINKLER SYSTEM WILL DELIVER A DENSITY OF .15 gpm/sq. ft.  
FOR A DESIGN AREA OF 900 SQ. FT. OF FLOOR AREA


THIS SYSTEM OPERATES AT A FLOW OF 0.00 gpm AT A PRESSURE OF 0.00 psi  
AT THE BASE OF THE RISER (REF. PT. 0)

PIPES USED FOR THIS SYSTEM

=====

111 DUCTILE IRON (350)  
002 SCHEDULE 10  
001 SCHEDULE 40  
009 BLAZEMASTER CPVC

Jeffrey G. Denis  
NICET Level 3  
Certification Number 89807



~~~~~  
SPRINKLER SYSTEM ANALYSIS TO SHOW THE MAXIMUM DENSITY AVAILABLE  
WITH ZERO PRESSURE REMAINING  
~~~~~

THE FOLLOWING SPRINKLERS ARE OPERATING IN:

TEST AREA 1     TEST AREA 2     TEST AREA 3     REMOTE AREA

Elevation of sprinklers = Elevation above water test.

REF. PT.	K	ELEV. ft	FLOW gpm	PRESSURE psi
70	5.60	8.00	27.60	24.28
71	5.60	8.00	27.19	23.57
72	5.60	8.00	25.76	21.16
73	5.60	8.00	25.39	20.55
74	5.60	8.00	22.50	16.14
75	5.60	8.00	22.17	15.67
76	5.60	8.00	21.56	14.82
77	5.60	8.00	21.23	14.37

THE SPRINKLER SYSTEM FLOW IS 193.40 gpm

THE OUTSIDE HOSE FLOW AT REFERENCE POINT NO. 1 IS 0.00 gpm

THE INSIDE HOSE     RACK SPKLR'S.

YARD HYDT. FLOW IS 0.00 gpm

THE MINIMUM DENSITY PROVIDED BY THIS SYSTEM IS 0.181 gpm/sq. ft.

THE FOLLOWING PRESSURES & FLOWS OCCUR

---> AT REF. PT. 1 <---

STATIC PRESSURE	81.00 psi	
RESIDUAL PRESSURE	70.00 psi	AT 1125.00 gpm
TOTAL SYSTEM FLOW	193.40 gpm	
AVAILABLE PRESSURE	80.58 psi	AT 193.40 gpm
OPERATING PRESSURE	80.58 psi	AT 193.40 gpm
PRESSURE REMAINING	0.00 psi	

THE ABOVE RESULTS INCLUDE 14.00 psi FRICTION LOSS AT REF. PT. # 2 FOR A

BACKFLOW PREVENTER                     METER  
 DETECTOR CHECK VALVE                  OTHER DEVICE

HYDRAULIC CALCULATIONS AT SPECIFIED DENSITY

THE FOLLOWING SPRINKLERS ARE OPERATING IN:

TEST AREA 1     TEST AREA 2     TEST AREA 3     REMOTE AREA

Elevation of sprinklers = Elevation above water test.

REF. PT.	K	ELEV. ft	FLOW gpm	PRESSURE psi
70	5.60	8.00	22.96	16.81
71	5.60	8.00	22.62	16.31
72	5.60	8.00	21.41	14.61
73	5.60	8.00	21.09	14.18
74	5.60	8.00	18.64	11.07
75	5.60	8.00	18.34	10.72
76	5.60	8.00	17.80	10.10
77	5.60	8.00	17.55	9.82

THE SPRINKLER SYSTEM FLOW IS 160.40 gpm

THE OUTSIDE HOSE FLOW AT REFERENCE POINT NO. 1 IS 0.00 gpm

THE INSIDE HOSE     RACK SPKLR'S.

YARD HYDT. FLOW IS 0.00 gpm

THE MINIMUM DENSITY PROVIDED BY THIS SYSTEM IS 0.150 gpm/sq. ft.

THE FOLLOWING PRESSURES & FLOWS OCCUR

---> AT REF. PT. 1 <---

STATIC PRESSURE	81.00 psi	
RESIDUAL PRESSURE	70.00 psi	AT 1125.00 gpm
TOTAL SYSTEM FLOW	160.40 gpm	
AVAILABLE PRESSURE	80.70 psi	AT 160.40 gpm
OPERATING PRESSURE	61.73 psi	AT 160.40 gpm
PRESSURE REMAINING	18.97 psi	

THE ABOVE RESULTS INCLUDE 14.00 psi FRICTION LOSS AT REF. PT. # 2 FOR A

BACKFLOW PREVENTER                     METER  
 DETECTOR CHECK VALVE                 OTHER DEVICE



Life Safety Fire Protection  
Fire Sprinklers Save Lives

31 Fore Street

~~~~~  
FITTING Equivalent Length per NFPA 13 1994, 6-4.3

'-' Indicates Equivalent Length. 'T' Indicates Threaded Fitting

1=45 Elbow, 2=90 Elbow, 3='T'/Cross, 4=Butterfly Valve, 5=Gate Valve, 6=Swing Check Valve


| FROM | TO | FLOW<br>(gpm) | PIPE<br>(ft) | FITS | EQV.<br>(ft) | H-W<br>C | PIPE<br>TYPE | DIA.<br>(in) | FRIC.<br>(psi) | ELEV.<br>(psi) | FROM<br>(psi) | TO<br>(psi) | DIFF<br>(psi) |
|------|----|---------------|--------------|------|--------------|----------|--------------|--------------|----------------|----------------|---------------|-------------|---------------|
| 1    | 2  | 160.40        | 85.00        | 2235 | 62.34        | 140      | 111          | 4.300        | 0.005          | 0.867          | 61.73         | 60.16       | 0.71          |
| 2    | 3  | 160.40        | 10.00        | 22   | 8.62         | 120      | 2            | 2.157        | 0.183          | 2.600          | 60.16         | 40.14       | 17.41         |
| 3    | 4  | 160.40        | 12.00        | 2236 | 32.60        | 120      | 2            | 2.157        | 0.183          | 0.000          | 40.14         | 31.96       | 8.18          |
| 4    | 5  | 160.40        | 35.00        | 2222 | 17.24        | 120      | 2            | 2.157        | 0.183          | 0.000          | 31.96         | 22.39       | 9.57          |
| 5    | 6  | 79.59         | 13.00        | 0    | 0.00         | 120      | 2            | 2.157        | 0.050          | 0.000          | 22.39         | 21.73       | 0.66          |
| 5    | 70 | 80.81         | 7.00         | 3    | 5.30         | 120      | 1            | 1.380        | 0.453          | 0.000          | 22.39         | 16.81       | 5.57          |
| 6    | 71 | 79.59         | 7.00         | 3    | 5.30         | 120      | 1            | 1.380        | 0.441          | 0.000          | 21.73         | 16.31       | 5.42          |
| 70   | 72 | 57.85         | 9.00         | 0    | 0.00         | 120      | 1            | 1.380        | 0.244          | 0.000          | 16.81         | 14.61       | 2.20          |
| 71   | 73 | 56.97         | 9.00         | 0    | 0.00         | 120      | 1            | 1.380        | 0.237          | 0.000          | 16.31         | 14.18       | 2.13          |
| 72   | 74 | 36.44         | 9.00         | 0    | 0.00         | 120      | 1            | 1.049        | 0.394          | 0.000          | 14.61         | 11.07       | 3.54          |
| 73   | 75 | 35.89         | 9.00         | 0    | 0.00         | 120      | 1            | 1.049        | 0.383          | 0.000          | 14.18         | 10.72       | 3.46          |
| 74   | 76 | 17.80         | 9.00         | 0    | 0.00         | 120      | 1            | 1.049        | 0.105          | 0.000          | 11.07         | 10.10       | 0.97          |
| 75   | 77 | 17.55         | 9.00         | 0    | 0.00         | 120      | 1            | 1.049        | 0.102          | 0.000          | 10.72         | 9.82        | 0.90          |
| 3    | 7  | 0.00          | 6.00         | 3    | 6.57         | 120      | 2            | 1.442        | 0.000          | 0.000          | 40.14         | 40.14       | 0.00          |
| 7    | 8  | 0.00          | 19.00        | 222  | 24.04        | 150      | 9            | 1.400        | 0.000          | 3.900          | 40.14         | 36.24       | -0.00         |
| 8    | 9  | 0.00          | 22.00        | 3    | 6.01         | 150      | 9            | 1.400        | 0.000          | 9.533          | 36.24         | 26.71       | -0.00         |
| 9    | 10 | 0.00          | 38.00        | 2223 | 30.04        | 150      | 9            | 1.400        | 0.000          | 0.000          | 26.71         | 26.71       | 0.00          |
| 10   | 50 | 0.00          | 2.00         | 3    | 5.01         | 150      | 9            | 1.109        | 0.000          | 0.000          | 26.71         | 26.71       | 0.00          |
| 50   | 51 | 0.00          | 15.00        | 0    | 0.00         | 150      | 9            | 1.109        | 0.000          | 0.000          | 26.71         | 26.71       | 0.00          |
| 10   | 52 | 0.00          | 14.00        | 2    | 7.01         | 150      | 9            | 1.109        | 0.000          | 0.000          | 26.71         | 26.71       | 0.00          |
| 52   | 53 | 0.00          | 12.00        | 0    | 0.00         | 150      | 9            | 1.109        | 0.000          | 0.000          | 26.71         | 26.71       | 0.00          |

A MAX. VELOCITY OF 17.33 ft./sec. OCCURS BETWEEN REF. PT. 5 AND 70

Sprinkler-CALC Release 7.2 Win  
By Walsh Engineering Inc.  
North Kingstown R.I. U.S.A.

# WATER SUPPLY/DEMAND GRAPH

31 Fore Street



Sprinkler-CALC 7.2 Win