
MEMORANDUM

To: FILE

From: Jean Fraser

Subject: Application ID: 2016-005

Date: 2/5/2016

Comments Submitted by: Keith Gautreau/Fire on 1/20/2016

Emergency access is real good to this site being on the corner of Fore and Waterville.

Comments Submitted by: Keith Gautreau/Fire on 1/20/2016

Hydrant located right in front of this building will be adequate water supply for this 4 unit light hazard building.

Comments Submitted by: Keith Gautreau/Fire on 2/5/2016

NFPA 101 2009 ed. Would allow a single means of egress in a sprinklered building up to 4 stories in height.