

60 Caledonia St.
Portland ME 04102
July 7, 1998

Dear Lt. McDougall,

In response to our conversation this morning, I am writing to thank you for your approval of the installation of three 20-minute U.L.-rated pre-hung wooden fire doors in my building at 53 Sheridan St, rather than one-hour rated metal doors. BRC of Portland will install the doors in the odd-sized openings which are 28" x 78", 28" x 76", and 24" x 80". I will be in touch when the work is completed and thank you again for your consideration.

Sincerely,

Margaret J. McCain

PORTLAND FIRE DEPARTMENT
FIRE PREVENTION BUREAU
180 CONGRESS STREET
PORTLAND, MAINE 04102

Approved: 7/8/98
[Signature]