

Benjamin Wallace - RE: 190 Congress Street Portland Me

From: "Piercy, Jay R (GE Power & Water)" <jay.piercy@ge.com>
To: <fireinspector@portlandmaine.gov>
Date: 9/18/2011 10:52 PM
Subject: RE: 190 Congress Street Portland Me
CC: <wallaceb@portlandmaine.gov>

Mr. Wallace,

Update to my previous note.

Violation number 1

3 Combo smoke/CO detectors are installed on the first floor. I will install the other two next weekend.

Violation number 2

Plumber being scheduled.
Smoke foam completed.

Violation number 3

Combustibles are removed.

Violation number 4

Drop lights are coiled up and put away.

Thank you,

Jay Piercy

From: Piercy, Jay R (GE Power & Water)
Sent: Friday, September 09, 2011 11:34 AM
To: fireinspector@portlandmaine.gov
Cc: wallaceb@portlandmaine.gov
Subject: FW: 190 Congress Street Portland Me

I think I had the email address below wrong... Please see notes regarding 190 Congress... Jay

From: Piercy, Jay R (GE Power & Water)
Sent: Friday, September 09, 2011 9:47 AM
To: WALLACEB@PORTLANDME.GOV
Subject: FW: 190 Congress Street Portland Me

From: Piercy, Jay R (GE Power & Water)
Sent: Friday, September 09, 2011 9:46 AM
To: wallaceb@portlandme.gov
Subject: 190 Congress Street Portland Me

Mr. Wallace,

I am working on some of the issues at 190 Congress this weekend.

I have contacted my plumber to install the fire protection over the furnace and will let you know when that is done.

Will pick up the combo unit hard wired smoke/CO units over the weekend and begin installing them (I may not finish this weekend though).

Great Stuff will be done asap.

Combustibles have been removed from the front stair case.

Temporary drop lights will be stored and only used as necessary.

I'll keep you posted on progress.

Thank you,

Jay R. Piercy

O 207-353-2190

C 404-431-7441