## DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK

ITY OF PORTLAN

BUILDING PERM

#### This is to certify that

#### Located at

107 Monument St

JUDKINS TYLER L & KATHERINE L COHEN JTS

**PERMIT ID:** 2015-01002 **ISSUE DATE:** 09/08/2015 **CBL:** 017 C016001

has permission to Build a new 3 story, 3 bedrooms, 4 bath home with no garage.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED. A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ David Petruccelli

/s/ Tammy Munson

Fire Official

**Building Official** 

### THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

*Fire Department* **Classification:** One or Two Family Dwellings ENTIRE



# BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY) or email: buildinginspections@portlandmaine.gov

# Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

## **REQUIRED INSPECTIONS:**

Final - DRC

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit			Permit No:	Date Applied For:	CBL:	
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716			2015-01002	05/06/2015	017 C016001	
			roposed Project Description:			
Sin	ngle Family Home	Build a	new 3 story, 3 bed	lrooms, 4 bath home	with no garage.	
		viewer:	Ann Machado	Approval Da		
	ote:				Ok to Issue: 🗹	
	<ul><li>Conditions:</li><li>1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.</li></ul>					
2)	As discussed during the review process, the property must be clearly identified prior to pouring concrete and compliance with the required setbacks must be established. Due to the proximity of the setbacks of the proposed structure, it may be required to be located by a surveyor.					
3)	This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval.					
Note:		viewer:	Tammy Munson	Approval Da	te: 08/11/2015 Ok to Issue: ☑	
	<ul> <li>Conditions:</li> <li>Window sills in locations more than 72 inches from finished grade shall be a minimum of 24 inches above the finished floor of the room, unless a window fall prevention devices is installed in accordance with section IRC Sec. R612.3 or IBC Sec. 1405.13.2.</li> </ul>					
2)	Tempered safety glazing is required at all hazardous locations per IRC 2009 Sec. R308.4 and IBC 2009 Sec. 2406.4					
3)	Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.					
4)	Energy Code compliance shall be confirmed via a ResCheck or ComCheck, http://www.energycodes.gov/software.stm#tabs-2 certificate or alternate program or testing standard for thermal envelope and MEP systems. This documentation is required prior to associated work for these items.					
5)	Egress size windows are required (1) in each bedroom per IRC Sec. R310 or per the State Fire Marshal policies for existing buildings.					
6)	6) The design load spec sheets for any engineered beam(s) / Trusses must be submitted to this office.					
7)	Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.					
8)	This permit is approved based upon information provided by the a approved plans requires separate review and approval prior to wor		or design professio	onal. Any deviation fr	om the final	
	ept: Fire Status: Approved w/Conditions Re-	viewer:	David Petruccelli		te: 06/12/2015 Ok to Issue: ☑	
Conditions:						
1)	<ul> <li>Single-station Carbon Monoxide (CO) alarms are required. They shall be powered by the building's electrical service with battery backup and shall be interconnected. CO alarms shall be installed in the following locations:         <ol> <li>Outside each separate dwelling unit sleeping area in the immediate vicinity of the bedrooms</li> <li>On every occupiable level of the dwelling unit, including basements, excluding attics and crawl spaces</li> </ol> </li> </ul>					
2)	A sprinkler system shall be installed in accordance with NFPA 131 required.	D. A no :	fee One- or Two-fa	amily CITY Fire Spri	inkler Permit is	

3)	<ul> <li>3) Single-station photoelectric smoke alarms are required. They shall be powered by the building's electrical service with battery backup and shall be interconnected. Smoke alarms shall be installed in the following locations: <ul> <li>(1) All sleeping rooms</li> <li>(2) Outside each separate sleeping area, in the immediate vicinity of the sleeping rooms</li> <li>(3) On each level of the dwelling unit, including basements.</li> </ul></li></ul>						
4)	Street addresses shall be marked on the structure and shall be as approved by the City E-911 Addressing Officer.						
5)	) Construction or installation shall comply with City Code Chapter 10.						
6)	) Shall meet the requirements of 2009 NFPA 1 Fire Code.						
7)	7) A copy of the State Sprinkler permit with RMS date and signature shall be provided prior to scheduling of the final inspection.						
D	ept: DRC Status: Approved w/Conditions Reviewer: Philip DiPierro Approval Date: 07/31/2015						
	ote: Prior to issuing the building permit, please check with Caitlin Cameron to make sure the design review Ok to Issue: 🗹 requirements have been met.						
	Conditions:						
1)	) The applicant shall have a licensed surveyor install, prior to the issuance of any Certificate of Occupancy, permanent mounumentation/pins identifying property corners.						
2)	) The Development Review Coordinator (874-8632) must be notified five (5) working days prior to date required for final site inspection. Please make allowances for completion of site plan requirements determined to be incomplete or defective during the inspection. This is essential as all site plan requirements must be completed and approved by the Development Review Coordinator prior to issuance of a Certificate of Occupancy. Please schedule any property closing with these requirements in mind.						
3)	3) All damage to sidewalk, curb, street, or public utilities shall be repaired to City of Portland standards prior to issuance of a certificate of occupancy. The sidewalk along the site's street frontage must be constructed in brick built to City of Portland technical standards.						
4)	A sewer permit is required for your project. Please contact Carol Merritt at 874-8300, ext. 8822. The Wastewater and Drainage section of Public Services must be notified five (5) working days prior to sewer connection to schedule an inspector for your site.						
5)	) A street opening permit(s) is required for your site. Please contact Carol Merritt ay 874-8300, ext. 8822. (Only excavators licensed by the City of Portland are eligible.)						
6)	) All Site work (final grading, landscaping, loam and seed) must be completed prior to issuance of a certificate of occupancy.						
7)	) Erosion and Sedimentation control shall be established and inspected by the Development Review Coordinator prior to soil disturbance, and shall be done in accordance with Best Management Practices, Maine Department of Environmental Protection Technical and Design Standards and Guidelines. All Erosion and Sedimentation control measures must be inspected and maintaned daily.						
8)	A performance guarantee will be required to cover the cost of site work not completed due to seasonal conditions ie., finish grading, loaming, seeding, mulching, installation of street trees, etc. The performance guarantee must be reviewed, approved, and accepted by the Planning Authority prior to the release of a Temporary Certificate of Occupancy.						
9)	The site shall be developed and maintained as depicted in the approved site plan, written submission of the applicant, and these written conditions of approval. The modification of the approved site plan or alteration of a parcel which was the subject of site plan approval shall require the prior approval of a revised site plan by the Planning Authority.						
10	A waiver for driveway separation has been granted given the fact that the existing house is being demolished and the driveway currently exists in this location, and that no resonable alternative meeting City standards for locating the driveway entrance in a different location exists.						
11	Two (2) City of Portland approved species and size trees must be planted on your street frontage prior to issuance of a Certificate of Occupancy. A contribution in the amount of \$200 per tree may be made to the City's street tree fund in lieu of planting street trees if approved by the City Arborist.						
12	The Development Review Coordinator reserves the right to require additional lot grading or other drainage improvements as necessary due to field conditions.						