

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

JUDKINS TYLER L & KATHERINE L COHEN JTS

**Located at**

107 MONUMENT ST

**PERMIT ID:** 2016-00198

**ISSUE DATE:** 02/18/2016

**CBL:** 017 C016001

has permission to **Replace existing chain link fence with a 8' wooden fence.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

**Fire Official**

/s/ Tammy Munson

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*  
single family

*Building Inspections*

*Fire Department*

**PERMIT ID:** 2016-00198

**Located at:** 107 MONUMENT ST

**CBL:** 017 C016001

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2016-00198	<b>Date Applied For:</b> 01/28/2016	<b>CBL:</b> 017 C016001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-				
<b>Proposed Use:</b> Single Family	<b>Proposed Project Description:</b> Replace existing chain link fence with a 8' wooden fence.			
<b>Dept:</b> Zoning <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Christina Stacey <b>Approval Date:</b> 02/18/2016 <b>Note:</b> R-6 zone <b>Ok to Issue:</b> <input checked="" type="checkbox"/> Proposed fence 8' height, set back 22' from front prop line. Sec 14-426 restricts fence height to 4' or less within 25' of front line unless DPW approves. DPW approval received 2/18/16 - OK <b>Conditions</b> 1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				