



# PORTLAND MAINE

*Strengthening a Remarkable City, Building a Community for Life • [www.portlandmaine.gov](http://www.portlandmaine.gov)*

*Lee Urban- Director of Planning and Development  
Aaron Shapiro- Director of Housing and Neighborhood Services  
Michael J. Nugent- Manager of Inspection Services*

November 30, 2004

Joseph Bauer  
72 Waterville St. Apt. 3  
Portland, Maine. 04101

Re: Permit #041378

Dear Mr. Bauer,

I have reviewed the plans that you submitted on 11/29/04, and need additional information.

On 11/24/04, it was indicated that specific details were required for the roof system, particularly the ridge, hangers, headers and how the ridge beam would tie into the structure and how you would accommodate the additional point load on the members through the building.

I have attached copies what was submitted and I have put some specific notes on the plans. I also included samples of suitable framing details. I cannot issue this permit until building code compliance has been established, and at this point it has not.

Please contact me at 874-8700 to discuss the matter.

Sincerely,

Mike Nugent  
Manager of Inspection Services