

A.P. - 24 Astorville St.

F.P. C. H. Murray  
Box 2297  
South Fortland

May 13, 1965

cc to: William Bellfontaine  
Shore Road, Cape Elizabeth

Consent

Permit to demolish a 2-story open porch 15'x7' and to construct a new 2-story open porch 8'x7'. As being issued subject to restrictions as follows:

1. Corner posts of open structures shall bear directly upon the sill and shall be continuous from sill to plate with lap splices no less than 18" in length permitted.
2. If angles are to be used to support the sills at the corner posts we will need to know the size of angles and size and number of lag bolts to be used in each case. These connections will need to be approved before the form inspection for the concrete pier forms is called for.

Very truly yours,

Archie L. Seekins  
Deputy Building Inspection Director

ALM:in