

Memorandum

To: Steve Thomas

CC:

From: Mike Nugent/Manager of Inspection Services

Date: 09/03/2002

Re: 36 Waterville St. (017 E015)

I have done a partial review of the building plans for permit #020834 and need the following:

- 1) What percent of the existing basement is 6' above grade, it appears that it's less than 50% .
- 2) The building addition will have to be type 5A construction, please review table 602 of the '99 BOCA Code and provide information on the required fire separations.
- 3) A waiver request for the openings on the North elevation with supporting information.
- 4) What is the actual distance between the two buildings(36 and 40 Waterville)?
- 5) The means of egress stairways and door, Fire rating & Details ?
- 6) Guard rail material/ Details
- 7) Letter from owner with fire suppression commitment.